

Application No:	Consultees Name:	Consultees Addr:	Received:	Comment:	Response:
2014/4803/P	Prakash Kaneria (Director)	Guidezone Ltd Ambassadors Bloomsbury Hotel 12 Upper Woburn Place London WC1H 0HX	27/08/2014 16:49:00	COMMNT	<p>Dear Sir</p> <p>I have been made aware of the above planning application and wish to make the following comment.</p> <p>The external metal staircase at the rear of the building does not serve any meaningful means of fire escape from the 2nd and 3rd floor of the property at 1 to 7 Woburn Walk as there is no means of escape to the street level from the flat roof space at the first floor level.</p> <p>This will be an import consideration for Camden Council in their decision whether or not to allow planning consent for change of use if the application requires a safe alternative means of fire escape for the residents from the 2nd and 3rd floors of 1 to 7 Woburn Walk.</p> <p>Yours sincerely</p> <p>Prakash Kaneria Director Guidezone Limited</p>
