

Item	Description	Model Number	Dimenslon WxHxD (mm)	Welght (KG)	Noise Level (dBA)	Duty	Electrical Data	Comments
AHU1	Air Vent Technology Air Handling Unit	STP06/S	1950 x 1000 x 1875	542	69 < 82	4.0m³/s @ 800Pa	3.0kW Motor, 400V/3ph/50Hz FLC: 6.18A 2 Stage 36kW Electric Heater Battery	Twin Motors
EF1	Air Vent Technology Fan	STP500/E/DUP	2130 x 900 x 1110	640	79>91	6.00m³/s @ 1400Pa	7.50kW, 380V/3ph/50Hz FLC: 14.5A Plenum Fan x 2	
EF2	Systemair Circular Duct Fan	K 250L	Ø336 (+40) x 145 Ø250 spigots	5.0	44 @ 3m	0.280m³/s	157W, 0.70A 230V/1ph/50Hz	
EF3	Systemair Circular Duct Fan	K 200L	Ø336 (+40) x 174 Ø200 spigots	4.5	51 @ 3m	0.270m³/s	159W, 0.71A 230V/1ph/50Hz	
AC1	Mitsubishi Ducted Indoor AC Unit	PEFY-P125VMA-ER2	1400 x 250 x 732	42	40	14kW Nominal Cooling	220-240V/1ph/50Hz RC: 1.36A (H) 1.47A (C)	
AC2	Mitsubishi Ducted Indoor AC Unit	PEFY-P125VMA-ER2	1400 x 250 x 732	42	40	14kW Nominal Cooling	220-240V/1ph/50Hz RC: 1.36A (H) 1.47A (C)	
AC3	Mitsubishi Ducted Indoor AC Unit	PEFY-P125VMA-ER2	1400 x 250 x 732	42	40	14kW Nominal Cooling	220-240V/1ph/50Hz RC: 1.36A (H) 1.47A (C)	
AC4	Mitsubishi Ducted Indoor AC Unit	PEFY-P125VMA-ER2	1400 x 250 x 732	42	40	14kW Nominal Cooling	220-240V/1ph/50Hz RC: 1.36A (H) 1.47A (C)	
AC5	Toshiba RAV Wall Mounted Indoor Unit	RAV-SM566KRT-E	1050 x 320 x 228	12	39	5.1kW Nominal Cooling	N/A	Office
CU1	Mitsubishi VRF Outdoor Unit	PUHY-P500YSJM-A	1840 x 1710 x 760	480	60	56kW Nominal Cooling	380-415V/3ph/50Hz RC: 23.7A SC: 8A	
CU2	Toshiba RAV Heat Pump Outdoor Unit	RAV-SM563AT-E	780 x 550 x 290	38	48	5.0kW Nom. Cooling 217l/s @ 42Pa	230V/1ph/50Hz Run Cur:8.2A Fused At:16A	
DC1	Thermoscreen Air Curtain C Range	C1000ENT	1137 x 275 x 198	18	55	4.5/9kW Output	400V/3ph/50Hz Loading: 13.7A per phase	
CC1	Marstair Cellar Cooling Indoor Unit	CX(E) 70	888 x 483 x 320	23	58	6.8kW	230V/1ph/50Hz FLC: 13.8A Motor Rated Fuse Size: 25A	
CCC1	Marstair Cellar Cooling Outdoor Unit	CKC 80	1000 x 720 x 310	66	49 @ 1.5m	6.8kW	400V/3ph/50Hz FLC: 13.8A Motor Rated Fuse Size: 25A	

-	-	-	-
No.	Date	Rev. By	Revision Description

Client:

Drake & Morgan

Project :

Regents Place

Drawing Title :

Equipment Schedule

Drawing No.:	Rev:
007-003-ES	-

Scale: N/A

Drawn By: RF	Date: 16-06-14
--------------	----------------

chapman
ventilation

Unit 2 Little Mundells
Welwyn Garden City
Hertfordshire AL7 1EW
Tel: 01707 372858 Fax: 01707 325001
E-mail: info@chapmanventilation.co.uk
Web: www.chapmanventilation.co.uk