

RMM/RPW/DP3516
24 July 2014

Ms S Ballantyne-Way
London Borough of Camden
6th Floor
Town Hall Extension, (Environment)
Argyle Street
London
WC1H 8EQ

DP9 Ltd
100 Pall Mall
London SW1Y 5NQ

Registered No. 05092507

telephone 020 7004 1700
facsimile 020 7004 1790

www.dp9.co.uk

Dear Sarah

**TOWN AND COUNTRY PLANNING ACT 1990 (AS AMENDED)
GOSH 20 GUILFORD STREET – SECTION 96A NON MATERIAL AMENDMENT**

We write on behalf of the applicants, Great Ormond Street Hospital Children's Charity and enclose a planning application for non-material amendments to planning permission under LPA reference number 2014/2880/P granted on 20 June 2014 for the "*erection of an electrical substation in rear yard adjoining Millman Mews*"

This submission includes:

- Four copies of completed application form; and
- Four copies of the following drawing numbers:
 - 464_PL_02 Rev 1;
 - 464_PL_05 Rev 1; and
 - 464_PL_06 Rev 1.

A cheque for £195 is enclosed to cover the application fee.

Proposed Changes

The extract louvre on the south elevation has increased in height by approximately 10cm in accordance with UKPN's ventilation requirements. On the east elevation, the door arrangement has been mirrored to accommodate the internal electrical plant arrangement. Due to health and safety reasons UKPN have requested that the previous steel lintels above the doors on the east elevation and the extract louvre on the south elevation be replaced with precast concrete. Finally, and following UKPN's request to improve the watertightness of the substation enclosure, a 15cm continuous concrete upstand has been incorporated at the base of all brickwork walls

We trust you will find the enclosed certification is sufficient for the discharge of condition 4. Should you wish to discuss the above submission please contact Rory McManus of this office.

Yours faithfully

A handwritten signature in black ink that reads 'DP9 Ltd'.

DP9 Ltd

Encl: