

	0	1	2	3	4	5	6
A							
B	Rectangular Valve Chamber Plan View The plan view shows a rectangular concrete base with a central service access opening. The opening is 1200x675 mm. The internal dimensions of the base are 1475 mm by 1875 mm. The concrete base has a thickness of 1025 mm internally and 1425 mm externally.						
C	Rectangular Valve Chamber Section The section view shows the vertical profile of the rectangular valve chamber. The ground level is at +0.00m. The concrete base is 1475 mm wide and 1675 mm high. The internal width is 1400 mm and the internal height is 1475 mm. The concrete base is 150 mm thick.						
D	Circular Valve Chamber Section The section view shows the vertical profile of the circular valve chamber. The ground level is at +0.00m. The concrete base is 2600 mm wide and 2400 mm high. The internal width is 1450 mm and the internal height is 1475 mm. The concrete base is 150 mm thick.						
E	Circular Valve Chamber Plan View The plan view shows a circular concrete base with a central service access opening. The opening is 1200x675 mm. The internal dimensions of the base are 2400 mm by 2600 mm. The concrete base has a thickness of 1025 mm internally and 1425 mm externally.						
F	Typical Valve Chamber Arrangement The arrangement view shows the layout of the valve chambers. The ground level is at +0.00m. The concrete base is 1475 mm wide and 1675 mm high. The internal width is 1400 mm and the internal height is 1475 mm. The concrete base is 150 mm thick.						



geothermalinternational

Notes:

- To be read with all other project drawings and specifications.
- Dimensions in millimeters unless otherwise stated.
- Report any errors, omissions or changes in or to this drawing to Geothermal International.
- Do not scale from this drawing.
- All builders work in connection with the Geothermal Installation by others

FOR APPROVAL

Rev.	By	Chkd	Appr'd	Date	Description
A	MP	RM	RM	10-May-11	Issued for Approval

The copyright in this document (including in electronic form) shall remain vested in Geothermal International. It is hereby acknowledged that the design and construction of the project is the responsibility of the client and that the client shall be liable for the use by any person of this document for any purpose other than that for which it was provided by GIL. This document shall not be reproduced in any form or by any means without the express written authority of GIL.

Client

BAM Construction Ltd.

ground source heating, cooling & hot water
geothermal installation by: **Geothermal International**
142 Albany Road, Farnborough, Hampshire, GU14 7JH
01489 444 888
www.geothermal-international.co.uk

Project: South Camden Community School

Drawing

Geothermal
Typical Valve Chamber
Arrangement

Drawn by:	MP	Date:	10-May-11
Checked by:	RM	Date:	10-May-11
Approved by:	RM	Date:	10-May-11
Drawing No:	SCCS-GIL-0007	Revision	A

Drawing Scale: 1:20 @ A1