

Comments Form

Name..... VAN HEYNINGEN + HAWARD ARCHITECTS.

Address..... 1A HARMOOD ST, LONDON, NW1 8BN.

Email address..... [REDACTED]

Telephone number..... [REDACTED]

Planning application number..... 2014/5516/P

Planning application address..... 38 CHALK FARM ROAD, NW1 8AJ

I support the application (please state reasons below)

I object to the application (please state reasons below)



Your comments

OUR OFFICES AT 1A HARMOOD STREET HAVE OPENING WINDOWS FACING THE PROPOSED LOCATION OF THE AIR EXTRACT + AIR CONDITIONING TO THE REAR OF 38, CHALK FARM ROAD.

AS OUR OFFICES ARE VENTILATED BY OPENING THE WINDOWS WE REQUEST THE FOLLOWING LIMITATIONS ON THE APPLICANT:

- 1) THE NOISE GENERATED BY VENTILATION PLANT IS NO LOUDER THAN BACKGROUND NOISE LEVELS;
- 2) VENTILATION DUCTWORK TERMINATED AT/ABOVE ROOF LEVEL TO AVOID UNWANTED SMELLS ENTERING OUR PREMISES.