Sent: 24 October 2014 15:03

Planning To:

Subject: 3rd Party Planning Application - 2014/6060/P

London Borough of Camden Camden Town Hall Argyle Street Euston Road London WC1H 8EQ

24 October 2014

Dear Sir/Madam

Re: 251 - 258 TOTTENHAM COURT ROAD &, 1 BEDFORD AVENUE, LONDON, W1T 7JY

Waste Comments

Thames Water have reviewed the documentation provided and cannot agree to the discharging of Condition 13.

Our DTS Ref: 36736

Your Ref: 2014/6060/P

Water Comments

Supplementary Comments

Despite not installing any pilling the excavation and subsequent construction and additional loading are likely to affect Thames Water assets in close proximity to the footprint of your site. As such this condition cannot be discharged until all parties are satisfied the proposed works will not have a detrimental impact on these Assets. Please contact Jonathon Langford at Thames Water Developer Services to discuss the process for conducting a full impact assessment for any piling or excavation on site. (Jonathon Langford2@thameswater.co.uk) Please use the following subject reference in all future correspondence: Pilling Condition Impact Assessment - DTS site ID 36736

Yours faithfully **Development Planning Department**

Development Planning, Thames Water, Maple Lodge STW, Denham Way, Rickmansworth. WD3 9SQ

Tel:020 3577 9998

Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to

devcon.team@thameswater.co.uk

Did you know you can manage your account online? Pay a bill, set up a Direct Debit, change your details or even register a change of address at the click of a button, 24 hours a day. Please visit www.thameswater.co.uk.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales each with their registered office at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of Thames Water Limited or its subsidiaries. If you are not the intended recipient of this email you may not copy, use, forward or disclose its contents to any other person; please notify our Computer Service Desk on +44 (0) 203 577 8888 and destroy and delete the message and any attachments from your system.

We provide the essential service that's at the heart of daily life.