

Specification Sheet

Proposed Condensers for the new VRF equipment are as follows:

System (floor served)	Qty	Mitsubishi Electric Model Reference	Height (mm)	Width (mm)	Depth (mm)	Sound Pressure (dBA)	Sound Pressure (dBA low noise mode)	Colour
System 6	1	PURY-P250YJM	1650	920	760	57	44	Munsell 5Y8/1
System 5	1	PURY-P200YJM	1650	920	760	56	44	Munsell 5Y8/1
System 4	1	PURY-P250YJM	1650	920	760	57	44	Munsell 5Y8/1
System 3	1	PURY-P250YJM	1650	920	760	57	44	Munsell 5Y8/1
System 2	1	PURY-P250YJM	1650	920	760	57	44	Munsell 5Y8/1

System 1	1	PURY-P250YJM	1650	920	760	57	44	Munsell 5Y8/1
Reception	1	PUHZ-ZRP- 71VHA	950	943	330	48	-	Munsell 5Y8/1
AHU DX Unit	2	PUHZ-RP200 YKAR	1338	950	360	59	-	Munsell 5Y8/1

New Air Handling Unit by Delair:

Qty	Dalair Model Reference	Height (mm)	Width (mm)	Depth (mm)	Colour
1	MA50/8/S	1825	6750	1700	Goosewing Grey