

Mr Terry Foulsham  
The Basement Design Studio  
Suite 17 Maple Court  
Grove Park  
White Waltham  
Berkshire  
SL6 3LW

Application Ref: **2014/5832/P**  
Please ask for: **Alex McDougall**  
Telephone: 020 7974 **2053**

14 November 2014

Dear Sir/Madam

## **DECISION**

Town and Country Planning Act 1990 (as amended)

### **Householder Application Granted**

Address:  
**23 Narcissus Road**  
**London**  
**NW6 1TJ**

Proposal: Excavation to enlarge existing single storey basement level including enlarged front lightwell, new stairs in front lightwell and new rear lightwell, alterations to fenestration and erection of a single storey ground floor rear infill extension.

Drawing Nos: 14-029-01-1, 14-029-01-2, 14-029-01-3, 14-029-01-4, 14-029-02-1, 14-029-02-2, 14-029-02-3, Sustainability Statement, Design & Access Statement, Construction Management Plan Rev: A, Basement Structural Method Statement Ref: 140807.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).



- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Core Strategy and policy DP24 of the London Borough of Camden Local Development Framework Development Policies.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans: 14-029-01-1, 14-029-01-2, 14-029-01-3, 14-029-01-4, 14-029-02-1, 14-029-02-2, 14-029-02-3, Sustainability Statement, Design & Access Statement, Construction Management Plan Rev: A, Basement Structural Method Statement Ref: 140807.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 4 The development hereby approved shall not commence until such time as a suitably qualified chartered engineer with membership of the appropriate professional body has been appointed to inspect, approve and monitor the critical elements of both permanent and temporary basement construction works throughout their duration to ensure compliance with the design which has been checked and approved by a building control body. Details of the appointment and the appointee's responsibilities shall be submitted to and approved in writing by the local planning authority prior to the commencement of development. Any subsequent change or reappointment shall be confirmed forthwith for the duration of the construction works.

Reason: To safeguard the appearance and structural stability of neighbouring buildings and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Development Policies and policy DP27 (Basements and Lightwells) of the London Borough of Camden Local Development Framework Development Policies.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public

Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website

<http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

- 3 Your proposals may be subject to control under the Party Wall etc Act 1996 which covers party wall matters, boundary walls and excavations near neighbouring buildings. You are advised to consult a suitably qualified and experienced Building Engineer.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully



Ed Watson  
Director of Culture & Environment