

**From:** BCTAdmin@thameswater.co.uk  
**Sent:** 25 November 2014 15:05  
**To:** Planning  
**Subject:** 3rd Party Planning Application - 2014/5822/p

London Borough of Camden  
Camden Town Hall  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

Our DTS Ref: 1247  
Your Ref: 2014/5822/p

25 November 2014

Dear Sir/Madam

Re: SITE BOUNDED AT HAWLEY WHARF , AND CASTLEHAVEN RD HAWLEY ROAD, KENTISH TOWN ROAD & REGENTS CANAL, LONDON, NW1

#### Waste Comments

Thames Water have reviewed the documentation provided and cannot agree to the discharging of Condition 58.

#### Water Comments

#### Supplementary Comments

As the net impact on the public sewer system due to this redevelopment is a decrease in peak flow, Thames Water believes that the public sewer system has sufficient capacity to accommodate the proposals. This site falls within the highly sensitive Counters Creek Catchment with significant flooding due to surface water flow in the combined sewer system. The supplied documentation does not clearly demonstrate all technical restrictions justifying connection of surface water into the combined sewer system. The London plan Policy 4a.14 identifies a hierarchy of drainage options for surface water drainage as follows and as such we would expect the development proposal to follow this. The London plan Policy 4a.14. The Mayor will, and boroughs should, seek to ensure that surface water run-off is managed as close to its source as possible in line with the following drainage hierarchy: >Store rainwater for later use >Use infiltration techniques, such as porous surfaces in non-clay areas >Attenuate rainwater in ponds or open water features for gradual release to a watercourse >Attenuate rainwater by storing in tanks or sealed water features for gradual release to a watercourse >Discharge rainwater direct to a watercourse >Discharge rainwater to a surface water drain >Discharge rainwater to the combined sewer.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

Did you know you can manage your account online? Pay a bill, set up a Direct Debit, change your details or even register a change of address at the click of a button, 24 hours a day. Please visit [www.thameswater.co.uk](http://www.thameswater.co.uk).

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales each with their registered office at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of Thames Water Limited or its subsidiaries. If you are not the intended recipient of this email you may not copy, use, forward or disclose its contents to any other person; please notify our Computer Service Desk on +44 (0) 203 577 8888 and destroy and delete the message and any attachments from your system.

We provide the essential service that's at the heart of daily life.