



- Point 15: Living room window glazing is at 700 mm above finished floor level.
- Point 14: The bathroom incorporates ease of access to the bath, WC and wash basin
- Point 13: The design does provide a route for a potential hoist
The structure will be designed to accept any future installation
- Point 12: Space for a future lift provision
- Point 11: Bathroom will be sufficiently capable of firm fixings
- Point 10: An accessible WC will be provided at the upper ground accessible level
- Point 9: Space for a temporary bedspace will be provided on the upper ground accessible level
- Point 7: The dining room and living room have space for a 1500mm in diameter and adequate circulation
Clear width of 750mm provided at both sides and foot of the bed.
- Point 5: No communal stair/lift requirement.
Each dwelling is self-contained.
- Point 4: All entrances meet the following three points namely:
- All entrances are illuminated
- All entrances have level access over the threshold and have a covered main entrance.
- All thresholds do not exceed 15mm.
- Point 3: Level approach to the entrance by the public pavement
Access from street level
- Point 2: N/A
- Point 1: N/A

