

Application No:	Consultees Name:	Consultees Addr:	Received:	Comment:	Response:
2014/5077/L	Richard Simpson	Primrose Hill CAAC 12A Manley Street London NW1 8LT	05/12/2014 16:55:53	OBJ	<p>ADVICE from Primrose Hill Conservation Area Advisory Committee 12A Manley Street, London NW1 8LT</p> <p>3 December 2014</p> <p>Top Floor Flat 22 Chalcot Square London NW1 8YA, 2014/5077/L</p> <p>Object. This is an application for a Listed Building but the drawings submitted are wholly inadequate for an assessment of the effect of the proposal on the Listed Building and its larger setting to be made.</p> <p>The agent's assertions that the new windows will have no impact on the heritage asset need to be evidenced by drawings showing the existing windows: this they have not done. We note, as an indication of our concern, that the glazing bar shown as proposed is 25mm wide, while a traditional glazing bar is 18mm: this is a substantial, harmful, difference.</p> <p>Richard Simpson FSA Chair</p>

---