



Noise Assessment Report

Report: 3204-R1 – Theobalds Road, Holborn, London, WC1X 8SP

Northern Office: The Old Vicarage, Barcroft Lane, Haywood DN6 ODS

Midlands Office: 22 Carlton Road, Bilton, Rugby CV22 7PB

t: 01302 707 199

e: info@cloveracoustics.co.uk www.cloveracoustics.co.uk

1. Table of Contents

2.	Introduction	3
	Scope	
4.	Site Description	4
5.	Survey Information	7
6.	Survey Results	9
7.	Noise Assessment	9
8.	Recommendations	. 12
9.	Conclusion	. 12
10.	Appendix	. 14

Report Revisions	Date		
3204-R1	05/12/2014	Initial Report	
	Produced by:	Checked by:	Authorised by:
Name:	Steve Clow MIOA	Steve Mckeever AMIOA	Steve Clow MIOA

<u>Steve Clow MIOA</u>, is a member of The Institute of Acoustics and has achieved the IOA Diploma in Acoustics and Noise Control. Steve Clow has over 15 years experience in an acoustic consultant capacity working on many assessments involving planning and regulatory services.

<u>Steve Mckeever AMIOA</u>, is an associate member of The Institute of Acoustics and has achieved the IOA Diploma in Acoustics and Noise Control. Steve Mckeever has 10 years experience working in acoustics and 5 years in an acoustic consultant capacity.

This report is for the exclusive use of the client named on page 1 and may not be reproduced without the authors' permission. The information reported had been prepared with all reasonable care and diligence. Clover Acoustics Ltd disclaims any responsibility to the client and others in respect of matters outside the scope of works agreed. We accept no responsibility to any third party to whom this report or any part of is made available. Any such parties rely upon this report at their own risk.

Aerial images contained in this document are reproduced under license from our Global Imaging System operator. License details are available upon request.

Clover Acoustics Ltd - The Old Vicarage - Barcroft Lane - Askern - Doncaster - DN6 0DS Tel: 01302 707 199 - Web: www.cloveracoustics.co.uk - Email: info@cloveracoustics.co.uk

3204-R1 Page 2/20

2. Introduction

Clover Acoustics Ltd has been appointed by Zohaib Khan to carry out a noise assessment on a proposed kitchen extract system to be installed at the rear of 37 Theobalds Road, Holborn, London, WC1 X8SP. The equipment will service a proposed restaurant located on the ground floor and basement of the building.

A baseline noise survey has been carried out over a period representative of the proposed operational hours of the restaurant in order to establish the existing background levels. The background noise survey was conducted at one monitoring location on Friday 28th November 2014 and Monday 1st December 2014.

The purpose of this report is to demonstrate that due consideration for noise affecting neighboring residential properties has been made and to assess the significance of any noise impact from the operation of the units.

3. Scope

BS4142:2014 Methods for rating and assessing industrial and commercial sound.

BS4142 gives a method for rating sound from industrial and commercial sources affecting people inside or outside dwellings or premises used for residential purposes. An initial estimate of the significance of the sound from the industrial/commercial nature can be assessed by subtracting the measured background noise level from the rating level (this is the specific sound level of the source with any corrections or penalties for distinctive acoustic characteristics). Typically, the greater the difference, the greater the magnitude of the impact.

- A difference of around +10dB or more is likely to be an indication of a significant adverse impact, depending on the context.
- A difference of around +5dB is likely to be an indication of an adverse impact, depending on the context.
- The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.

3204-R1 Page 3/20

Local Authority Requirements

The proposed development is located in the London Borough of Camden. The planning guidance document DP28 from the Camden Local Authority offers the following guidance on noise level requirements:

able E: Noise levels from plant and granted			
Noise description and location of measurement	Period	Time	Noise level
Noise at 1 metre external to a sensitive façade	Day, evening and night	0000-2400	5dB(A) <la90< td=""></la90<>
Noise that has a distinguishable discrete continuous note (whine, hiss, screech, hum) at 1 metre external to a sensitive façade.	Day, evening and night	0000-2400	10dB(A) <la90< td=""></la90<>
Noise that has distinct impulses (bangs, clicks, clatters, thumps) at 1 metre external to a sensitive façade.	Day, evening and night	0000-2400	10dB(A) <la90< td=""></la90<>
Noise at 1 metre external to sensitive façade where LA90>60dB	Day, evening and night	0000-2400	55dB _{LAeq}

Figure 1 – Table E from Camden Planning Guidance Document DP28

4. Site Description

The proposed restaurant is to be located on the ground and basement level of 37 Theobalds Road, Holborn, London. The area is predominantly a mixed commercial and residential environment.

The ground floor area of the building being developed was previously part of a larger restaurant that spanned the neighbouring property which is also going through its own refurbishment. *The client advises that some items of plant from this neighbouring establishment is not currently running and therefore the assessment should be viewed as a "worst case" lowest background noise level.*The remaining 3-floors above the proposed restaurant are residential dwellings.

The proposed restaurant kitchen is to be located within the basement. Kitchen extract equipment will be ducted through the building and exit at rear of the building between the ground and first floor. From this point it will be vertically ducted to the discharge point at 1meter above roof level.

The current application hours of operation are Mon-Fri 07:00-23:00 and Sat-Sun 11:00-23:30. The proposed extract system is to include a SMVW 560/4 extraction fan which is likely to run throughout the proposed operational hours.

It was observed at the rear of the development that there were other extract systems and air condensing units servicing neighbouring properties. The proposed development was previously a restaurant and the area is of mixed commercial and residential use. We would consider the proposed system as within context of the surrounding area. Subjectively whilst attending the site the background noise was dominated by road traffic noise from the surrounding area.

Figure 2 shows the site location plan and Figure 3 shows the proposed development layout.

3204-R1 Page 4/20



Figure 2 – Site Location Plan

3204-R1 Page 5/20



Figure 3 – Proposed Development Layout

3204-R1 Page 6/20

5. Survey Information

Measurement Instrumentation

The measurement instrumentation used on the survey was as follows:

Equipment	Manufacturer & Type	Serial Number	Calibration Certificate
Sound Level Meter	Norsonic 118	30559	U16612
Acoustic Calibrator	Norsonic 1251	32856	U16611

The equipment was calibrated to comply with section 4.2 of BS7445:1-2003 before and after the surveys. The calibration was as follows:

Meter	Serial	Bef	ore	Af	ter
Norsonic 118	30559	113.9	-26.1	113.9	-26.1

Measurements & Timescales

During the background survey 15-minute measurements were made over a typical daytime and night time period between Friday 28th November 2014 and Monday 1st December 2014 at a location representative of the residential dwellings to the rear of 37 Theobalds Road. The measurements were subsequently analysed into hourly periods.

The following measurements are reported: L_{Aeq,T}, L_{A90,T}, L_{Amax,T}

The measurements and their interpretation shall be in accordance with BS 7445: Parts 1 and 2. All sound pressure levels are in dB (re 20μ Pa).

Meteorology

Wind speed measurements were logged during the background survey close to the noise monitoring location. The monitoring location was shielded from wind by the surrounding buildings, throughout the assessment period Sunday 30th November 2014, wind speed measurements were below 5m/s⁻¹.

Local weather station data indicates temperatures ranged between 6°C and 10°C and there was no precipitation during the assessment period.

Position of Monitoring Equipment


The equipment was mounted free field 1.5m from the flat roof at a location representative of the nearest receivers. Figure 2 shows the site location plan with the location of the proposed unit and background monitoring location.

3204-R1 Page 7/20










Produced 26 Nov 2014 from the Ordnance Survey National Geographic Database and incorporating surveyed revision available at this date. Reproduction in whole or part is prohibited without the prior permission of Ordnance Survey. © Crown Copyright 2014.

Ordnance Survey and the OS Symbol are registered trademarks of Ordnance Survey, the national mapping agency of Great Britain.

The representation of a road, track or path is no evidence of a right of way. The representation of features as lines is no evidence of a property boundary.

Version 1.0 Unversioned directory PNG



37, Theobalds Rd London WC1 X8SP

Supplied by: Stanfords 26 Nov 2014 Stanfords Ordnance Survey Partner Licence: 100035409 Reference: 01787625 Centre coordinates: 530666 181810



Background Monitoring Location



Proposed Extract Equipment

Figure 4 – Site Location Plan Showing Monitoring Location


Page 8/20 3204-R1

6. Survey Results

Background Noise Summary

The background monitoring from Sunday 30th November 2014 has been selected as the representative background period for the assessment. The collated data is indicative that background levels were slightly lower during this Sunday period and it is presumed that this is due to neighbouring properties being inactive throughout the period.

<u></u>			Site: Position 1 - 37 Theobald	Site: Position 1 - 37 Theobalds Road, Holborn, London, WC1 X8SP			
clove	r		Table: 1 Summary	Start Date: 30/11/2014			
Clove	acoustics		Report: 3204-R1	End Date: 30/11/2014			
	Hou	urly Summary					
Hour End	LAeq,1Hour	Min LA90,15min	Max LAMax, 15min				
00:00	44.9	43.0	54.2				
01:00	45.3	44.0	61.3				
02:00	46.3	42.5	70.2				
03:00	46.3	41.5	75.0				
04:00	46.1	42.0	70.9				
05:00	45.6	41.0	69.4				
06:00	44.1	41.0	60.6				
07:00	46.1	42.0	70.0				
08:00	46.3	41.5	77.6				
09:00	44.7	42.0	65.9				
10:00	45.0	42.0	69.6				
11:00	46.4	44.0	67.0				
12:00	49.9	45.5	78.2				
13:00	46.9	46.0	67.3				
14:00	50.2	46.0	71.6				
15:00	47.3	46.5	62.6				
16:00	47.8	47.5	62.2				
17:00	51.9	47.5	77.2				
18:00	50.2	48.0	70.2				
19:00	55.9	47.5	81.3				
20:00	49.7	46.5	73.1				
21:00	50.4	47.0	75.3				
22:00	48.1	46.5	67.1				
23:00	45.4	43.0	65.4				



3204-R1 Page 9/20

7. Noise Assessment

BS4142:2014 - Methods for rating and assessing industrial and commercial sound

The proposed kitchen extract specification includes a Helios SMVW 560/4 Extractor Fan with a published sound output level of 61dB(A) at 1m. The proposed development layout identifies the fan unit would be installed on the flat roof level adjacent the residential receiver windows. Substantial attenuation would be required to attenuate the fan case breakout to a level to avoid a significant adverse impact on the nearby receivers. We would strongly recommend installing the fan unit internally to avoid substantial attenuation requirements to the fan unit.

Noise will be generated within the ductwork by the fan unit. This noise may become apparent at the receiver via noise breakout from the external ductwork wall and discharge point.

The proposed hours of operation are Mon-Fri 07:00-23:00 and Sat-Sun 11:00-23:30. The lowest background noise level monitored during the proposed operational hours was 43dB $L_{A90,15min}$.

Based on the manufacturers' published information using prediction methods from CIBSE Guide B and other appropriate calculation methods¹ the specific noise impacting on the receiver has been calculated for both duct wall breakout and discharge point aspects of the system before any mitigation has been applied as follows:

Kitchen Extract System				
Extract	Noise Level at receiver dB(A)			
Duct Breakout	64			
Discharge Point	59			
Fan Case (Installed Internally)	-			
Total	65			

The total system noise level has been predicted as 65dB(A) at the receiver. The lowest operational background noise level recorded was $43dBL_{A90.}$ A BS4142 Assessment based on the proposed untreated system would result in a specific level of 22dB above background at the receiver. According to BS4142, "A difference of around +10dB or more is likely to be an indication of a significant adverse impact".

The local authority requirement is to achieve a specific noise level that is 10dB below the background LA90 (where the source contains a whine hiss screech or hum). To achieve the local authority requirements, additional attenuation for the extract system of 32dB is required which would result in a combined noise rating level 10dB below the lowest operational hours background of 43dB L_{A90} . Each contributing element therefore needs to be attenuated to achieve no more than 30dB at the receiver.

3204-R1 Page 10/20

¹ Calculations are presented in the Appendix

Kitchen Extract System:

Insertion loss requirements have been calculated as follows:

Table 2: Insertion Loss Requirement	125	250	500	1000	2000	4000	8000
Discharge point	13	19	41	55	55	45	31
Duct wall breakout	24	33	59	75	78	68	56

To achieve the required insertion loss for the discharge point the suggested treatment would be to adopt an in-line silencer solution. The clients' kitchen extraction designer has included information on a range of Helios silencers. Based on the insertion loss requirements this could be achieved by installing 2x off KSD 600 silencers.

To achieve the required insertion loss for the duct-wall breakout the suggested treatment would be to adopt the in-line silencers as above and in addition lag the external ductwork. A typical product used for this purpose would be Muftilag Tap-Wrap 6F/5kg (http://www.tapacoustic.com/).

Noise Assessment

Adopting further treatment to the system and achieving the required insertion loss values for the system would predict a noise rating level of 33dB(A) at the receiver¹. This would give a predicted level of 10db below the lowest operational hours background level. This is line with the local authority requirement to achieve a specific noise level that is 10dB below the background LA90 (where the source contains a whine hiss screech or hum) at 1m external to a sensitive facade.

Local Authority Assessment –	dB(A)
Extract System with mitigation.	
Combined specific level at Receiver	33
Lowest Operational Hours Level L _{A90}	43
Rating Above/ Below Background	-10dB

BS4142 Assessment – Extract	dB(A)
System with mitigation.	
Combined specific level at Receiver	33
Acoustic Feature Correction	+5
Rating Level	38
Lowest Operational Hours Level L _{A90}	43
Rating Above/ Below Background	-5dB

BS4142 advises, "The lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact".

3204-R1 Page 11/20

8. Recommendations

The current proposed system would predict a noise rating above the existing background noise level and indicate a significant adverse impact on the neighbouring properties. To avoid this and achieve the local authority requirements of a specific noise level that is 10dB below the background LA90 (where the source contains a whine hiss screech or hum) further treatment would be required.

The suggested treatment options would be to install the fan unit internally. If the fan unit were to be installed externally, significant attenuation would be required.

To attenuate noise from the extraction system discharge point and duct-wall breakout, install in-line silencers with the minimum insertion loss values from table 2. This could be achieved by installing 2x off KSD 600 silencers in combination with Muftilag Tap-Wrap 6F/5kg lagging of the external ductwork.

It is understood that anti vibration mountings have been specific in line with good practice and detail is included in the appendix.

Clover Acoustics Ltd can only advise on noise issues in this regard, and it is recommended that professional advice be sought from others in respect of non acoustic issues such as air flow, ventilation to the equipment, any visual aspects and structural support issues.

9. Conclusion

A noise assessment has been carried out at the 37 Theobalds Road, Holborn, London, WC1 X8SP to assess the impact of a proposed kitchen extraction system at the rear of the building. A background noise survey was conducted between Friday 28th November 2014 and Monday 1st December 2014 at a location representative of the nearest sensitive receivers.

An assessment has been made in accordance with Local Authority and BS4142 which has shown that with attenuation applied a predicted specific noise level of 10dB below the proposed operational operation background hours can be achieved. This specific noise level would achieve the Local Authority of a specific noise level that is 10dB below the background LA90 (where the source contains a whine hiss screech or hum).

Further, according to BS4142, "Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact"

Steve Clow MIOA Acoustic Consultant

3204-R1 Page 12/20

3204-R1 Page 13/20

10. Appendix

Glossary of Terms

Specific Noise Source

The noise source under investigation for assessing the likelihood of complaints.

Specific Noise Level, LAeq,T

The equivalent continuous A-weighted sound pressure level at the assessment position produced by the specific noise source over a given reference time interval.

Rating Level, LA,T

The specific noise level plus any adjustment for the characteristic features of the noise.

Background Noise Level, LA90,T

The A-weighted sound pressure level of the residual noise at the assessment position that is exceeded for 90 % of a given time interval, T.

Residual Noise

The ambient noise remaining at a given position in a given situation when the specific noise source is suppressed to a degree such that it does not contribute to the ambient noise.

Ambient Noise

Totally encompassing sound in a given situation at a given time usually composed of sound from many sources near and far.

Reference Time Interval, T

The specified interval over which an equivalent continuous A-weighted sound pressure level is determined.

$L_{Aeq,T}$

The A-weighted equivalent continuous sound level – the sound level of a notionally steady sound having the same energy as the fluctuating sound over a specified measurement period, T.

$L_{A10,T}$

The A-weighted sound level exceeded for 10% of the specified measurement period, T.

L_{Amax}

The highest short duration A-weighted sound level recorded during a noise event.

A-Weighting

The 'A' weighting is a correction term applied to the frequency range in order to approximate to the sensitivity of the human ear to noise. It is generally used to obtain an overall noise level from octave or third octave band frequencies.

Octave Band

A frequency band in which the upper limit of the band is twice the frequency of the lower limit.

One-third-octave Band

A frequency band in which the upper limit of the band is 1/3 times the frequency of the lower limit.

3204-R1 Page 14/20




Figure 5 – View West Along Neighbouring Properties



Figure 6 – View East Along Neighbouring Properties



Figure 7 – View of existing neighbouring extract formally used by 37 Theobalds Road.



3204-R1 Page 16/20

Noise Impact Calculations (Including Proposed Mitigation)

_			Site: 37 Theobald								
clover acoustic	rs		Table: 3 - Kitcher Report: 3204-R1	Extract -	Discharge	point no	ise				
scharge Point Noise			63	125	250	500	1000	2000	4000	8000	dBA
		Unit Sound Power Level		64.0	69.0	73.0	77.0	73.0	65.0	57.0	80
	Straight Ducts			Τ	I	I			1		
Width x Height (mm)	Length (m)	Lined									
500 x 500	10	No		4.0	3.0	1.0	1.0	1.0	1.0	1.0	
				-							
				1							
	Bends / Take Offs			_							
Width x Height (mm)	Type	Lined	<u> </u>								
7, 20, 1,	71										
			<u> </u>								
	Other Attenuation		ı —	1	I	I			I	I I	
Silencer 1	Helios KSD 600	1		7	10	21	28	28	23	16	
Silencer 2	Helios KSD 600			7	10	21	28	28	23	16	
				+							
Į.		1	ı	-	·						
	Discharge Point Noise								1		
		wer Level at Discharge Point		46.0	46.0	30.0	20.0	16.0	18.0	24.0	
	Dista	nce Exhaust to Receiver 4m		20.0	20.0	20.0	20.0	20.0	20.0	20.0	
											20
	Soun	d Pressure Level at Receiver		26.0	26.0	10.0	0.0	-4.0	-2.0	4.0	29
clover		d Pressure Level at Receiver	Site: 37 Theobald Table: 4 - Kitcher	ls Road, H	olborn, Lo	ondon, W	C1 X8SP	-4.0	-2.0	4.0	29
clover acoustic to Noise Breakout			Site: 37 Theobald	ds Road, H Extract - 125	olborn, Lo Duct brea 250	ondon, Wo kout nois	C1 X8SP e 1000	2000	4000	8000	dBA
		d Pressure Level at Receiver	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ds Road, H 1 Extract -	olborn, Lo Duct brea	ondon, Wo	C1 X8SP e				
ıct Noise Breakout			Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ds Road, H Extract - 125	olborn, Lo Duct brea 250	ondon, Wo kout nois	C1 X8SP e 1000	2000	4000	8000	dBA
oct Noise Breakout Width x Height (mm)	Straight Ducts Length (m)	Unit Sound Power Level Lined	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
ıct Noise Breakout	Straight Ducts	Unit Sound Power Level	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ds Road, H Extract - 125	olborn, Lo Duct brea 250	ondon, Wo kout nois	C1 X8SP e 1000	2000	4000	8000	dBA
ct Noise Breakout Width x Height (mm)	Straight Ducts Length (m)	Unit Sound Power Level Lined	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
ct Noise Breakout Width x Height (mm)	Straight Ducts Length (m)	Unit Sound Power Level Lined	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
ct Noise Breakout Width x Height (mm)	Straight Ducts Length (m) 10	Unit Sound Power Level Lined	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
Width x Height (mm) 500 x 500	Straight Ducts Length (m) 10 Bends / Take Offs	Unit Sound Power Level Lined	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
Width x Height (mm) 500 x 500	Straight Ducts Length (m) 10	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
Width x Height (mm) 500 x 500	Straight Ducts Length (m) 10 Bends / Take Offs	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
Width x Height (mm) 500 x 500	Straight Ducts Length (m) 10 Bends / Take Offs	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
Width x Height (mm) 500 x 500	Straight Ducts Length (m) 10 Bends / Take Offs	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
Width x Height (mm) 500 x 500	Straight Ducts Length (m) 10 Bends / Take Offs Type	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
Width x Height (mm) 500 x 500	Straight Ducts Length (m) 10 Bends / Take Offs	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	ls Road, H 10 Extract - 125 64.0	olborn, Lo Duct brea 250 69.0	ondon, Wikout nois 500 73.0	C1 X8SP e 1000 77.0	2000	4000 65.0	8000 57.0	dBA
Width x Height (mm) 500 x 500 Width x Height (mm)	Straight Ducts Length (m) 10 Bends / Take Offs Type Other Attenuation Helios KSD 600 Helios KSD 600	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	125 64.0 4.0	250 69.0 3.0	21 21	1000 77.0 1.0	2000 73.0 1.0	4000 65.0 1.0	1.0 1.0 1.6	dBA
Width x Height (mm) 500 x 500 Width x Height (mm)	Straight Ducts Length (m) 10 Bends / Take Offs Type Other Attenuation Helios KSD 600	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	125 64.0	250 69.0 3.0	500 73.0	1000 77.0	2000 73.0 1.0	1.0	1.0	dBA
Width x Height (mm) 500 x 500 Width x Height (mm) Silencer 1 Silencer 2	Straight Ducts Length (m) 10 Bends / Take Offs Type Other Attenuation Helios KSD 600 Helios KSD 600	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	125 64.0 4.0	250 69.0 3.0	21 21	1000 77.0 1.0	2000 73.0 1.0	4000 65.0 1.0	1.0 1.0 1.6	dBA
Width x Height (mm) 500 x 500 Width x Height (mm) Silencer 1 Silencer 2	Straight Ducts Length (m) 10 Bends / Take Offs Type Other Attenuation Helios KSD 600 Helios KSD 600	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	125 64.0 4.0	250 69.0 3.0	21 21	1000 77.0 1.0	2000 73.0 1.0	4000 65.0 1.0	1.0 1.0 1.6	dBA
Width x Height (mm) 500 x 500 Width x Height (mm) Silencer 1 Silencer 2	Straight Ducts Length (m) 10 Bends / Take Offs Type Other Attenuation Helios KSD 600 Helios KSD 600	Unit Sound Power Level Lined No	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	125 64.0 4.0	250 69.0 3.0	21 21	1000 77.0 1.0	2000 73.0 1.0	4000 65.0 1.0	1.0 1.0 1.6	dBA
Width x Height (mm) 500 x 500 Width x Height (mm) Silencer 1 Silencer 2	Straight Ducts Length (m) 10 Bends / Take Offs Type Other Attenuation Helios KSD 600 Helios KSD 600 Tap-Wrap 6F/5KG Duct Noise Breakout Sound Power Leve	Lined No Lined Lined	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	125 64.0 4.0 4.0 7 7 7 12.5	250 69.0 3.0 10 10 15.8	21 21 11.9	1000 77.0 1.0 1.0 28 28 21.4	2000 73.0 1.0 1.0 28 28 24.1	1.0 1.0 23 23 24.6	1.0 1.0 1.6	dBA
Width x Height (mm) 500 x 500 Width x Height (mm) Silencer 1 Silencer 2	Straight Ducts Length (m) 10 Bends / Take Offs Type Other Attenuation Helios KSD 600 Helios KSD 600 Tap-Wrap 6F/5KG Duct Noise Breakout Sound Power Leve Sound Reduction	Lined No Lined Lined Lined Lined Lined Lined Lined	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	7 7 7 12.5 37.1 8.0	250 69.0 3.0 3.0 10 10 15.8	21 21 19 20.0	28 28 21.4	2000 73.0 1.0 1.0 28 28 24.1	23 23 24.6	1.0 1.0 1.6 16 26	dBA
Width x Height (mm) 500 x 500 Width x Height (mm) Silencer 1 Silencer 2	Straight Ducts Length (m) 10 Bends / Take Offs Type Other Attenuation Helios KSD 600 Helios KSD 600 Tap-Wrap 6F/5KG Duct Noise Breakout Sound Power Leve Sound Reductic Sound Reductic	Lined No Lined Lined Lined Lined Lined Lined Lined	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	7 7 12.5 37.1 8.0 34.1	250 69.0 3.0 10 10 15.8 32.9 14.0 29.9	21 11.9 20.0 5.7	28 28 21.4	2000 73.0 1.0 1.0 28 28 24.1 0.0 26.0 0.0	23 23 24.6	1.0 1.0 1.6 16 26	dBA
Width x Height (mm) 500 x 500 Width x Height (mm) Silencer 1 Silencer 2	Straight Ducts Length (m) 10 Bends / Take Offs Type Other Attenuation Helios KSD 600 Helios KSD 600 Tap-Wrap 6F/5KG Duct Noise Breakout Sound Power Leve Sound Reductic Sound Reductic	Lined No Lined Lined Lined Lined Lined Lined Lined	Site: 37 Theobald Table: 4 - Kitcher Report: 3204-R1	7 7 7 12.5 37.1 8.0	250 69.0 3.0 3.0 10 10 15.8	21 21 19 20.0	28 28 21.4	2000 73.0 1.0 1.0 28 28 24.1	23 23 24.6	1.0 1.0 1.6 16 26	dBA

3204-R1 Page 17/20

METAL WORKS LTD.

Unit 6 • 20 Kynoch Road Edmonton • London • N18 3BD 020 8807 78 78 • activems@ymail.com

450 - 630 MM Diameter Square Mix Flow Fan Extraction Motor Unit Details





Type		2		D	-	45
SMV 450	492	400	470	65	447	10
SMV 500	547	450	520	65	502	10
SMV 560	595	435	573	65	550	10
SMV., 630	707	510	680	66	661	10

Applications/use

- □ For medium airflow volumes against high resistances. Square flanges for quick connection onto ducting.
- Features
- ☐ The Square Mixed flow vent range offers execellent fan performance in nominal duct dimensions of 450 to 660 mm aquare.
- Compact design to minimise
- space and cost Square quick fix flanges offer fast and effective installation.
- 100 % speed controllable. Extensive range of accessories including starters, speed controllers, flexible connectors, siloncors and filters.
- Units can be mounted in any position.
- Simple diectrical connection via a terminal box on the casing. ☐ Robust corrosion resistant casing, designed for duct connection. Suitable for internal

or external installation.

Specification Motor

Maintenance free, external rotor motor with sealed for life ball bearings. Protection to IP 54, insulation-class B for 1 phase and class F for 3 phase motors.

■ Motor protection

All models are fitted with thermal contacts which should be connected to a motor protection device.

■ Casing

Made from gavanised sheet steel with fitted quick fix flanges.

Impeller
Mixed flow impeller made from galvarised stool.

Speed control

All models are fully speed controllable. Suitable controllers, electronic and auto-transformers, are available as accessories.

Terminal box

The external terminal box for electrical connection is IP 55.

Electrical connection

The connection of the electrical supply must be carried out in accordance with all relevant regulations. Connection is via the terminal box on the casing.

Installation

Installation at any angle.

Safety notice

Protection against accidential contact to DIN EN 294 must be provided by the installer.

The data table below gives the sound pressure level (air noise) in dB(A) at 1 metre under freefield conditions. The total sound power levels shown on the performance curves are for intake, extract and case breakout

Performances

speed controlers

All performances are at an air density of 1,20 kg/m².

Other accessories Pages Adaption plate for circular ducts, flexible connectors, attenuators, filters, heaters and

210

Туре	Fat No.	R.P.M.	All flow VOIUTIN FID	Sound priss.	Power	Max air Now tomp.	Current Arros	Wiring	Non inst Weight	5 stip tra		5 step to controller we prote	th full motor
		min-1	n1/s	dB(A)	KW	6°C	FLC	No.	kg	Туре	Flat. No.	Туро	Ref. No.
Single phase, 230 Y	/ 1 ph. / 30 Hz	sapacitor s	start motor, pr	otection to IP 3	4								
SMVW 450/4	7822	1385	1.00	54	0.33	50	1.55	SS-434	26.0	TSW 3.0	1496	MWS 3	1948
SMVW 500/4	7823	1330	1.45	62	0.51	46	2.27	SS 434	41.0	TSW 3.0	1496	MWS 3	1948
SMWW 560/4	7824	1280	1.94	61	0.85	45	4.10	\$5-434	42.0	TSW 5.0	1497	MWS 5	1949
SMVW 630/4	7925	1315	3.10	69	150	40	6.60	SS-434	57.0	TSW 7.5	1596	MWS 7.5	1960
Three phase, 400 V	/ 3 ph. / 50 Hz	motor, prete	ection to IP 54										
SMVD 500/4	7826	1400	1.48	57	0.55	70	1.48	SS-409	32.0	TSD 3.0	1502	RDS 2	1315
SMVD 560/4	7927	1315	1.87	62	0.79	50	1.51	SS-469	40.0	TSD 3.0	1502	RDS 2	1315
SMVD 630/4	7828	1305	2.90	53	1.28	50	2.24	SS-469	52.0	TSD 3.0	1502	RDS 4	1316

3204-R1 Page 18/20

ARDA METAL WORKS LTD.

Unit 6 • 20 Kynoch Road Edmonton • London • N18 3BD 020 8807 78 78 • activems@ymail.com

450 - 630 MM Diameter Square Mix Flow Fan Silencer Details

■ Rectangular attenuator KSD


Specification – Installation
Casing made from galvanised
steel with flanges to fit the fan's
dimensions. To be installed
in-line with ducting on inlet or
exhaust. To reduce vibration
transmission from the fan, a
flexible connector (accessories
VS or VS... Ex) should be
installed between fan/attenuator


and ducting.

resistance.

Pressure drop
The attenuator will add an additional resistance to the duct system (see chart), which must be considered when selecting a fan. The figures shown refer to an equal inlet into the attenuator. Turbulences from the fan's exhaust can be reduced if 1 metre of straight ducting is fitted between fan and attenuator. Otherwise allow for a higher







Ty	rpe	Ref. No.	Duct size in mm	Α	Dimension B	ns in mm C	D	Nominal weight kg	125	250	500 Att	enuation D _e 1000	dB 2000	4000	8000	Average attenuation
KSD	400/200	8728	400/200	420	220	443	240	13	8	11	23	31	31	26	18	17
KSD	500/250.	. 8729	500/250-300	520	270/320	540	340	16.5	6	9	19	25	25	20	15	14
KSD	600/300.	. 8730	600/300-350	620	320/370	640	390	20	7	10	21	28	28	23	16	12
KSD	700/400	8731	700/400	720	420	740	440	25	6	8	18	24	24	20	14	12
KSD	800/500	8732	800/500	820	520	840	540	31	7	9	19	26	26	21	15	14
KSD	1000/500	8733	1000/500	1020	520	1040	540	35	5	7	16	21	21	17	12	11

450 - 630 MM Diameter Square Mix Flow Fan Speed Controller




Туре	Ref. No.	I max.	Din W	ns. in n H	nm D						
For 1 ph.	230 V										
TSW 3.0	1496	3.0	154	200	148						
TSW 5.0	1497	5.0	200	254	98						
TSW 7.5	1596	7.5	200	254	167						
For 3 ph. / 400 V											
TSD 3.0	1502	3.0	200	254	167						


5 step transformer controller TSW / TSD

Robust ISO casing, of impact resitant polymers colour light grey. Protection IP 54. Bulit in 5 step switch providing on/off and 5 speed settings. Available for 220/240 V 1 ph. and 400/440 V, 3 ph. supply.

3204-R1 Page 19/20

Enclosed Spring Vibration Isolators







Туре	Load range per mounting (kg)	Product Number	A		a	0	E	F	G	н	a	ĸ
ES20/10/ZSB Purple	10	503008	76	38	60	54	48	66	3	MB	40	6.5
ES20/15/ZSB Yellow	15	503009	76	38	60	54	48	66	3	MB	40	6.5
ES20/20/ZSB Grey	20	503010	76	38	60	54	48	66	3	MB	40	6.5
ES25/60/758 Green	60	503015	110	70	90	85	78	94	6	M10	60	9
ES25/100/ZSB Blue	100	503016	110	70	90	85	78	94	G	M10	60	9

All dimensions shown in mm

Rubber in Shear Vibration Isolators





Note: These vibration isolators are not suitable for use with JM Aerofoll HT category 300/1 and 400/2 series smoke venting fans - please use spring isolators.

Туре	Load range per mounting (kg)	Product Number	A		G	E	F	н	J	к	L
63.105.40	0-4	267321	64	43	2	20	50	MG	-		-
63.105.60	0.8	267322	64	43	2	20	50	MG	-		-
19.100.Yellow	5-28	267336	80	45	5	32	57	MB	41	12	9
19.100.Blue	9-50	267337	80	45	5	32	57	MB	41	12	9
19.101.Blue	23-180	267345	95	60	5	45	71	M10	56	14	9
19.101.Red	35-280	267346	95	60	5	45	71	M10	56	14	9
19.102.Red	48-400	267352	150	86	G	70	115	M12	82	22	11

All dimensions shown in mm

Bold text denotes next day delivery available if ordered by 4pm

3204-R1 Page 20/20