EXISTING FLOODLIGHT TO REMAIN

EXISTING FLOODLIGHT TO REMAIN

20.725

SIGN

DB1/1L3

V1

V1

V1

SWA CABLE BURIED UNDER HARD STANDING

DB1/1L2

V

CANOPY

PHOTOCELL

DE

G.F+0.10 Staff Meeting Room

G.F+0.07

G.F+0.09 Main Entrance

G.F+0.04 Office

G.F+0.05 Reception/Office

G.F+0.07 Foyer

G.F+0.06 Music Therapy

G.F+0.06 Music Therapy

G.F+0.08 Toilet

G.F+0.13 Toilet

G.F+0.12 WC

G.F+0.11 WC

G.F+0.14 Art Therapy

G.F+0.17 Living Room

G.F+0.14 Hall

G.F+0.15 Lobby

G.F+0.16 Staff Toilet

Raised timber deck

21.1

20.725

20.725

DB1/1L2

V

100ø DUCT

SIGN

100ø DUCT EXITS BUILDING FOR EXTERNAL LIGHTING CABLES TO SOFT DIG DB1/1L3 & DB1/1L2

SWA CABLE TERMINATED IN IP JUNCTION BOX AT GATE FOR FUTURE LIGHTS DB1/2L1

SWA CABLE TO SOFT DIG AND TERMINATED IN IP RATED JUNCTION BOX FOR FUTURE CAR PARK COLUMN LIGHTS. DB1/1L3

100ø DUCT

CATV

CATV

CATV

EXISTING 100ø DUCT

SWA CABLE IN SOFT DIG DB1/1L2

SWA CABLES IN SOFT DIG DB1/1L2 & 1L3

EXISTING FLOODLIGHT

EXISTING FLOODLIGHT

SIGN

100ø DUCT ACROSS PATH

SWA CABLE IN SOFT DIG DB1/1L3

100ø DUCTS TO SOFT DIG DB1/1L3

NOTES

- D — BUILDING MOUNTED WALL LIGHTS BY OTHERS.
- V — BUILDING MOUNTED LED TREE FLOOD. CRESENT LIGHTING CLF2746 11W LED 1P67
- V1 — AS TYPE V BUT GROUND MOUNTED EXACT LOCATIONS TO BE DETERMINED ON SITE
- X — SOFFIT ADJUSTABLE WALL WASH DOWN LIGHT ERCO 84466 8W LED 1P65
- X1 — SOFFIT DOWNLIGHT 1P65. ERCO DOWNLIGHT 84426 8W LED FIXED FLOOD.
- T — WINDSOR AVENUE 24x2.4W LED 3000K L230 BLACK ON 3M COLUMN
- W — WIRING POINT ONLY NO FITTINGS

REV	DESCRIPTION	DATE
A	GENERAL UPDATE	26-11-2014

CONTRACTORS MUST VERIFY ALL DIMENSIONS BEFORE COMMENCING ANY WORK OR MAKING ANY SHOP DRAWINGS

ARCHITECT
PHILIP MEADOWS ARCHITECTS

JOB
CORAM FOUNDATION
PROPOSED PAVILION

TITLE
EXTERNAL LIGHTING PROPOSAL

A & G Partnership
Building Services Consulting Engineers
95 Buckingham Palace Road
London,
SW1W 0RP
Tel:- 020 7828 8200
Fax:- 020 7828 8122

CHECKED RSG	DRAWN BY MW
DATE AUG 2013	SCALE 1:100 @ A1
DRG No E/4359/107	REV A