

5

10 June 2008

Mr. R. Truman  
Building Control  
London Borough of Camden  
Town Hall  
Argyle Street, London  
WC1H 8EQ

Your ref. 06/2/375/4C/RTR/afe

Dear Mr. Truman,

**Re: 139 and 141 Camden High Street, London NW1**

We have now installed a fire escape door within the Party Wall as shown on the attached drawing and now need to clarify the arrangements for an interlinked fire alarm system.

We propose to install 2 no. smoke detectors to the first floor store area over 139, 4 no. smoke detectors to the ground floor shop area and one heat detector to the kitchen area of the new flat at 141 and one smoke detector to the corridor area of the new flat. All as marked on the attached drawings. The control panel will be located in the shop area and all detectors will be mains connected and interlinked. Would you kindly comment on this arrangement prior to installation.

Thanking you in anticipation.

Yours sincerely,

**K. Nicholas**

cc. J. Kanani

10 June 2008

Mr. R. Truman  
Building Control  
London Borough of Camden  
Town Hall  
Argyle Street, London  
WC1H 8EQ

Your ref. 06/2/375/4C/RTR/afe

Dear Mr. Truman,

**Re: 139 and 141 Camden High Street, London NW1**

We have now installed a fire escape door within the Party Wall as shown on the attached drawing and now need to clarify the arrangements for an interlinked fire alarm system.

We propose to install 2 no. smoke detectors to the first floor store area over 139, 4 no. smoke detectors to the ground floor shop area and one heat detector to the kitchen area of the new flat at 141 and one smoke detector to the corridor area of the new flat. All as marked on the attached drawings. The control panel will be located in the shop area and all detectors will be mains connected and interlinked. Would you kindly comment on this arrangement prior to installation.

Thanking you in anticipation.

Yours sincerely,

**K. Nicholas**

cc. J. Kanani