

Mr Sam Harper  
Firstplan  
25 Floral Street  
London  
WC2E 9DS

Application Ref: **2013/7482/P**  
Please ask for: **Aysegul Olcar-Chamberlin**  
Telephone: 020 7974 **6374**

4 February 2014

Dear Sir/Madam

### **DECISION**

Town and Country Planning Act 1990 (as amended)  
Town and Country Planning (Development Management Procedure) Order 2010  
Town and Country Planning (Applications) Regulations 1988

#### **Full Planning Permission Granted**

Address:  
**37 Heath Street**  
**London**  
**NW3 6TR**

Proposal:  
Replacement of extract duct and fan to rear elevation and roof.

Drawing Nos: (Prefix: 106.08/) 100 (Site Location Plan); 101; 103; 104; 104 (including noise levels to the nearest windows); Technical specification of GigaBox centrifugal fans; and Acoustic Assessment Report dated November 2013 by ACA Acoustics (ref: 131005-002A).

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and



Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Core Strategy and policy DP24 and DP25 of the London Borough of Camden Local Development Framework Development Policies.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans: (Prefix: 106.08/) 100 (Site Location Plan); 101; 103; 104; 104 (including noise levels to the nearest windows); Technical specification of GigaBox centrifugal fans; and Acoustic Assessment Report dated November 2013 by ACA Acoustics (ref: 131005-002A).

Reason:

For the avoidance of doubt and in the interest of proper planning.

- 4 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the [adjoining] premises [and the area generally] in accordance with the requirements of policy CS5 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

- 5 Automatic time clocks shall be fitted to the equipment/machinery hereby approved, prior to commencement of the use of the units, to ensure that the plant/equipment does not operate between 23:00 hrs and 8:00hrs. The timer equipment shall thereafter be permanently retained and maintained and retained in accordance with the manufacturer's recommendations.

Reason: To safeguard the amenities of the [adjoining] premises [and the area generally] in accordance with the requirements of policies CS5 and CS7 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26, DP28 and DP12 of the London Borough of Camden Local Development Framework Development Policies.


Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

Your attention is drawn to the notes attached to this notice which tell you about your Rights of Appeal and other information.

Yours faithfully



Rachel Stopard  
Director of Culture & Environment

It's easy to make, pay for, track and comment on planning applications on line. Just go to [www.camden.gov.uk/planning](http://www.camden.gov.uk/planning).

It is important to us to find out what our customers think about the service we provide. To help us in this respect, we would be very grateful if you could take a few moments to complete our [online planning applicants' survey](#). We will use the information you give us to monitor and improve our services.