

Muthoora, Leela

From: [REDACTED]
Sent: 04 March 2015 13:03
To: Planning
Subject: 3rd Party Planning Application - 2014/5208/P

London Borough of Camden
Camden Town Hall
Argyle Street
Euston Road
London
WC1H 8EQ

Our DTS Ref: 39788
Your Ref: 2014/5208/P

4 March 2015

Dear Sir/Madam

Re: 317, FINCHLEY ROAD, LONDON, , NW3 6EP

Waste Comments

Following initial investigation, Thames Water has identified an inability of the existing wastewater infrastructure to accommodate the needs of this application. Should the Local Planning Authority look to approve the application, Thames Water would like the following 'Grampian Style' condition imposed. "Development shall not commence until a drainage strategy detailing any on and/or off site drainage works, has been submitted to and approved by, the local planning authority in consultation with the sewerage undertaker. No discharge of foul or surface water from the site shall be accepted into the public system until the drainage works referred to in the strategy have been completed". Reason - The development may lead to sewage flooding; to ensure that sufficient capacity is made available to cope with the new development; and in order to avoid adverse environmental impact upon the community. Our preferred option would be for all surface water to be disposed of on site using SUDs as per policy 5.13 of the London plan. The London plan Policy 5.13 identifies a hierarchy of drainage options for surface water drainage and as such we would expect the development proposal to follow this. Policy 5.13: The Mayor will, and boroughs should, seek to ensure that surface water run-off is managed as close to its source as possible in line with the following drainage hierarchy: >Store rainwater for later use >Use infiltration techniques, such as porous surfaces in non-clay areas >Attenuate rainwater in ponds or open water features for gradual release to a watercourse >Attenuate rainwater by storing in tanks or sealed water features for gradual release to a watercourse >Discharge rainwater direct to a watercourse >Discharge rainwater to a surface water drain >Discharge rainwater to the combined sewer. The use of sustainable urban drainage systems should be promoted for development unless there are practical reasons for not doing so. Such reasons may include the local ground conditions or density of development. In such cases, the developer should seek to manage as much run-off as possible on site and explore sustainable methods of managing the remainder as close as possible to the site. The Mayor will encourage multi agency collaboration (GLA Group, Environment Agency, Thames Water) to identify sustainable solutions to strategic surface water and combined sewer drainage flooding/overflows. Developers should aim to achieve greenfield run off from their site through incorporating rainwater harvesting and sustainable drainage. Boroughs should encourage the retention of soft landscaping in front gardens and other means of reducing or at least not increasing the amount of hard standing associated with existing homes. Should the Local Planning Authority consider the above recommendation is inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority

liaises with Thames Water Development Control Department (telephone 0203 577 9998) prior to the Planning Application approval.

Legal changes under The Water Industry (Scheme for the Adoption of private sewers) Regulations 2011 mean that the sections of pipes you share with your neighbours, or are situated outside of your property boundary which connect to a public sewer are likely to have transferred to Thames Water's ownership. Should your proposed building work fall within 3 metres of these pipes we recommend you contact Thames Water to discuss their status in more detail and to determine if a building over / near to agreement is required. You can contact Thames Water on 0800 009 3921 or for more information please visit our website at www.thameswater.co.uk

No impact piling shall take place until a piling method statement (detailing the depth and type of piling to be undertaken and the methodology by which such piling will be carried out, including measures to prevent and minimise the potential for damage to subsurface sewerage infrastructure, and the programme for the works) has been submitted to and approved in writing by the local planning authority in consultation with Thames Water. Any piling must be undertaken in accordance with the terms of the approved piling method statement. Reason: The proposed works will be in close proximity to underground sewerage utility infrastructure. Piling has the potential to impact on local underground sewerage utility infrastructure. The applicant is advised to contact Thames Water Developer Services on 0800 009 3921 to discuss the details of the piling method statement.

Where a developer proposes to discharge groundwater into a public sewer, a groundwater discharge permit will be required. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Groundwater permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 020 8507 4890 or by emailing wwriskmanagement@thameswater.co.uk. Application forms should be completed on line via www.thameswater.co.uk/wastewaterquality. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991.

Water Comments

On the basis of information provided, Thames Water would advise that with regard to water infrastructure capacity, we would not have any objection to the above planning application.

Thames Water recommend the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ



This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to



Did you know you can manage your account online? Pay a bill, set up a Direct Debit, change your details or even register a change of address at the click of a button, 24 hours a day. Please visit www.thameswater.co.uk.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales each with their registered office at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of Thames Water Limited or its subsidiaries. If you are not the intended recipient of this email you may not copy, use, forward or disclose its contents to any other person; please notify our Computer Service Desk on +44 (0) 203 577 8888 and destroy and delete the message and any attachments from your system.

We provide the essential service that's at the heart of daily life.