

Mr Patrick Smith
Smith Coldham Design Ltd
55 Lime Grove
Ruislip
London
HA4 8RL

Application Ref: **2014/7257/P**
Please ask for: **David Peres Da Costa**
Telephone: 020 7974 **5262**

10 March 2015

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:
Smugglers Tavern
28 Warren Street
London
W1T 5ND

Proposal:
Erection of kitchen extract flue and fresh air input to existing pub.

Drawing Nos: Site location plan; 5733-14-101 Rev A; 5733-14-100 Rev A; 11199 REVC/V Rev 01; Details of RAF 520 Attenuator; Details of MUB 042 500D4-A2 IE2; Noise report dated Jan 2015

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of two months from the date of this permission.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies CS5 and CS7 of the



London Borough of Camden Local Development Framework Core Strategy and policies DP12, DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies and Section 91(1)b of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Core Strategy and policy DP24 and DP25 of the London Borough of Camden Local Development Framework Development Policies.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans: Site location plan; 5733-14-101 Rev A; 5733-14-100 Rev A; 11199 REVC/V Rev 01; Details of RAF 520 Attenuator; Details of MUB 042 500D4-A2 IE2; Noise report dated Jan 2015

Reason:

For the avoidance of doubt and in the interest of proper planning.

- 4 Noise levels at a point 1 metre external to sensitive facades shall be at least 10dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 15dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policy CS5 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

- 5 Before the first use of the kitchen extract and ventilation hereby approved, the extract ventilating system shall be mounted on anti-vibration isolators and the fan motors shall be vibration isolated from the casing. All such measures shall thereafter be retained and maintained in accordance with the manufacturers' recommendations.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policy CS5 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

- 6 Before the development commences, full details of a scheme for odour abatement, including manufacturers specifications, shall be submitted to and approved by the Local Planning Authority in writing. The use shall not proceed other than in complete accordance with such scheme as has been approved. All such measures shall be retained and maintained in accordance with the manufacturers' recommendations.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies CS5 and CS7 of the London Borough of Camden Local Development Framework Core Strategy and policies DP12, DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

- 7 Before the first use of the kitchen extract hereby permitted, the ventilation and filtration equipment to suppress and disperse fumes and/or smells created from cooking activities on the premises, shall be installed and be in full working order in accordance with the approved scheme. All such measures shall thereafter be retained and maintained in accordance with the manufacturers' recommendations. In the event of no satisfactory ventilation plant and / or machinery being provided, no primary cooking shall take place on the premises.

Reason: To safeguard the amenities of the premises and the area generally in accordance with the requirements of policies CS5 and CS7 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26, DP28 and DP12 of the London Borough of Camden Local Development Framework Development Policies.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'Ed Watson', with a stylized flourish at the end.

Ed Watson
Director of Culture & Environment