



622.01\_Tree Planting letter

Hergest Estate Office  
Ridgebourne Road  
Kington  
Herefordshire  
HR5 3EG  
U.K.

5<sup>th</sup> March 2015

T: +44 (0)1544 232 035 F: +44 (0)1544 232 031

Paul Straupmanis  
Moxley Architects  
47 Clapham High Street  
London  
SW4 7TL

[www.robertmyers-associates.co.uk](http://www.robertmyers-associates.co.uk)  
[mail@robertmyers-associates.co.uk](mailto:mail@robertmyers-associates.co.uk)

Dear Paul,

**6-10 CAMBRIDGE TERRACE, REGENTS PARK**

I am writing in relation to the construction of a new basement in front of 6-10, Cambridge Terrace in Regents Park, London. It is proposed to construct a new garden above the basement, as set out in the approved Robert Myers Associates planning drawings.

Having studied the engineer's cross section through the site (ref: 6392-3 903 section D-D) it would appear that there will be a depth of 1.8m of soil above the basement slab in which to establish the garden. This will include the planting of small/medium ornamental trees.

I confirm that subject to the inclusion of appropriate drainage of the roof slab, the use of free-draining soil and the installation of an automatic irrigation system, there would appear to be sufficient soil depth and extent to establish the approved tree planting.

Please let me know if you have any queries.

Yours sincerely,

Robert Myers

Director  
Robert Myers Associates