


proposed basement floor licensing plan

scale - 1:100



1:100 @ A3

EMERGENCY LIGHTING SYSTEM

An independant self-contained non-maintained system, type XOA180, will be installed in accordance with BS 5266-1:2011, Emergency Lighting - Part 1 - Code of Practice for Emergency Lighting of premises other than cinemas and certain otherspecified premises for entertainment, and BS EN 50172 : 2004, BS 5266-8 : 2004 Lighting Applications - Emergency Lighting. Luminaires will be located the approximate positions indicated on this drawing. All signs and notices will comply with BS 5499 : Part 1 - Fire Safety Notices and Graphic Symbols.

- 3 hr maintained exit legend
- 3 hr maintained exit light & legend
- 3 hr non-maintained light
- 3 hr non-maintained LED light
- 3 hr maintained external light
- 3 hr non-maintained floodlight
- Fire Fighting Equipment

FIRE ALARM SYSTEM

A Fire Alarm system will be installed to BS 5839 : Part 1, 2001 & A2 : 2008 Code of Practice for system design, installation, commissioning and maintenance, comprising of devices as indicated. The system category to be a L4 system.

- Fire Alarm Panel
- Magnetic Door Hold
- Manual Call Point
- Heat Detector
- Smoke Detector
- Indicator for Void Detector
- Indicates Void Detector
- Sounder
- Zenon Beacon
- Sounder Bases

Revisions			
Rev No.	Date	Revision	Rev by
Rev A	08.01.15	Alterations to toilet area added, emergency lighting and fire fighting equipment amended.	CE
Rev B	27.01.15	Tasting table, Bookshelves and loose furniture added. Areas defined.	CE
Rev C	29.01.15	Display fridges omitted, bookshelves reduced and re-positioned, Reading Area added.	CE



The Design Studio
211 Dumbarton Road
Glasgow
G11 6AA

(T) 0141 341 0343
(E) info@cmdesignconsultants.com
(W) www.cmdesignconsultants.com

GLASGOW - EDINBURGH - LONDON

DO NOT SCALE FROM THIS DRAWING

All dimensions to be checked on site prior to the start of any work and any discrepancies to be notified in writing.

All building works to comply in all respects to current Building Standards for country in which site is located.

All electrical work to be carried out in accordance with the latest edition of the Institute of Electrical Engineers Regulations and to the approval of the Local Authority.

All drainage work to be carried out in consultation with the Local Authority Inspectors and to be tested to the satisfaction of the Local Authority.

This drawing and the information shown are the property of CM Design Consultants Limited.

Client

BrewDog

Project

Bottle Dog (Basement)
69 Gray's Inn Road
London
WC1X 8TP

Drawing

Licensing Plan (Basement)

Drawn By

CE

Checked By

MB

Date

December 2014

Scale

1 : 100 @ A3

Job No.

1784

DWG. No.

100

Rev.

C