

<b>Application No:</b>	<b>Consultees Name:</b>	<b>Consultees Addr:</b>	<b>Received:</b>	<b>Comment:</b>	<b>Response:</b>
2015/1260/L	Richard Simpson Chair Regent's Park CAAC	12A Manley Street London NW1 8LT	01/05/2015 12:18:00	COMMNT	ADVICE from REGENT'S PARK CONSERVATION AREA ADVISORY COMMITTEE 12A Manley Street London NW1 8LT  27 April 2015  The White House , Albany Street, London NW1 3UP 2015/1260/L  No objection of principle, but, whatever the previous uses of this method of cleaning, we advise that a small area be used for a test. We are concerned about the penetration of the cleaning powder into the joints and cracks, the effect on the surface of the faience, and on the 'breathability' of the finish once completed.  Richard Simpson FSA Chair

---