

THE REGENT'S CANAL CONSERVATION AREA ADVISORY COMMITTEE
31 OVAL ROAD, CAMDEN TOWN, LONDON NW1 7EA

Chairman: Anthony Richardson

Please reply to: Anthony Richardson email: anthonyrichardson@arparchitects.co.uk Tel: 020 7485 0991

3111/03

22 May 2015

FAO: Kate Phillips
The Planning Dept
London Borough of Camden
The Town Hall, 2nd Floor, 5 Pancras Square
London WC1 4AG

Dear Sir

Application Ref: 2015/2020/P 80-82 Camden Road – Rear Garden Wall

We OBJECT to this application as follows.

1. The existing wall should be dismantled and rebuilt using the existing bricks.
2. The rebuilt wall should be constructed using English Garden Wall bond.
3. The existing tree should be retained – the new footing should be a suitable depth to allow for adjacent plant/tree growth.
4. The applicant should review their need to rebuild the whole wall. It will be more cost effective to repair the existing as there is no evidence of defective foundations.

Yours faithfully



Anthony Richardson

Chairman, The Regent's Canal Conservation Area Advisory Committee

cc: RCCAA Committee
thoogewerf@msn.com