

**ACOUSTIC REPORT**

**NO CS7612/1**

**Royal Free Hospital,  
Pond Street,  
London  
NW3 2QG**

**10<sup>th</sup> February 2015**

**Prepared By:**

*Stuart Metcalfe*

Stuart Metcalfe MIOA

**CLIENT:**

**Royal Free Hospital NHS Trust,  
Pond Street,  
London  
NW3 2QG**

**Royal Free London**



**NHS Foundation Trust**

**Conabeare Acoustics Limited**

11 Chiltern Enterprise Centre, Station Road, Theale, Berkshire. RG7 4AA  
Telephone 0118 930 3650 Facsimile 0118 930 3912

[sales@conabeare.co.uk](mailto:sales@conabeare.co.uk)

## **FORWARD**

An environmental acoustic survey has been carried out to the rear courtyard of Royal Free Hospital, Pond Street, London NW3 2QG.

The results of the survey will establish the Background Sound Level for new mechanical services plant in order that it complies with planning/design requirements.

## **SUMMARY**

The lowest  $L_{A90,15\text{min}}$  levels measured in the rear courtyard were;

$L_{A90,15\text{min}}$  52dB(A) between 07:00 hours to 19:00 hours.

$L_{A90,15\text{min}}$  54dB(A) between 19:00 hours to 23:00 hours.

$L_{A90,15\text{min}}$  53dB(A) between 23:00 hours to 07:00 hours.

### **Conabeare Acoustics Limited**

11 Chiltern Enterprise Centre, Station Road, Theale, Berkshire. RG7 4AA  
Telephone 0118 930 3650 Facsimile 0118 930 3912

[sales@conabeare.co.uk](mailto:sales@conabeare.co.uk)

## CONTENTS

1. Author
2. Client
3. Introduction
4. Noise Principles
5. The Site
6. Measurement Methodology
7. Planning Noise Requirements
8. Assessment
9. Measuring Location
10. Tabular Results
11. Graphs

**Conabeare Acoustics Limited**

**1. Author**

Stuart Metcalfe MIOA

The author of this report has been practicing in building services acoustics and noise control engineering for 25 years, is a Member of the Institute of Acoustics (MIOA) and is a Director at Conabeare Acoustics Ltd.

**2. Client**

The report and survey has been undertaken on behalf of:

Royal Free Hospital NHS Trust,  
Pond Street,  
London  
NW3 2QG

**3. Introduction**


The survey has been carried out to establish a maximum noise level for the proposed generator so that it does not have a detrimental effect on the local surroundings and in particular residential premises for testing purposes.

**4. Noise Principles**

The environmental survey has been carried out generally in accordance with the principles of BS7445-1 (2003) and BS4142 to establish the Background Sound Level

The Background Sound levels measured is in terms A-weighted sound pressure level  $L_{A90}$  with a time interval of 15 minutes.

**Conabeare Acoustics Limited**



## GLOSSARY.

L <sub>A90</sub>	The sound pressure level in dB(A) which is exceeded for 90% of the time and is taken to be the effective lowest background sound level for the period by such methods of sound rating as that recommended in British Standard 4142. It will also be used as a basis for selecting limiting sound levels from new plant by Local Planning Authorities when setting Planning Consent Conditions.
L <sub>eq</sub>	The “equivalent continuous sound level” for the measuring period, defined as the level in dB(A) which, if held constant over the measuring period, would produce the same amount of sound energy as does the actual varying ambient sound level. It is a measure of the amount of sound energy affecting the site from sources other than new plant or operations.
L <sub>A10</sub>	The sound level exceeded for 10% of the time over the sample period. Originally used as a measure of subjective reaction to traffic noise in particular, it can also be taken as an indication of the practical maximum sound level that the building envelope will have to protect against.
dB(A)	Describes measured on a sound level meter incorporating a frequency weighting (A weighting) which differentiates between sounds of different frequency (pitch) in a similar way to the human ear. Measurements in dB(A) broadly agree with people’s assessment of loudness. A change of 3dB(A) is the minimum perceptible under normal conditions, and a change of 10dB(A) corresponds roughly to halving or doubling the loudness of a sound.

**Conabeare Acoustics Limited**

11 Chiltern Enterprise Centre, Station Road, Theale, Berkshire. RG7 4AA

Telephone 0118 930 3650 Facsimile 0118 930 3912

[sales@conabeare.co.uk](mailto:sales@conabeare.co.uk)

## 5. The Site

The site is located to the South of the Hospital facing the rear elevation of premises to Aspern Grove.

The nearest residential façade is therefore at a distance of approximately 50 metres from the proposed plant.

We would judge that a mixture of existing plant and transportation noise are the dominant sound sources within the area.

## 6. Measurement Methodology

A CEL593 (precision) Environmental Sound Level Analyser, fitted with a CEL Electret Microphone was located at the rear of the property on the flat roof containing the existing plant.

The Survey commenced at approximately 11:30 hours on Thursday 5<sup>th</sup> February 2015 until approximately 11:00 hours on Friday 6<sup>th</sup> February 2015.

The Analyser was checked for calibration before readings commenced and at the end of the measurement period using a CEL 284/2 Class 1 calibrator. There was no measurable deviation on the Analyser.

The weather was mostly dry with some showers and cold throughout the measuring period.

The weather in our opinion did not have a detrimental effect on the readings obtained.


## 7. Planning noise requirements.

The Planning noise requirement of this area usually states, that any proposed plant should be at least 10dBA below the Background Sound level ( $L_{A90}$ ) measured at 1 metre from the nearest effected residential property. Allowance should also be made for any tonal noise emanating from the proposed units.

However as the plant in question is for Emergency and Testing only a level of 10dBA above the lowest measured background level would usually apply subject to the conditions as stated below.

This is generally acceptable to local authorities. However, this should be verified with the local Environmental Health or Planning Departments.

### **Conabeare Acoustics Limited**



## 8. Assessment

The Environmental Sound Level Analyser was located at a height of 1.5 metres above the ground level to the rear of the property to pick up the existing ambient noise and the background noise.

The values of  $L_{A90}$  measured on site are therefore assumed to be representative of the background levels at the façade of other nearby properties.

The objective of any specification limiting new noises should therefore be to ensure that sound emission from the new building services plant and any other new sources in particular should not materially add to the existing ambient sound climate.

As to the level at which the target should be set, this is normally specified by the planning authority in their planning consent conditions. As the Generator will only be used in case of emergency use or testing purposes on a monthly basis the proposed level would be 10db(A) above the measured background.

Most Planning Policies state;

*Where emergency plant or an emergency life supporting generator is to be installed, noise emitted from it must not exceed 10 dB above the lowest background ( $L_{A90}$  15 min) noise level within a 24-hour period.*

*Where emergency plant or a generator is installed testing times will be regulated. This period will be for a maximum one hour period per month between the hours of 09:00 and 17:00 Monday to Friday and not on public holidays or at weekends. Emergency plant will not be used for any other purpose other than emergency energy generation for the building occupiers or associated plant.*

The premises in closest proximity to the proposed facility are residential in usage and must be given particular consideration in terms of acceptable levels of noise exposure from the proposed fixed mechanical plant installation.

We would therefore propose, based upon the above, the following design targets for testing of the new Generator when measured at 1 metre from the Generator

$L_{Aeq-15min}$  62dB(A) between 07:00 hours to 19:00 hours (Day Time)


In our opinion all of the above should generally be acceptable to the local authority for this area, but all design targets should as a matter of course should be verified with the local Environmental Health or Planning Departments.

Once plant details are established we will carry out Acoustic Calculations to predict the noise levels and propose any mitigating measures accordingly.

### **Conabeare Acoustics Limited**

11 Chiltern Enterprise Centre, Station Road, Theale, Berkshire. RG7 4AA  
Telephone 0118 930 3650 Facsimile 0118 930 3912

[sales@conabeare.co.uk](mailto:sales@conabeare.co.uk)

**CONABEARE**  **ACOUSTICS**

Report carried out for and on behalf of Conabeare Acoustics Limited by,

*Stuart Metcalfe*

Stuart Metcalfe MIOA


**Conabeare Acoustics Limited**

11 Chiltern Enterprise Centre, Station Road, Theale, Berkshire. RG7 4AA  
Telephone 0118 930 3650 Facsimile 0118 930 3912

[sales@conabeare.co.uk](mailto:sales@conabeare.co.uk)



**CONABEARE**




**ACOUSTICS**

**9. Measuring Location**

Measuring  
Location

Location  
for New  
Generator

Nearest Residential  
Premises



**Conabeare Acoustics Limited**

11 Chiltern Enterprise Centre, Station Road, Theale, Berkshire. RG7 4AA

Telephone 0118 930 3650 Facsimile 0118 930 3912

[sales@conabeare.co.uk](mailto:sales@conabeare.co.uk)

**Survey Location**



**View showing nearest residential premises**




**Conabeare Acoustics Limited**

11 Chiltern Enterprise Centre, Station Road, Theale, Berkshire. RG7 4AA  
Telephone 0118 930 3650 Facsimile 0118 930 3912  
[sales@conabeare.co.uk](mailto:sales@conabeare.co.uk)

CS7612 - Royal Free Hospital, Pond Street, London NW3 2QG

- Period result profile -



Overload occurred	Yes
Low battery occurred	No
Pause was used	No
Frequency weighting	A
Band	Broadband
Period time	15 min
Periods too short for LNs	No
First period listed	1 : 94





Period number	Flags	Date and Time	LN90.0% F dB, (A)	LN10.0% F dB, (A)	Leq dB, (A)
	OBPZ				
1	O---	05/02/2015 11:29	55	61	60.8
2	----	05/02/2015 11:44	56	61	59.4
3	----	05/02/2015 11:59	58	62	61.1
4	----	05/02/2015 12:14	57	61	59.8
5	----	05/02/2015 12:29	59	61	59.8
6	----	05/02/2015 12:44	59	61	60.3
7	----	05/02/2015 12:59	59	60	59.8
8	----	05/02/2015 13:14	60	62	60.6
9	----	05/02/2015 13:29	60	61	60.4
10	----	05/02/2015 13:44	60	61	60.5
11	O---	05/02/2015 13:59	60	61	60.6
12	----	05/02/2015 14:14	59	60	60
13	O---	05/02/2015 14:29	60	61	60.6
14	----	05/02/2015 14:44	59	60	59.9
15	----	05/02/2015 14:59	57	61	59.9
16	----	05/02/2015 15:14	56	58	57
17	----	05/02/2015 15:29	57	60	58.4
18	----	05/02/2015 15:44	56	59	57.9
19	----	05/02/2015 15:59	57	59	58.1
20	----	05/02/2015 16:14	59	61	60.4
21	----	05/02/2015 16:29	57	61	59.4
22	----	05/02/2015 16:44	56	59	57.7
23	----	05/02/2015 16:59	56	58	57.5
24	----	05/02/2015 17:14	57	59	58.3
25	----	05/02/2015 17:29	57	60	58.8
26	----	05/02/2015 17:44	57	60	58.5
27	----	05/02/2015 17:59	56	61	59.2
28	----	05/02/2015 18:14	58	63	61.6
29	----	05/02/2015 18:29	56	59	58.1
30	----	05/02/2015 18:44	57	59	58.4
31	----	05/02/2015 18:59	56	59	57.5
32	----	05/02/2015 19:14	56	58	57.6
33	----	05/02/2015 19:29	56	59	57.6
34	----	05/02/2015 19:44	56	58	58
35	----	05/02/2015 19:59	56	59	57.3
36	----	05/02/2015 20:14	56	57	57.1
37	----	05/02/2015 20:29	56	59	58
38	----	05/02/2015 20:44	56	57	57.5
39	----	05/02/2015 20:59	56	59	57.6
40	----	05/02/2015 21:14	56	61	59.4
41	----	05/02/2015 21:29	54	61	58.6
42	----	05/02/2015 21:44	56	58	57.3
43	----	05/02/2015 21:59	56	58	57.2
44	----	05/02/2015 22:14	56	58	57.1
45	----	05/02/2015 22:29	56	57	57.1
46	----	05/02/2015 22:44	56	59	57.9

Period number	Flags	Date and Time	LN90.0% F	LN10.0% F	Leq
	OBPZ		dB, (A)	dB, (A)	dB, (A)
47	----	05/02/2015 22:59	56	58	57.1
48	----	05/02/2015 23:14	56	57	56.8
49	----	05/02/2015 23:29	56	58	57.2
50	----	05/02/2015 23:44	57	59	58
51	----	05/02/2015 23:59	56	58	57.4
52	----	06/02/2015 00:14	56	58	56.9
53	----	06/02/2015 00:29	56	58	57.5
54	----	06/02/2015 00:44	56	58	57.1
55	----	06/02/2015 00:59	56	57	56.6
56	----	06/02/2015 01:14	56	58	57
57	----	06/02/2015 01:29	56	57	56.5
58	----	06/02/2015 01:44	56	58	56.9
59	----	06/02/2015 01:59	56	57	56.6
60	----	06/02/2015 02:14	56	58	57
61	----	06/02/2015 02:29	56	58	57.3
62	----	06/02/2015 02:44	60	62	60.9
63	----	06/02/2015 02:59	56	60	57.6
64	----	06/02/2015 03:14	60	61	60.5
65	----	06/02/2015 03:29	53	57	56.4
66	----	06/02/2015 03:44	56	62	59.4
67	----	06/02/2015 03:59	56	58	56.9
68	----	06/02/2015 04:14	56	57	56.7
69	----	06/02/2015 04:29	56	58	57.1
70	----	06/02/2015 04:44	56	57	56.5
71	----	06/02/2015 04:59	56	58	56.8
72	----	06/02/2015 05:14	56	57	56.4
73	----	06/02/2015 05:29	56	57	56.5
74	----	06/02/2015 05:44	56	57	56.6
75	----	06/02/2015 05:59	56	58	57.1
76	----	06/02/2015 06:14	56	58	56.8
77	----	06/02/2015 06:29	57	58	57.4
78	----	06/02/2015 06:44	56	58	57.3
79	----	06/02/2015 06:59	56	59	57.8
80	----	06/02/2015 07:14	56	58	57.2
81	----	06/02/2015 07:29	56	58	57.5
82	----	06/02/2015 07:44	56	59	57.8
83	----	06/02/2015 07:59	56	59	57.8
84	----	06/02/2015 08:14	58	61	60.2
85	----	06/02/2015 08:29	57	62	60.5
86	----	06/02/2015 08:44	57	61	60.1
87	----	06/02/2015 08:59	52	61	59.6
88	----	06/02/2015 09:14	60	61	60.6
89	----	06/02/2015 09:29	59	61	60.5
90	----	06/02/2015 09:44	60	61	60.9
91	----	06/02/2015 09:59	60	61	60.9
92	----	06/02/2015 10:14	60	61	60.9
93	----	06/02/2015 10:29	60	62	61.4
94	----	06/02/2015 10:44	57	60	58.7



# CS7612 - Royal Free Hospital, Pond Street, London NW3 2QG



# CS7612 - Royal Free Hospital, Pond Street, London NW3 2QG



# CS7612 - Royal Free Hospital, Pond Street, London NW3 2QG



# CS7612 - Royal Free Hospital, Pond Street, London NW3 2QG

