

Jennifer Chivers
Planning Office
London Borough of Camden
5 Pancras Square
London NIC 4AG

Job 12741

11 June 2015


Dear Jennifer

3 DOWNSHIRE HILL LONDON NW3

In response to the point raised in your email of the 4 June please find our comments

1. Attached is a Map that is supplied by Camden showing the water courses in the area. It can be seen that there are no recorded water courses along either Pilgrims Lane or Downshire Hill. The main water courses are either side of the Haverstock Hill and will generally be fed by surface run off.
2. I can see no mention of a well under No 8 Pilgrims Lane, however one of the maps within the BIA notes there are two bore holes within 100m or so. These are marked as 'W' but are water extracting bore holes that are over 140m deep and extend in the chalk aquifer. Our basement will not have detrimental effect on the bore holes.
- 3 The additional tests for the permeability exercise are within appendix 6 of our report.

Yours sincerely



M W Stone
For Train & Kemp
marcstone@trainandkemp.co.uk

cc: Chris Gough Willetts – Studio Azzurro

