

<b>Application No:</b>	<b>Consultees Name:</b>	<b>Consultees Addr:</b>	<b>Received:</b>	<b>Comment:</b>	<b>Response:</b>
2014/6130/P	Meredith Whitten	Covent Garden Community Association 42 Earlham Street WC2H 9LA	30/06/2015 02:05:24	COMMNT	No objection provided any permission granted should require the applicant to have at least annual maintenance performed on all equipment, including ducting, to ensure it is running effectively and is not causing disturbance to nearby residents or exceeding 10 decibels below background. A condition also should be included that restricts use of the condenser unit to normal business/office hours. The unit should be turned off outside of these hours, including overnight. The CGCA notes that the applicant's acoustic report refers to the Royal Borough of Kensington and Chelsea's acoustic requirements, not Camden's, which causes concern that the report does not accurately reflect Camden's specific requirements.

---