



PROPOSED WORKS

- 1 Fit new compliant, upward flowing, high-level terminal to kitchen extract.
- 2 Fit silencers above and below kitchen extract fan to bring noise levels to at least 10dBA below background noise.
- 3 Fit acoustic enclosures to large and small Fujitsu air conditioning units to bring noise levels to at least 10dBA below background noise levels.

<p>73 GRAYS INN ROAD, LONDON WC1X REAR ELEVATION & SECTION AA - PROPOSED JONATHAN A LAW & ASSOCIATES © 99 LINCOLN COURT, BETHUNE ROAD, LONDON, N16 5EA t 020-7923 0708 e jala@jala.co.uk</p>	<p>DWG No: 327/B/2302 SCALE: 1:50 & 1:100 DATE: JULY 2015</p>
--	---