Henry, Genna

From:

Sent: 10 July 2015 13:33

Planning To:

3rd Party Planning Application Subject:

London Borough of Camden Camden Town Hall June 15 Argyle Street Euston Road London

WC1H 8EQ 10 July 2015

Dear Sir/Madam

Re: SITE BOUNDED AT HAWLEY WHARF, AND CASTLEHAVEN RD HAWLEY ROAD. KENTISH TOWN ROAD & REGENTS CANAL, LONDON, NW1

Waste Comments

Thames Water have reviewed the documentation provided and cannot agree to the discharging of Condition 57 Water Comments

Our DTS Ref: 1247

Your Ref: 2015/2238/P & 2015/2307/P -

Supplementary Comments

Thames Water have a large diameter trunk water main running along Kentish Town Road and passing beneath the footpath in close proximity to the development site. Whilst no impact piling works are to be carried out as part of this scheme, the proposed piling works for Building D will be within the exclusion zone for this asset and therefore we are unable to discharge Conditions 31 and 57 of the planning application until a full study is undertaken assess the impact to Thames Water assets as a result of the development. Please contact Thames Water Developer Services to discuss the requirements for an impact study further. (0845 850 2777 or by email at developer.services@thameswater.co.uk)

Yours faithfully **Development Planning Department**

Development Planning, Thames Water, Maple Lodge STW, Denham Way, Rickmansworth. WD3 9SQ

Tel:020 3577 9998

Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to

devcon.team@thameswater.co.uk

Did you know you can manage your account online? Pay a bill, set up a Direct Debit, change your details or even register a change of address at the click of a button, 24 hours a day. Please visit www.thameswater.co.uk.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales each with their registered office at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and intended solely for the use of the individual to whom it is addressed. Any views or opinions presented are solely those of the author and do not necessarily represent those of Thames Water Limited or its subsidiaries. If you are not the intended recipient of this email you may not copy, use, forward or disclose its contents to any other person; please notify our Computer Service Desk on +44 (0) 203 577 8888 and destroy and delete the message and any attachments from your system.

We provide the essential service that's at the heart of daily life.