

Application No:	Consultees Name:	Consultees Addr:	Received:	Comment:	Response:
2015/2742/L	Richard Simpson for Regent's Park CAAC	12A Manley Street London NW1 8LT	24/07/2015 18:08:05	OBJ	<p>Regent's Park CAAC 6 July 2015</p> <p>5 Chester Place, 2015/2742/L Discharge of condition 4 (drawings or samples of materials) granted under reference 2014/6989/L dated 21/01/15.</p> <p>The application was principally for the lining of the original pavement vaults to the Listed Building.</p> <p>The Committee advised that there was insufficient information on the drawings to allow the impact of the work of the fabric of the Listed structure to be adequately assessed. There were no indications of how the cavity between the existing structure and the lining would be drained – would it no need pumps, and if so where would they be located? There were no indications of electrical installation, and there was no detail showing how the mechanical ventilation unit would terminate on the face of the area wall. There were no indications of floor or ceiling finishes.</p> <p>Richard Simpson FSA Chair</p>
