

1 THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE MECHANICAL SPECIFICATION AND ALL OTHER ASSOCIATED MECHANICAL, ELECTRICAL AND ARCHITECTURAL DOCUMENTS.

2 DO NOT SCALE FROM THIS DRAWING — USE FIGURED DIMENSIONS ONLY. UNLESS OTHERWISE NOTED ALL DIMENSIONS ARE GIVEN IN MILLIMETRES.

ALL DIMENSIONS MUST BE VERIFIED ON SITE BEFORE THE COMMENCEMENT OF WORK OR THE FABRICATION OF ANY ITEM.

3 THE CONTRACTOR SHALL VISIT THE SITE DURING THE TENDER PERIOD TO ASCERTAIN THE EXTENT AND COMPLEXITY OF THE WORKS.

LOCATIONS SHOWN ARE APPROXIMATE ONLY FINAL POSITIONING IS TO BE DETERMINED ON SITE.

THE WHOLE OF THE NEW PIPEWORK INSTALLATION SHALL BE CHLORINATED AND TESTED PRIOR TO FINAL CONNECTION TO THE EXISTING NWL SYSTEMS.

15 TRENCH DEPTHS SHALL BE AS THE STANDARD SPECIFICATION FOR DISTRICT HEATING NETWORKS

IN THE CASE OF OF THE EXISTENCE OF BRANCHES THE ACTUAL DEPTH IS DETERMINED BY THE BRANCH AS PER THE STANDARD SPECIFICATION FOR DISTRICT HEATING NETWORKS

PIPEWORK TO BE INSTALLED AT THE CORRECT DEPTH AND FALLS IN BUILDERS TRENCH, COMPLETE WITH BEDDING MATERIAL. TRENCH TO BE BACKFILLED AND SURFACE MADE GOOD FOLLOWING TESTING AND COMMISSIONING

16 FOR CONNECTION/BRANCH DETAILS NOT IDENTIFIED CONTRACTOR TO CONFIRM MANUFACTURES STANDARD DETAILS

11 DISTRICT HEATING MAINS TO BE COMPLETE WITH ALL VALVES, FITTINGS, EXPANSION PROVISION & LEAK DETECTION.

CONTRACTOR SHALL MAKE DUE ALLOWANCE FOR INSTALLING DISTRICT HEATING MAINS AROUND EXISTING UTILITY SERVICES AND DRAINAGE ENSURING ALL CLASHES ARE AVOIDABLE.

10 VENTS, DRAINS, TEMPERATURE/PRESSURE RELIEF VALVES NOT SHOWN FOR CLARITY.

LOCATIONS SHOWN ARE APPROXIMATE ONLY. FINAL POSITIONING IS TO BE DETERMINED ON SITE.

THE CONTRACTOR SHALL DETERMINE ALL PIPEWORK ROUTES BEFORE COMMENCEMENT ON SITE.

INSTALL VENTS AND DRA LOW POINTS.

OCKS ON ALL SYSTEM HIGH AND

SERVICE LOCATIONS SHOWN ARE APPROXIMATE ONLY. ACTUAL POSITIONS ARE TO BE DETERMINED ON SITE.

NOTES

DRAWING No. 5649/M-142 REV. C

TYPICAL SUB PLANT ROOM SERVING BLOCK C

ALEXANDRA ROAD ESTATE

Camden

90E

BSI Company Co sesdale South, n on Tees, TS17 6SE ax No. 01642 634 877 Web www.dtagroup.c TEESSIDE

Consulting Engineers LLP

Multi Discipline Consultancy

DECEMBER 2013

1:25 1:50 DATE

TENDER ISSUE.

TENDER ISSUE.

CONNECTION TO MAINS WATER SERVICES REROUTED

FOR INFORMATION

DESCRIPTION

Cons

X Tender

Tender SSUE.

Consequence

Tender issue.

Tender issue.

Tender issue.

Tender issue. N DW TC
DR. CH.
Construction
As-Built PB LA GL LA DW TC.