10 August 2015

Job No: 12051



Ecos Maclean Ltd Engineering – materials, energy, structure 8A Chamberlain St London NW1 8XB T: 020 7722 7525 F: 020 7722 9711 E: <u>office@ecosmaclean.co.uk</u> <u>www.ecosmaclean.co.uk</u>

Sam Fowler Planning Officer London Borough of Camden

Dear Mr Fowler

30 Princess Road

I am writing as the structural engineer appointed to prepare the Basement Impact Assessment in January 2013. The plans have been amended to enlarge the extent of the basement below the rear courtyard.

This change has no significant impact on the subterranean ground water flow and so the response to screening questions 3.1 1 to 6 are unchanged. The changes also have no significant impact on slope stability and so the response to screening questions 3.2 1 to 14 are unchanged. The changes also have no impact on hydrogeological, hydrological or flood risk impacts and so the responses to screening questions 3.3 1 to 6 remain the same. The conceptual site model also remains the same.

The additional excavation in the rear yard is further away from the neighbouring properties and so will not increase the risk of movement or cracking of the party wall.

I therefore conclude that the Basement Impact Assessment does not need to be amended and the conclusions remain the same.

Yours sincerely

Nide Maclean

Nick Maclean Principal Engineer & Director

Company registered in England and Wales Company number 8141950 VAT Reg No. 154 5109 26