

Application No:	Consultees Name:	Consultees Addr:	Received:	Comment:	Response:
2015/4219/P	Chris Horden	162 Eversholt St NW1 1BL	25/08/2015 17:45:14	COMMNT	<p>All of the supporting documents state that there will be 32 beds in the hostel. However, photos of the hostel - and other backpacker type hostels - contain bunks, which would make the total number of people 64, assuming all beds are in fact bunks, as the plans suggest.</p> <p>I believe, though stand to be corrected, this would also be in violation of standard fire safety requirements that state no more than 30 people should be resident on one level without a secondary fire escape.</p> <p>I would like my name and address to remain anonymous, due to perceived competitor overlap.</p>
