

FLAT 14, 34 JAMESTOWN ROAD, LONDON

PLANNING COMPLIANCE REPORT

Report 13033.PCR.01

For:

**The Iceworks
Jamestown Road
London
NW1 7BY**

Site Address	Report Date	Revision History
Flat 14, 34 Jamestown Road, London, NW1 7BY	24/08/2015	

CONTENTS

1.0	INTRODUCTION	2
2.0	ENVIRONMENTAL NOISE SURVEY AND EQUIPMENT	2
2.1	Procedure	2
2.2	Equipment	2
3.0	RESULTS	3
4.0	NOISE CRITERIA	3
5.0	DISCUSSION	4
5.1	Objective overview	4
6.0	CONCLUSION	5

List of Attachments

13033.SP1	Indicative Site Picture
13033.SP2	Indicative Side Plan
13033.TH1	Environmental Noise Time History
Appendix A	Glossary of Acoustic Terminology
Appendix B	Acoustic Calculations

1.0 INTRODUCTION

KP Acoustics Ltd, Britannia House, 11 Glenthorne Road, London, W6 0LH, has been commissioned by The Iceworks, Jamestown Road, London, NW1 7BY to undertake an environmental noise survey at Flat 14, 34 Jamestown Road, London. The background noise levels measured will be used to determine daytime and night-time noise emission criteria for the installation of one air conditioning unit in agreement with the planning requirements of The London Borough of Camden.

This report presents the overall methodology and results from the environmental survey followed by calculations to demonstrate the feasibility of the plant installation to satisfy the emissions criterion at the closest noise-sensitive receiver and outline mitigation measures as appropriate.

2.0 ENVIRONMENTAL NOISE SURVEY AND EQUIPMENT

2.1 Procedure

Automated noise monitoring and manual measurements were undertaken on the proposed site as shown in Site Plan 13033.SP1 and 13033.SP2. The choice of this position was based both on accessibility and on collecting representative noise data in relation to the nearest noise sensitive receiver relative to the proposed plant installation. The duration of the survey was between 16:30 on 05/08/2015 and 15:30 on 07/08/2015.

Initial inspection of the site revealed that the background noise profile at the monitoring location was dominated by road traffic noise from the surrounding roads and activities at a construction site close to the noise monitoring location.

The weather during the course of the survey was generally dry with wind speeds within acceptable tolerances and therefore suitable for the measurement of environmental noise. The measurement procedure generally complied with ISO 1996-2:2007 Acoustics *"Description, measurement and assessment of environmental noise - Part 2: Determination of environmental noise levels"*.

2.2 Equipment

The equipment calibration was verified before and after the survey and no calibration irregularities were observed.

The equipment used was as follows.

- 1 No. Svantek Type 958 Class 1 Sound Level Meter
- B&K Type 4231 Class 1 Calibrator

3.0 RESULTS

The results from the continuous noise monitoring are shown as a time history of L_{Aeq} , L_{Amax} , L_{A10} and L_{A90} averaged over 5 minute sample periods in Figure 13033.TH1.

Minimum background noise levels are shown in Table 3.1.

Minimum background noise level	
$L_{A90: 5min}$ dB(A)	
Daytime (07:00-23:00)	44
Night-time (23:00-07:00)	39

Table 3.1: Minimum measured background noise levels

4.0 NOISE CRITERIA

The criterion of The London Borough of Camden states that noise emission level from machinery at 1m from the closest noise sensitive receiver should be at least 5 dB below background noise level. If the proposed plant units generate noise that has a distinguishable discrete continuous note (whine, hiss, screech, hum) or distinct impulses the noise emission level should be at least 10 dB below background noise level.

Since the proposed condenser unit would not generate distinct impulses and spectral noise levels provided by the manufactured do not present any tonal note, the 5 dB below background noise level criterion is proposed and shown in Table 4.1.

Noise emission level criteria for proposed new plant units	
(dBA)	
Daytime (07:00-23:00)	39
Night-time (23:00-07:00)	34

Table 4.1: Proposed criteria following The London borough of Camden criterion

Since the plant unit could be operate at any time, we therefore propose the level of 34 dB(A) at night-time as the noise emission level criterion at 1m from the closest noise sensitive receiver façade for new plant units.

5.0 DISCUSSION

It is understood that the plant installation is comprised of the following units:

- 1 No. Mitsubishi MXZ5D102VA Outdoors Condenser Unit

The unit would be installed behind the glass balustrade of the Flat 14 roof terrace at 34 Jamestown Road as shown in site plan 13033.SP1-2. The closest noise sensitive receiver to this location will be a residential window at the top floor level of Gilbey House located to the west of the proposed plant unit location. The aforementioned closest noise sensitive receiver is located at a direct distance of approximately 15 meters as shown in site plan 11270.SP1.

The aforementioned glass balustrade would provide a certain degree of acoustic attenuation.

The sound pressure levels as provided by the manufacturer for the units are shown in Table 5.1.

	Sound Pressure Level at 1m (dB) by octave frequency band (Hz)							
	63	125	250	500	1k	2k	4k	8k
Mitsubishi MXZ5D102VA Condenser Unit	59	55	52	49	48	43	44	33

Table 5.1 Manufacturer’s Sound Pressure Levels at 1m.

5.1 Objective overview

As shown in Appendix B and Table 5.2, transmission of noise to the nearest sensitive window fully satisfies the London Borough of Camden noise emission criterion.

Receiver - Nearest Noise Sensitive Window	Criterion	Noise Level at Receiver (Residential Window)
Any time	34 dB(A)	27 dB(A)

Table 5.2: Predicted noise level and criterion at nearest noise sensitive location

Furthermore, the value of 27dB(A) is to be considered outside of the receiver’s facade. Windows may be closed or partially closed leading to further attenuation.

Further calculations have been undertaken to assess whether the noise emissions from the air conditioning unit would be expected to meet the recognised British Standard recommendations, in order to further ensure the amenity of nearby noise sensitive receivers.

British Standard BS8233:2014 ‘Guidance on sound insulation and noise reduction for buildings’ gives recommendations for acceptable internal noise levels in different types of buildings. Assuming worst case conditions of the closest window being for sleeping/resting space, BS8233 recommends 30-35 dB(A) as being acceptable internal rest conditions.

According to BS8233:2014, even a partially open window offers 10-15dB attenuation, thus leading to a further reduced interior noise level.

Receiver	Conditions Design Range – <i>For resting/sleeping conditions in a bedroom, in BS8233:2014</i>	Noise Level at Receiver (due to plant installation)
Inside Nearest Residential Space	30-35 dB(A)	Non-significant

Table 5.5: Noise levels and criterion inside nearest residential space

Predicted levels are shown in Table 5.5, with detailed calculations shown in Appendix B. It can therefore be stated that, as well as complying with the set criterion, the emissions from the air conditioning units would be expected to comfortably meet the most stringent recommendations of the relevant British Standard.

6.0 CONCLUSION

An environmental noise survey has been undertaken Flat 14, 34 Jamestown Road, London, NW1 7BY, by KP Acoustics Ltd between 05/08/2015 and 07/08/2015. The results of the survey have enabled criteria to be set for noise emissions. Using manufacturer noise data, noise levels are predicted at the nearby noise sensitive receivers for compliance with current requirements.




Calculations show that noise emissions from the proposed plant unit installation would meet the set requirements.

Further calculations have been undertaken with regards to the relevant British Standard and it has been ensured that the amenity of nearby residential receiver will be protected.

Report by
Victor Lindstrom
KP Acoustics Ltd

Checked by
Kyriakos Papanagiotou MIOA
KP Acoustics Ltd



-  Proposed condenser unit location
-  Closest noise sensitive receiver
-  Noise monitoring position

Title:


Indicative site picture showing noise monitoring and closest noise sensitive receiver.

Source: Google Earth.

Date: 24 August 2015

FIGURE 13033.SP1





Title:

Indicative site plan of Flat 14 terrace, 34 Jamestown Road showing noise monitoring and proposed condenser unit location.

Date: 24 August 2015

FIGURE 13033.SP2



34 Jamestown Road, London
Environmental Noise Time History
5th to 7th April 2015




Figure 12349.TH1

GENERAL ACOUSTIC TERMINOLOGY

Decibel scale - dB

In practice, when sound intensity or sound pressure is measured, a logarithmic scale is used in which the unit is the 'decibel', dB. This is derived from the human auditory system, where the dynamic range of human hearing is so large, in the order of 10^{13} units, that only a logarithmic scale is the sensible solution for displaying such a range.

Decibel scale, 'A' weighted - dB(A)

The human ear is less sensitive at frequency extremes, below 125Hz and above 16Khz. A sound level meter models the ears variable sensitivity to sound at different frequencies. This is achieved by building a filter into the Sound Level Meter with a similar frequency response to that of the ear, an A-weighted filter where the unit is dB(A).

L_{eq}

The sound from noise sources often fluctuates widely during a given period of time. An average value can be measured, the equivalent sound pressure level L_{eq} . The L_{eq} is the equivalent sound level which would deliver the same sound energy as the actual fluctuating sound measured in the same time period.

L_{10}

This is the level exceeded for no more than 10% of the time. This parameter is often used as a "not to exceed" criterion for noise.

L_{90}

This is the level exceeded for no more than 90% of the time. This parameter is often used as a descriptor of "background noise" for environmental impact studies.

L_{max}

This is the maximum sound pressure level that has been measured over a period.

Octave Bands

In order to completely determine the composition of a sound it is necessary to determine the sound level at each frequency individually. Usually, values are stated in octave bands. The audible frequency region is divided into 11 such octave bands whose centre frequencies are defined in accordance with international standards. These centre frequencies are: 16, 31.5, 63, 125, 250, 500, 1000, 2000, 4000, 8000 and 16000 Hertz.

Environmental noise terms are defined in BS7445, *Description and Measurement of Environmental Noise*.

APPLIED ACOUSTIC TERMINOLOGY

Addition of noise from several sources

Noise from different sound sources combines to produce a sound level higher than that from any individual source. Two equally intense sound sources operating together produce a sound level which is 3dB higher than a single source and 4 sources produce a 6dB higher sound level.

Attenuation by distance

Sound which propagates from a point source in free air attenuates by 6dB for each doubling of distance from the noise source. Sound energy from line sources (e.g. stream of cars) drops off by 3dB for each doubling of distance.

Subjective impression of noise

Hearing perception is highly individualised. Sensitivity to noise also depends on frequency content, time of occurrence, duration of sound and psychological factors such as emotion and expectations. The following table is a guide to explain increases or decreases in sound levels for many scenarios.

Change in sound level (dB)	Change in perceived loudness
1	Imperceptible
3	Just barely perceptible
6	Clearly noticeable
10	About twice as loud

Transmission path(s)

The transmission path is the path the sound takes from the source to the receiver. Where multiple paths exist in parallel, the reduction in each path should be calculated and summed at the receiving point. Outdoor barriers can block transmission paths, for example traffic noise. The effectiveness of barriers is dependent on factors such as its distance from the noise source and the receiver, its height and construction.

Ground-borne vibration

In addition to airborne noise levels caused by transportation, construction, and industrial sources there is also the generation of ground-borne vibration to consider. This can lead to structure-borne noise, perceptible vibration, or in rare cases, building damage.

Sound insulation - Absorption within porous materials

Upon encountering a porous material, sound energy is absorbed. Porous materials which are intended to absorb sound are known as absorbents, and usually absorb 50 to 90% of the energy and are frequency dependent. Some are designed to absorb low frequencies, some for high frequencies and more exotic designs being able to absorb very wide ranges of frequencies. The energy is converted into both mechanical movement and heat within the material; both the stiffness and mass of panels affect the sound insulation performance.

APPENDIX B

FLAT 14, 34 JAMESTOWN ROAD, LONDON

PLANT UNIT EMISSIONS CALCULATIONS

	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Source: Outdoor condenser unit MXZ5D102VA									
Receiver: Gilbey House Window									
Mitsubishi MXZ5D102VA outdoor condenser unit	59	55	52	49	48	43	44	33	
Attenuation due to distance (15m)	-24	-24	-24	-24	-24	-24	-24	-24	
Correction due to reflection	3	3	3	3	3	3	3	3	
Correction due to acoustic barrier (glass balustrade)	-5	-5	-5	-5	-5	-5	-5	-5	
Maximum Sound pressure level at receiver	33	29	26	23	22	17	18	0	27
	Design Criterion								34

	Frequency, Hz								dB(A)
	63	125	250	500	1k	2k	4k	8k	
Source: Outdoor condenser unit MXZ5D102VA									
Receiver: Gilbey House Window									
Sound pressure level outside bedroom window	43	41	30	22	15	2	0	0	28
Minimum attenuation from partially open bedroom window, dB	-10	-10	-10	-10	-10	-10	-10	-10	-10
Maximum Sound pressure level inside receiver due to source	33	31	20	12	5	-8	-10	-10	18
	BS8233 Design Criterion								30-35