

Dempsey, Matthew

From: Baxter, Nick
Sent: 06 August 2015 12:48
To: matthew.gibbs@dp9.co.uk
Cc: Dempsey, Matthew
Subject: Bedford Square 42, 2015/3616/L (piano nobile doorway)

Follow Up Flag: Follow up
Flag Status: Flagged

Dear Matthew – I am concerned that the wall between the front and back rooms might be load bearing.

If this is the case, it may contain diagonal timber members, and you will need to design your doorway differently.

Please can you explain whether you have ruled out this possibility? It may be that more careful opening-up is necessary.

Kind regards,
Nick Baxter MSc
Senior Heritage and Conservation Officer
Regeneration and Planning
Culture and Environment
London Borough of Camden

Telephone: 020 7974 3442
Web: camden.gov.uk
5 Pancras Square
5 Pancras Square
London N1C 4AG

Please consider the environment before printing this email.