

Lounge

Proposed Floor Joists - 150mm x 75mm C24 timber @ 400 c/c T.B.C. by Approved Inspector.

60mm Kingspan Kooltherm K12 framing board insulation

22mm Tongue & Groove flooring

50mm mineral fibre (Green) acoustic matt slabs

Inside



Outside

Window.

Double glazed Acid Etched Glass within painted timber frame.

Above Caretakers Office.

Support to floor joists (trimmer beam) at opening in solid masonry wall to be 200mm x 50mm grade 24 timber, fixed to blockwork with 2 M12 resin anchors at each support.

Above Cycle Store.

Support to floor joists (trimmer beam) at opening in solid masonry wall to be 152 x 89 UB 16 bearing on SHS 80 x 80 x 5.0 columns at each end (denoted by short dashed lines).

Glass panel with acid etched film on internal face of glass panel, supported by beads at top and bottom.

Door. Double glazed part acid etched glass within painted timber frame.

291

1 layer of Gyproc Plank and 12.5mm Gyproc WallBoard

100mm mineral fibre (Green) acoustic matt slabs

2no. 15mm British Gypsum SoundBloc ceiling boards with 3mm skim finish.

Caretakers Office / Store

Outside

Preliminary		Project Lithos House, 307 Finchley Road		Drawing Size. A4	File Ref: 1123 - BB - Plans 31a.pln	© Copyright	
Planning		Client Gallery Zadah Pension Fund	Date June 15	Scale 1:5	Rev A	Date 24-08-15	Amendment to annotation.
Building Regs.		Drawing Detail 004 - Floor intersection at external arched opening.	Reference Number 1123-BB-119 B		Rev B	Date 15-09-15	Amendment to annotation.
Tender							
Construction							
As-built							

© Copyright

DONALD SHEARER
ARCHITECTS
CHARTERED ARCHITECTS

Scholar's House, Shotton Brook Office Park, Tel: 01789 294 560
Timothy's Bridge Road, Stratford-upon-Avon,
Warwickshire, CV37 9NR donald@ds-architects.demon.co.uk