

## Hazelton, Laura

---

**Subject:** FW: Lighting levels Northumberland Hs  
**Attachments:** LO.0-006.pdf; LO.0-005.pdf; AU-ST106A.pdf

---

**From:** Allison Matthews [mailto: [REDACTED]]  
**Sent:** 16 September 2015 13:26  
**To:** Hazelton, Laura  
**Subject:** Fw: Lighting levels Northumberland Hs

Dear Laura

please see the information below re: lighting levels. Please note that there are 2no. LED strips to be positioned on the last 2 slats of the canopy facing onto the existing curtain walling, each strip will run the width of the canopy.

Also, I attach a copy of the manufacturers details and PDF copy of the amended front elevation as per my email of yesterday. 3no. hard copies of the drawings are in the post again.

Please advise if you require further clarification.

Best wishes

Allison

---

**From:** Terry Froud [mailto: [REDACTED]]  
**Sent:** 15 September 2015 11:05  
**To:** Lee Bedford  
**Subject:** Re: Lighting levels Northumberland Hs

Lee I sent this to supplier  
They have confirmed it is hard to do a calc as it is not a room area ie no walls ,ceilings ,or floor finishes

The tape will give 420 lumens per metre  
And will be approx 150 lux under the canopy  
There will be no glare from the tape

Regards

Terry

Sent from my iPhone