

Miss Jade Wong
Montagu Evans LLP
5 Bolton Street
London
W1J 8BA

Application Ref: **2015/3526/P**
Please ask for: **Rachel English**
Telephone: 020 7974 **1343**

28 September 2015

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:
Centro House
20-23 Mandela Street
London
NW1 0DU

Proposal:
Alternative use of part of ground floor as either office (Class B1) or restaurant/café (Class A3) use.
Drawing Nos: Site location plan, 2648/L/02
Cover letter from Montagu Evans dated 22nd June 2015 (ref PD9297/NS/JW)
Sharps Redmore Acoustic Consultants Noise Assessment dated 24th April 2015

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and



Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans:
Site location plan, 2648/L/02, Cover letter from Montagu Evans dated 22nd June 2015 (ref PD9297/NS/JW) and Sharps Redmore Acoustic Consultants Noise Assessment dated 24th April 2015

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 The use hereby permitted shall not be carried out other than between the following times: 0700 and 1700 Mondays to Fridays.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies CS5 and CS7 of the London Borough of Camden Local Development Framework Core Strategy and policies DP12, DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

- 4 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policy CS5 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel.

No. 020 7974 4444 or on the website
<http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

- 3 You are advised that if implemented, the alternative use permission hereby granted gives flexibility of use for 10 years from the date of this permission. After 10 years the lawful use would revert to whichever of the uses is taking place at the time.
- 4 You are reminded of the need to provide adequate space for internal and external storage for waste and recyclables. For further information contact Council's Environment Services (Waste) on 020 7974 6914/5 or see the website <http://www.camden.gov.uk/ccm/content/environment/waste-and-recycling/twocolumn/new-recycling-rubbish-and-reuse-guide.en>.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully



Ed Watson
Director of Culture & Environment