

Mr Thaddaeus Jackson-Browne
Lambert Smith Hampton
United Kingdom House,
180 Oxford Street,
London,
W1D 1NN

Application Ref: **2015/4845/P**
Please ask for: **Anna Roe**
Telephone: 020 7974 **1226**

14 October 2015

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted

Address:
225 Tottenham Court Road
London
W1T 7QF

Proposal:
Installation of replacement rooftop Air Conditioning (AC) equipment.
Drawing Nos: 12021J-02; OS Extract and Acoustic Report, produced by Aulos Acoustics,
dated 28th July 2015.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as



possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Core Strategy and policy DP24 and DP25 of the London Borough of Camden Local Development Framework Development Policies.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans: 12021J-02; OS Extract and Acoustic Report, produced by Aulos Acoustics, dated 28th July 2015.

Reason:

For the avoidance of doubt and in the interest of proper planning.

- 4 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policy CS5 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out

construction other than within the hours stated above.

3 Reasons for granting permission.

The proposal is to install a replacement rooftop air conditioning unit in connection with the refurbishment of a commercial unit.

Due to the location of the equipment behind parapet walls on the roof of the building it would not be visible from surrounding streets and would have no discernible impact upon the appearance of the building when viewed from neighbouring buildings.

A Plant Noise Assessment Report has been undertaken to establish the minimum background noise level. The lowest background noise levels measured during the survey were 54 dB during the daytime and 52dB at night. Camden Council requires plant noise emission to be 5 dB below the minimum background noise level at 1m from the nearest noise sensitive receptor. Predicted noise levels are expected to be 15dB below the minimum background noise levels. Therefore the proposal is considered to comply with policies DP26 and DP28. As a safeguarding measure this permission has been granted subject to a condition to ensure that the unit is installed and maintained in accordance with the submitted information.

The site's planning history has been taken into account when coming to this decision. No objections have been received following statutory consultation.

Considerable importance and weight has been attached to the harm and special attention has been paid to the desirability of preserving or enhancing the character or appearance of the conservation area, under s.72 of the Planning (Listed Buildings and Conservation Areas) Act 1990 as amended by the Enterprise and Regulatory Reform Act 2013.

As such, the proposed development is in general accordance with policies CS5, CS14 and CS17 of the London Borough of Camden Local Development Framework Core Strategy, and policies DP24, DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies. The proposed development also accords with policies 7.4 and 7.6 of the London Plan 2011; and paragraphs 14, 17, 56-67, and 123 of the National Planning Policy Framework.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'Ed Watson', written in a cursive style.

Ed Watson
Director of Culture & Environment