



**Developer Services
Customer Led Team**

Niall McFadden
Walsh
32 Lafone Street
London,
SE1 2LX

Your ref
Our ref X2039/635
Name Khai Ng
Phone 07747 644963
E-Mail ng.khai@thameswater.co.uk

4th Nov 2015

Dear Niall McFadden,

**Camden Lock Village, Kentish Town Road, London
Thames Water's Letter of No Further Comment to Proposed Development
Adjacent to the Existing 16" Diameter Water Main**

I confirm that we have completed the review of your submission as listed below:-

- Camden Lock Village, London: Area D and E Thames Water asset impact assessment (ref: CG/18067A, date: 29th October 2015).
- Trigger limits for levelling points (e-mail dated 30th October 2015).

Based on your submission, we have no further comment to your proposed development adjacent to Thames Water's 16" water main that runs beneath Kentish Town Road. However the proposal detailed in the documentation listed above is subject to the following condition:

- Vibration monitoring shall be undertaken during the proposed works according to "Thames Water's Guidance for Working near Our Assets". A monitoring plan shall be produced to Thames Water prior to the works.
- Ground movement monitoring.

Please note that Thames Water reserves the right to hold Stanley Sidings Limited and any relevant contractors or sub-contractors liable for any losses incurred or damage caused to Thames Water assets arising from the construction works and/or subsequent use of the facility.

Yours sincerely,

Khai Ng
Design Consultant,
Customer Led Group, Developer Services.

Thames Water Utilities Limited
Customer Led Team
Developer Services
Clearwater Court
Vastern Road
Reading RG1 8DB

T 0118 373 8871

Registered in England and Wales
No. 2366661, Registered office
Clearwater Court, Vastern Road,
Reading, Berkshire RG1 8DB