

<b>Application No:</b>	<b>Consultees Name:</b>	<b>Consultees Addr:</b>	<b>Received:</b>	<b>Comment:</b>	<b>Response:</b>
2015/6443/P	Meredith Whitten	Covent Garden Community Association 42 Earlham Street WC2H 9LA	11/12/2015 17:01:00	OBJ	<p>Objection. The noise report submitted by the applicant is significantly flawed. It does not include the required measurements, instead relying on the consultant's subjective hearing. (The report says, "Subjectively I could not hear any noise contribution from the McDonald's plant" – see page 5).</p> <p>Additionally, the noise report relies on a current configuration of plant and equipment that is operating either without planning permission or without proper maintenance. Thus, establishing a baseline background level with the existing (unpermitted) equipment is wrong.</p> <p>Further, the noise report says that the plant and equipment will operate until 23:00, however the applicant is currently is seeking a license to operate the premises until 1 a.m, at which time the other equipment in the lightwell will have ceased operating. In this case the applicant's equipment will add to background noise and will therefore cause harm to residents.</p>

---