

Planning Statement

Energy Assessment

Ellerdale Road

Document information:

Prepared for:
Matthew Berry-McIntosh
Charles Edward Construction

Date of current issue:
10/12/2015

Issue number: 1

Our reference:
1587-Energy Assessment-1512-10YP.docx

Assessment information:

Prepared by:
Panayiota Paraskeva

Quality assured by:
Chris Hocknell

Signature:
Panayiota Paraskeva

Signature:
Chris Hocknell

Disclaimer:

This report is made on behalf of Eight Associates. By receiving the report and acting on it, the client - or any third party relying on it - accepts that no individual is personally liable in contract, tort or breach of statutory duty (including negligence).

Contents:

Executive Summary	1
Introduction	4
Establishing Emissions: The Carbon Profile	5
'Be Lean': Demand Reduction Measures	6
'Be Clean': Heating Infrastructure & CHP	8
'Be Clean': Connection to Existing and Planned Networks	9
'Be Clean': Site Wide Networks and CHP	10
'Be Clean': Cooling	11
'Be Green': Renewable Energy	16
'Be Green': Summary of Renewable Technologies.....	23
'Be Green': Photovoltaic.....	24
Conclusion	27
Appendix	28

Executive Summary

Energy Assessment

Ellerdale Road

About the Scheme:

The project consists of the new construction of a 3 storey dwelling at 1 Ellerdale Road in the London Borough of Camden, with two basement levels and a small garden. The dwelling has a total Gross Internal Area of 221 m².

Planning Policy


The scheme does not have to comply with the London Plan Policy based on the floor area, however the aspiration of the scheme is to achieve a 35% carbon reduction target (beyond Part L 2013) as set out in The London Plan Policy 5.2.

The scheme complies with the 2013 Building Regulations Part L and the minimum energy efficiency targets in the following documents have been followed:

- New build (Part L1A) – The actual building CO₂ emissions rate (DER) is no greater than the notional building CO₂ target emissions rate.

The Energy Hierarchy:

The proposed scheme has followed the energy hierarchy that is illustrated below:



The resulting energy savings are shown below in accordance with the GLA's Energy Hierarchy:

GLA's Energy Hierarchy – Regulated Carbon Emissions				
	Baseline:	Be Lean:	Be Clean:	Be Green:
CO ₂ emissions (Tonnes CO ₂ /yr)	3.31	3.23	-	1.94
CO ₂ emissions saving (Tonnes CO ₂ /yr)	-	0.07	-	1.29
Saving from each stage (%)	-	2.2	-	39.0
Total CO ₂ emissions saving (Tonnes CO ₂ /yr)	1.36			
41.2% Total carbon emissions savings over Part L of the Building Regulations 2013 achieved				

Executive Summary


Energy Assessment

Ellerdale Road

GLA's Energy Hierarchy – Regulated Carbon Emissions:

A graphical illustration of how the scheme performs in relation to Building Regulations and the Energy Hierarchy is shown below.

Figure:



Summary:

As demonstrated above the development will reduce carbon emissions by 2.2% from the fabric energy efficiency measures described in the 'Be Lean' section, and will reduce total carbon emissions by 41.2% over Building Regulations with the further inclusion of low and zero carbon technologies (PV panels).

Executive Summary

Energy Assessment

Ellerdale Road

Shortfall in Emissions:

As set out in Policy 5.2 of the London Plan, if the development fails to meet the 35% target, the annual shortfall is determined by subtracting the overall regulated carbon dioxide savings from the target savings. The result is then multiplied by the assumed lifetime of the development's services (e.g. 30 years) to give the cumulative shortfall. The cumulative shortfall is multiplied by the carbon dioxide off-set price to determine the required cash-in-lieu contribution, as shown below.

Carbon Dioxide Emissions – Regulated (Tonnes CO ₂ /yr)		
	(Tonnes CO ₂ /yr)	%
Savings from 'Be Lean-After energy demand reduction	0.07	2.2%
Savings from 'Be Clean-After CHP	0.00	0.0%
Savings from 'Be Green-After renewable energy	1.29	39.0%
Total Cumulative Savings	1.36	41.2%
Total Target Savings	1.16	35%
Annual Surplus	0.21	
	Annual Shortfall (Tonnes CO₂/yr)	Cumulative Shortfall (Tonnes CO₂)
Shortfall	-	-

Carbon offset contribution required: £0

Total Carbon Emissions:

As required by the GLA both the regulated and unregulated emissions of the development must be quantified and demonstrated. The total emissions for the scheme are shown below.

Carbon Dioxide Emissions – Regulated and Unregulated (Tonnes CO ₂ /yr)			
	Regulated Emissions	Unregulated Emissions	Total Emissions
Baseline: Part L 2013	3.31	1.53	4.83
Be Lean: After demand reduction	3.23	1.53	4.76
Be Clean: After CHP	-	-	-
Be Green: After Renewable energy	1.94	1.53	3.47

Introduction

Energy Assessment

Ellerdale Road

Aim of this study:

The purpose of an energy assessment is to demonstrate that climate change mitigation measures comply with London Plan energy policies, including the energy hierarchy. It also ensures energy remains an integral part of the development's design and evolution.

Methodology:

The methodology in this report follows the guidance set out by the Greater London Authority (GLA) for developing energy strategies as detailed in the document "ENERGY PLANNING: Greater London Authority guidance on preparing energy assessments (April 2014)"

This report has followed these documents and comprises the following components:

- **BASELINE:** A calculation of the Part L 2013 Building Regulations complaint CO₂ emission baseline using approved software. The baseline assumes a gas boiler would provide heating and any active cooling would be electrically powered.
- **LEAN:** A calculation of the impact of demand reduction measures. For example, passive design measures, including optimising orientation and site layout, natural ventilation and lighting, thermal mass and solar shading, and active design measures such as high efficacy lighting and efficient mechanical ventilation with heat recovery.
- **COOLING HIERARCHY:** in accordance with Policy 5.9 of London Plan, measures that are proposed to reduce the demand for cooling have been set out such as minimisation of solar and internal gains and night cooling strategies.
- **CLEAN:** in accordance with Policy 5.6 of London Plan, this report has demonstrated how the scheme has selected heating, cooling and power systems to minimise carbon emissions. This comprises an evaluation of the feasibility of connecting to existing low carbon heat networks, planned networks, site-wide and communal heat networks and CHP.
- **GREEN:** in accordance with Policy 5.7 of London Plan, this report has conducted a feasibility assessment of renewable energy technologies. This comprised a site-specific analysis of the technologies and if applicable how they would be integrated into the heating and cooling strategy for the scheme.

Please note that these findings are currently subject to a detailed analysis from a building services design engineer and qualified quantity surveyor.

Establishing Emissions: The Carbon Profile

Energy Assessment

Ellerdale Road

Building Regulations Part L 2013
Minimum Compliance:


The 'baseline' carbon emissions for the development are 3.31 Tonnes CO₂/yr.

The pie chart below provides a breakdown of the scheme's baseline carbon emissions by system over the course of one year.

Carbon Emissions in Tonnes
CO₂/yr

Heating	Hot Water	Cooling	Auxiliary	Lighting
2.38	0.57	0.00	0.04	0.32

Baseline CO₂ Breakdown



Overview:

The chart above shows that space heating is the primary source of carbon emissions, and domestic hot water is the second largest, across the scheme as a whole.

'Be Lean': Demand Reduction Measures Energy Assessment Ellerdale Road

Be Lean - Summary:

Demand reduction measures have reduced the scheme's carbon emissions by 2.2% over the minimum Part L 2013 Building Regulations baseline.

Site Layout

Passive Design measures:

The development is located at the rear of land at 1 Ellerdale Road and is protected by other developments on two sides. The compact shape of the dwelling means that the external area is minimised and consequently the heat losses through the building envelope are reduced. Windows (total glazing area is 33.3% of the external wall) are mainly facing south (29%) to exploit the passive solar heat gains and reduce the heating demand. However, there are few openings that are placed towards the north (4.3%) in order to enable cross ventilation, resulting in more effective air change rate and reducing the overheating risk.

Building Fabric

Passive Design measures:

Element	Minimum Building Regulations U value W/m ² K	Proposed U value W/m ² K
External Wall	0.30	0.18
Basement Wall	0.30	0.18
Ground Floor	0.25	0.11
Flat Roof	0.20	0.11
Glazing (window)	2.00	1.20
Glazing (rooflight)	2.00	1.20
Doors	2.00	1.20

Airtightness:

The target air permeability for the scheme has been modelled as 3 m³/(hr.m²) @ 50 pa.

This will require careful attention to two key areas:

- Structural leakage
- Services leakage

Structural leakage occurs at joints in the building fabric and around window and door openings, loft hatches and access openings. There will also be some diffusion through materials such as cracks in masonry walls typically this is caused by poor perpends in blockwork inner leafs. Structural leakage is hard to remedy retrospectively. Good detailing at the design stage is therefore essential.


Services leakage occurs at penetrations from pipes and cables entering the building. These can be sewerage pipes, water pipes and heating pipes. As well as electricity cables there may also be telecommunication cables. Attention therefore, needs to be paid to sealing all penetrations during construction.

Thermal Bridging:

The scheme has been indicatively modelled with the default thermal bridge y-values for all junction types, 0.15W/m²K.

Thermal Mass:

The thermal mass of the scheme has been indicatively modelled as 250 kJ/m²K (medium).




Graphic illustrations of the heat flow through a wall and how it is minimized with low u-value (consequence of the additional insulation).

'Be Lean': Demand Reduction Measures Energy Assessment Ellerdale Road

Energy Efficient Services

Active Design measures:



Graphic illustration of a heat recovery unit, which exploits the extract hot air of the room to heat the cold supply air.

Heating:

Heating will be provided by a gas boiler, featuring time and temperature zone control by suitable arrangement of plumbing and electrical services, delayed thermostat and a weather compensator. The heat will be distributed via radiators. The gas boiler will have a minimum efficiency of 89.5%.

Ventilation:

Balanced mechanical ventilation with heat recovery (90% efficiency) will be provided to dwellings and wet rooms with a specific fan power of 0.52 W/l/s.

Air Conditioning

Cooling will be provided to the principle four rooms by split systems, the systems will have an energy label class of A.

Lighting:

High efficient lighting has been specified for the development.


'Be Clean': Heating Infrastructure & CHP Energy Assessment Ellerdale Road

Heating Infrastructure including CHP:

Once demand for energy has been minimised, schemes must demonstrate how their energy systems have been selected in accordance with the order of preference in Policy 5.6B of London Plan. This has involved a systematic appraisal of the potential to connect to existing or planned heating networks and on site communal and CHP systems.

Heating Infrastructure:

The London Heat Map (shown below) has been consulted to establish the possibility of connecting to heating infrastructure.



Source: <http://www.londonheatmap.org.uk/Mapping>

'Be Clean': Connection to Existing and Planned Networks


Energy Assessment Ellerdale Road

Existing and Planned Networks:

Existing networks:

A review of the London Heat Map demonstrates that there are no existing networks present within connectable range of the scheme. A map of the existing and potential networks in the scheme's location is shown below.

- Existing DH Networks
- Potential DH Networks



There are no existing or potential networks within the vicinity of the scheme, therefore a connection is not possible.

'Be Clean': Site Wide Networks and CHP Energy Assessment Ellerdale Road

Site-wide Heat Networks:

In accordance with section 8.2 of the GLA guidance for Energy Planning, where it is demonstrable that a site wide network is not feasible then an individual heating strategy can be implemented. A site wide network will not be adopted because is only one dwelling and local conditions are not favourable to centralised distribution. Therefore, it is considered that distribution losses would be relatively large and the effectiveness and carbon reducing potential would be undermined when compared to an individual servicing strategy.

Combined Heat and Power (CHP)

In accordance with section 8.3 of the GLA guidance for Energy Planning where connection to an area wide heat network will not be available in the foreseeable future i.e. 5 years following completion, or the development is of such a scale that it could be the catalyst for an area wide heat network, applicants should evaluate the feasibility of on-site CHP

GLA guidance stipulates that small, or purely residential developments of less than 350 dwellings will not be expected to include on-site CHP. CHP systems are best utilised where there is a consistent and high demand for heat. Because of the small electricity supplies and demand of this scheme, a CHP installed to meet the base heat load would typically require the export of electricity to the grid. The administrative burden of managing CHP electricity sales at a small scale without an active energy service companies (ESCOs) is prohibitive for smaller operators of residential developments.

The heat demand profile of this residential scheme is not suitable to CHP. The implemented fabric improvements from the 'Be Lean' scenario have also reduced the energy demand from space heating to hot water. For CHP systems to be economically viable they need to run for at least 5,000 hours per year. Therefore, a CHP system would most likely be oversized, and as a result less efficient and economic.

'Be Clean': Cooling Energy Assessment Ellerdale Road

Policy 5.9 Overheating and Cooling:


The aim of this policy is to reduce the impact of the urban heat island effect in London and encourage the design of spaces to avoid overheating and excessive heat generation, and to mitigate overheating due to the impact of climate change.

Where design measures and the use of natural and/or mechanical ventilation are not enough to guarantee the occupant's comfort, in line with the cooling hierarchy the development's cooling strategy must include details of the active cooling plant being proposed, including efficiencies, and the ability to take advantage of free cooling and/or renewable cooling sources.


Where appropriate, the cooling strategy should investigate the opportunities to improve cooling efficiencies through the use of locally available sources such as ground cooling and river/dock water-cooling.

The Cooling Hierarchy:

Major developments should reduce potential overheating and reliance on air conditioning systems and demonstrate this with the Cooling Hierarchy:

- 
- 1) **Minimise internal heat generation through energy efficient design**
 - 2) **Reduce the amount of heat entering the building in summer (e.g. shading and fenestration)**
 - 3) **Manage the heat within the building through thermal mass, room height and green roofs**
 - 4) **Passive ventilation**
 - 5) **Mechanical ventilation**
 - 6) **Active cooling systems (ensuring the lowest carbon option)**

Avoiding Overheating Measures taken:



LED bulbs can emit 80% less heat compared to an incandescent bulb and their life span is up to 41 times more.

The following measures have been taken in accordance with the cooling hierarchy to reduce overheating and the need for cooling:

1) **Minimise internal heat generation through energy efficient design**

Internal heat gains have been minimised where possible. Energy Efficient appliances will help reduce internal heat gain and reduce the cooling requirement.

Energy efficient lighting will also be specified (>45 lumens per circuit watt). LED lighting will be specified and a lumen per circuit watt figure of 9W/m² will be targeted.

'Be Clean': Cooling Energy Assessment Ellerdale Road

Avoiding Overheating Measures taken:

2) Reduce the amount of heat entering the building in summer (e.g. shading and fenestration)

Direct solar gains will be controlled in the following ways:

- Solar control – all methods controlling solar gain to within tolerable limits have been considered. The location, size, design and type of window openings and glazing have been optimised, and reduced solar gain factors from low emissivity windows with a g-value of 0.55 have been specified.
- Dark-coloured curtain/roller blinds will be specified to limit solar gain. The shading has also been optimised to avoid substantially reducing daylighting or increasing the requirement for electric lighting.

Heat transfer and infiltration has been controlled in the following ways:

- Insulation levels have been maximised and the resulting u-values are lower than required by Building Regulations. The build-ups therefore prevent the penetration of heat as much as practically possible. See the 'Be Lean' section of this report for target u values.
- A reduced air permeability rate of $3 \text{ m}^3/(\text{hr.m}^2) @ 50 \text{ pa}$ has been targeted to minimise uncontrolled air infiltration. This will require attention to detailing and sealing. See 'Be Lean' section of this report for details of how this will be achieved.

3) Manage the heat within the building through thermal mass, room height and green roofs.

The following measures have been specified to manage heat accumulation within the building:


- High thermal mass – exposed building fabric materials such as masonry or concrete have been utilised in the form of concrete floors and dense masonry external walls. These materials act as 'thermal batteries'; they absorb heat gains during the day when the building is occupied and 'store' it for an extended period, thereby helping to stabilise daytime temperatures. At night this heat can be dissipated, which 'resets' the heating cycle. Ventilation will also be used at night to purge the stored heat within the structure. A 'ground coupled' system that uses the thermal storage capacity of the ground has not been specified as the passive ventilation option has been selected instead.



Examples of how the thermal mass absorbs heat during day and emits it during night.

'Be Clean': Cooling Energy Assessment Ellerdale Road

Avoiding Overheating Measures taken:



Typical building section demonstrating
passive cross ventilation.

- Room heights – high ceilings are traditionally used in hot climates to allow thermal stratification so that occupants can inhabit the lower cooler space, and to decrease the transfer of heat gain through the roof. The existing building has floor to ceiling heights of approximately 2.8m. As the roof will be well insulated to achieve a U-value of $0.11 \text{ W/m}^2\text{K}$, there will be minimal penetration of heat through the roof.
- Green roofs – a green roof has been specified for the scheme. This will act as an insulation barrier and the ecological processes will reduce the amount of solar energy absorbed by the roof membrane, so will reduce temperatures below the surface and cool the building areas directly below.


4) Passive ventilation

Ventilation that does not use fans or mechanical system has been specified to reduce the cooling load.

- Openable windows are specified on the two main external facades of the building. Cross ventilation will be achieved by opening windows on two facades and ensuring there is a clear path for airflow.

'Be Clean': Cooling Energy Assessment Ellerdale Road

Avoiding Overheating Measures taken:



Typical building section demonstrating a simple method of supply and extract ventilation system.

Overheating Risk:

5) Mechanical ventilation

Passive ventilation will not be adequate to cool the building to the required temperature. Mechanical ventilation will be utilised in the following forms:

- A mixed mode system will be implemented. This will be complimentary to the passive cooling measures taken. During summer months, mechanical ventilation using fans will circulate and remove hot air from the building. The building will also adopt a zoned design to allow natural ventilation where possible and mechanical ventilation where there are increased cooling loads.
- Fan powered ventilation: single point extracts will be used in WCs and kitchen. A whole building system will be specified which will use air handling units with separate supply and extract fans. Heat recovery units will also be specified to reduce energy demand, optimal performance will be achieved by the reduced air permeability rate of $3 \text{ m}^3/(\text{hr} \cdot \text{m}^2) @ 50 \text{ pa}$.
- The mechanical systems will have the following efficiencies which are in compliance with the Domestic Building Services Compliance Guide:
 - ✓ Specific fan power of 0.52 W/l/s for whole ventilation systems with heat recovery
 - ✓ Heat recovery efficiency of 90%

The overheating risk considering all the above strategies, described passive measures, has been assessed for the development and is presented in the table below:

Dwellings	Overheating risk according to SAP
1 Ellerdale Road	Slight

According to the GLA guidance on preparing energy assessments (April 2015), Section 11, a dynamic modelling to assess the risk of overheating should be carried out. However, due to the overheating results of SAP showing that there is no significant risk of overheating, it has been considered that a dynamic modelling is not required.

'Be Clean': Cooling Energy Assessment Ellerdale Road

Efficiency Measures taken:

6) Active cooling systems (ensuring the lowest carbon option)

Passive design measures and the use of natural and mechanical ventilation result in slightly overheating risk. In order to guarantee the occupant's comfort, an air conditioning system has been specified for. Following the methodology of the cooling hierarchy has progressively reduced the demand for cooling.

The monthly cooling requirements of the dwelling are presented in the table below.

Dwellings	Monthly Cooling Requirement (kWh/m ² /year)			
	June	July	August	Annual
1 Ellerdale Road	0.74	0.93	0.73	2.39

To ensure the cooling system is the most carbon efficient possible the following parameters have been selected:

- Location: Indoor cooling units have been specified on a localised basis where internal gains are too high. The units will be fully fitted with local temperature controls for optimal usage.
- The location of the outdoor units that 'dump' the heat has been carefully considered so not to cause problems for people and the environment, and not to add to the urban heat island effect. They will be located on the roof space and will allow adequate air movement around the condensing units, this will ensure maximum operating efficiency and will limit the impacts of dumped heat on people and the environment.
- The AC systems will have the following efficiencies which are in compliance with the Domestic Building Services Compliance Guide:
 - ✓ Energy label class of A.

'Be Green': Renewable Energy

Energy Assessment

Ellerdale Road

Renewable Energy Feasibility:

In line with Policy 5.7 of the London Plan the feasibility of renewable energy technologies has been considered. A detailed site-specific analysis and associated carbon saving calculations have also been provided for renewable energy technologies for the feasible options.

Renewable Energy Technology Comparison:

Each technology has been assessed under 5 broader categories. There are key criteria for each category on which the technology is evaluated. The key criteria have been given a weighting based on a tick-system, a graphical representation of this is shown below:

✓ ✓ ✓ ✓ ✓ = 1 scored out of a possible 5

The weighting of each of the criteria within the categories is shown below:

- **Local, site-specific impact:** (Maximum score of 4)
 - o Local planning criteria = ✓ ✓
 - o Land used by all components = ✓
 - o Noise impact from operation = ✓
- **Suitability and design impact:** (Maximum score of 4)
 - o Interaction on the current building design = ✓ ✓
 - o Building orientation suitability = ✓
 - o Buildability of installation = ✓
- **Economic viability:** (Maximum score of 5)
 - o Capital cost of all components = ✓ ✓
 - o Grants and funding available = ✓
 - o Payback periods (years) 3-5, 5-10, 10-15 = ✓ ✓ ✓
- **Operation and maintenance:** (Maximum score of 3)
 - o Servicing requirements (low or high) = ✓
 - o Maintenance costs (low or high) = ✓
 - o Resource use from future maintenance (low or high) = ✓
- **CO₂ and sustainability:** (Maximum score of 10)
 - o Carbon saving per year = ✓ ✓ ✓ ✓
 - o Impact of future grid decarbonisation (gas vs. electric) = ✓ ✓
 - o Local air quality/pollution = ✓ ✓
 - o Resource use of installation = ✓ ✓

Key comments on each of the criteria and the corresponding score will be provided in a table (example below) for each of the technologies. The score for each of the criteria will be summed and each of the technologies will then be ranked. The assessment of each technology is undertaken on the following pages.

Renewable Technology	Local, site-specific impact	Suitability and design impact	Economic viability	Operation and maintenance	CO ₂ and sustainability
	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓ ✓	✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓

'Be Green': Renewable Energy

Energy Assessment

Ellerdale Road

Biomass & Biofuel:

Rejected



Biomass is normally considered a carbon 'neutral' fuel, as the carbon dioxide emitted on burning has been recently absorbed from the atmosphere by photosynthesis. Although some form of fossil fuel derived inputs are required in the production and transportation of the fuel.

Wood is seen as a by-product of other industries and the small quantity of energy for drying, sawing, pelleting and delivery are typically discounted. Biomass from coppicing is likely to have external energy inputs from fertiliser, cutting, drying etc. and these may need to be considered. In this toolkit, all biomass fuels are considered to have zero net carbon emissions.

Biomass can be burnt directly to provide heat in buildings. Wood from forests, urban tree pruning, farmed coppices or farm and factory waste, is the most common fuel and is used commercially in the form of wood chips or pellets. Biomass boilers can also be designed to burn smokeless to comply with the Clean Air Acts.

Boilers can be fed automatically by screw drives from fuel hoppers. This typically involves daily addition of bagged fuels.

A biomass boiler could be installed on site for supplementary LTHW heating; however, a major factor influencing the suitability of a biomass boiler is the availability of the biomass fuel. A local and reliable fuel source would be essential for the biomass boiler to be an efficient replacement for a conventional boiler system. Therefore, a very comprehensive feasibility assessment needs to be undertaken to understand the practicalities of such a system.

It is estimated that the heating and hot water demand of the site is too small to meet the required CO₂ emissions reduction if a biomass boiler was a standalone system. Therefore a biomass boiler would need to be combined with energy demand reduction measures and/or CHP. In order to meet the 35% CO₂ emissions reduction a biomass boiler would need to be installed. The likely installed cost would be circa £15,000. The additional cost of providing and storing the bio-fuel also needs to be accounted for. The site is likely to be unsuitable for biomass boilers due to site constraints such as limited transport/access issues, and storage of the biomass fuel. A detailed feasibility study will be required to investigate the suitability.

Renewable Technology	Local, site-specific impact	Suitability and design impact	Economic viability	Operation and maintenance	CO ₂ and sustainability
Biomass Boiler	<p>✓ ✗ ✗ ✗</p> <p>Local air quality impacts, increased transport usage on the restricted site, increased plant space.</p>	<p>✓ ✓ ✓ ✗</p> <p>Increase in plant space required, orientation fine, slightly increased buildability issues.</p>	<p>✓ ✓ ✓ ✗ ✗</p> <p>Increased capital costs of installation, typical payback of 8 years</p>	<p>✓ ✗ ✗</p> <p>Increased maintenance relative to gas boiler, resource use not significantly increased if well serviced.</p>	<p>✓ ✓ ✓ ✓ ✓ ✓ ✓ ✗ ✗ ✗</p> <p>Very low carbon intensity of feedstock if properly procured. Decarbonisation impact not applicable, air quality issues.</p>

'Be Green': Renewable Energy Energy Assessment Ellerdale Road

Photovoltaic (PV):

Accepted



Photovoltaic systems convert energy from the sun into electricity through semi conductor cells. Systems consist of semi-conductor cells connected together and mounted into modules. Modules are connected to an inverter to turn the direct current (DC) output into alternating current (AC) electricity for use in buildings.

Photovoltaic systems can be discreet through being designed as an integral part of the roof. An 'invisible' design using slates or shingles as opposed to an architectural statement could be preferable in a sensitive area.

Photovoltaics supply electricity to the building and are attached to electricity grid or to any other electrical load. Excess electricity can be sold to the National Grid when the generated power exceeds the local need. PV systems require only daylight, not sunlight to generate electricity (although more electricity is produced with more sunlight), so energy can still be produced in overcast or cloudy conditions.

The cost of PV cells is heavily dependent on the size of the array. There are significant cost reductions available for larger installations.

The most suitable location for mounting photovoltaic panels is on roofs as they usually have the greatest exposure to the sun. The proposed site has a potential useable roof area of approximately 65 m² and is orientated southwest.

Renewable Technology	Local, site-specific impact	Suitability and design impact	Economic viability	Operation and maintenance	CO ₂ and sustainability
Photovoltaic	<p>✓✓✓✓</p> <p>No local air quality impacts, use of unutilised roof space, conservation officer has concerns for part of the site, no noise issues.</p>	<p>✓✓✓✓</p> <p>Can be added to the roof, good orientation, and slightly increased buildability issues for wiring and metering.</p>	<p>✓✓✓✓</p> <p>Increased capital costs of installation, typical payback of 8 years, Feed in Tariff available.</p>	<p>✓✓✓</p> <p>Limited servicing and maintenance i.e. 1 visit per year, inverter will require replacement.</p>	<p>✓✓✓✓✓</p> <p>High carbon saving from electricity, uses minimal grid electricity, no local air impact, high embodied energy of panels.</p>

'Be Green': Renewable Energy

Energy Assessment

Ellerdale Road

Solar Thermal:

Rejected



Solar water heating systems use the energy from the sun to heat water for domestic hot water needs. The systems use a heat collector, generally mounted on the roof in which a fluid is heated by the sun. This fluid is used to heat up water that is stored in either a separate hot water cylinder or a twin coil hot water cylinder inside the building. The systems work very successfully in all parts of the UK, as they can work in diffuse light conditions.

Like photovoltaic panels the most suitable location for mounting solar hot water panels is on roofs as they usually have the greatest exposure to the sun. The proposed site has a potential useable roof area of approximately 65 m² and is orientated southwest.

It is estimated that the CO₂ emissions reduction that would be produced by solar hot water as a standalone system would not be adequate to achieve the required CO₂ emissions reduction target. Therefore a solar hot water system would need to be combined with more energy efficiency strategies, a CHP or additional renewable technologies to achieve the carbon reduction target.

Renewable Technology	Local, site-specific impact	Suitability and design impact	Economic viability	Operation and maintenance	CO ₂ and sustainability
Solar Thermal	<p>✓✓✓✓</p> <p>No local air quality impacts, use of unutilised roof space, conservation officer has concerns for part of the site, no noise issues.</p>	<p>✓✓✓✓</p> <p>Can be added to the roof, good orientation, and slightly increased buildability issues for piping and cylinders.</p>	<p>✓✓✓✓</p> <p>Increased capital costs of installation, typical payback of 8 years, Renewable Heat Incentive available.</p>	<p>✓✓✓</p> <p>Limited servicing and maintenance i.e. 1 visit every two years, heat transfer fluid requires replacing every 10 years.</p>	<p>✓✓✓✓✓</p> <p>Lower carbon saving as primarily displacing gas, uses minimal grid electricity, no local air impact, medium embodied energy of panels.</p>

'Be Green': Renewable Energy

Energy Assessment

Ellerdale Road

Wind Energy:

Rejected



Wind energy is a cost effective method of renewable power generation. Wind turbines can produce electricity without carbon dioxide emissions in ranges from watts to megawatt outputs. The most common design is for three blades mounted on a horizontal axis, which is free to rotate into the wind on a tall tower.

The blades drive a generator either directly or via a gearbox to produce electricity. The electricity can either be linked to the grid or charge batteries. An inverter is required to convert the electricity from direct current (DC) to alternating current (AC) for feeding into the grid.

Modern quiet wind turbines are becoming viable in low density areas where ease of maintenance and immediate connection to the grid or direct use of the electricity in a building, may make them cost effective, despite lower wind speeds than open areas.

Wind turbines are generally less suited to dense urban areas as their output will be affected by potentially lower and more disrupted wind speeds, and their use of much more cost effective machines may be prohibited by their proximity to some building types. Small turbines can be used in inner city areas mounted on buildings, although there are relatively few installations.

Typically a 1.5 kW turbine can provide 4,000 kWh of electrical power annually. To achieve the required CO₂ emissions reduction target approximately 1 turbines would be required as a standalone solution. The indicative cost of a smaller roof mounted turbine is £2,000/kW so achieving the required CO₂ emissions reduction would cost approximately £3,000.

A detailed wind resource evaluation would be required for the site to fully understand the generation potential and payback period. Also, it is likely that planning restrictions and resistance from small groups within the local community could also affect the viability of wind energy for the project.

Renewable Technology	Local, site-specific impact	Suitability and design impact	Economic viability	Operation and maintenance	CO ₂ and sustainability
Wind Energy	<p>✓ ✓ ✓ ✓</p> <p>No local air quality impacts, use of unutilised roof space, conservation officer will have concerns for the site, minor noise issues.</p>	<p>✓ ✓ ✓ ✓</p> <p>Can be added to the roof, relatively limited wind speeds in local area, increased buildability issues for wiring and metering.</p>	<p>✓ ✓ ✓ ✓ ✓</p> <p>Medium capital costs of installation, typical payback < 5 years, Feed in Tariff available.</p>	<p>✓ ✓ ✓</p> <p>Very limited servicing and maintenance, costs of 2-3% typical.</p>	<p>✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓</p> <p>High carbon saving from electricity, output limited from urban installation, consumes little grid electricity, no local air impact, low embodied energy of panels.</p>


'Be Green': Renewable Energy

Energy Assessment

Ellerdale Road

Ground Source Heat Pump (GSHP):

Rejected



Geo-thermal energy is essentially heat collected from the ground. Heat obtained from the ground may be considered it as a source of heating and cooling within the UK by the use of a geo-thermal heat pump or ground source heat pumps.

A ground source heat pump is a device for converting energy in the form of low level heat to heat at a usable temperature. The heat pump consists of five main parts; ground collector loop/or bores, heat exchanger, compressor, condenser heat exchanger and expansion valve.

At approximately 1.2-1.5 metres down below ground level the temperature is a constant 10 to 12°C. Any bores would need to be sunk to an effective depth of 50 – 120m and a ground feasibility report would be required to ascertain if this method of heat source was viable.

From the bores pre-insulated pipework is laid in the ground to the heat exchanger device. The system is filled with water and antifreeze. The cooled water is pumped around the loop / bore gathering energy as it circulates. The water that has been heated to 10-12°C is returned to the ground source heat exchanger where the energy is transferred to the refrigerant gas. For every 1kW of energy used to compress the refrigerant, the process 'gives up' 4 kW of energy for use in the system being used to heat the building.

Typical costs for an installation this are in the region of £16,000-20,000 for a smaller commercial or domestic size installation, with general installation costs at £1200 /kW of energy produced.

Renewable Technology	Local, site-specific impact	Suitability and design impact	Economic viability	Operation and maintenance	CO ₂ and sustainability
GSHP	<p>✓✓✓✓</p> <p>No local air quality impacts, not visible so conservation friendly, no noise issues, however the constrained site may prohibit its installation.</p>	<p>✓✓✓✓</p> <p>Can be added to the roof, good air-flow on roof, increased buildability issues for pipework and heating emitters internally.</p>	<p>✓✓✓✓✓</p> <p>High capital costs of installation, typical payback of 15 years where gas is displaced, Renewable Heat Incentive available.</p>	<p>✓✓✓</p> <p>Limited servicing and maintenance i.e. 1 visit per year, mechanical parts may require replacement over lifespan.</p>	<p>✓✓✓✓✓ ✓✓✓✓✓</p> <p>Limited carbon saving from gas displacement, consumes some electricity so benefits from decarbonisation, no local air impact, high embodied energy of equipment.</p>


'Be Green': Renewable Energy

Energy Assessment

Ellerdale Road

Air Source Heat Pump (ASHP):

Rejected



Air source heat pump systems work on the same principle as a ground source heat pump although they use the outside air as the heat source.

The coefficients of performance given by air source heat pump systems are inferior to that of ground source systems due to varying air temperatures. In the depth of winter the energy efficiency of an air source system will be lower than that of a ground source system, and it is likely that more back-up heat will be required if an air source unit is fitted. This back-up heat often comes from a direct electric heater. They operate over a varying temperatures range of -15°C to +25°C, however, the performance will reduce to below the required 3 to 1 carbon saving ratio in winter, and the also require a defrosting mechanism to melt ice that forms on the air heat exchanger.

ASHPs are cheaper to install than ground source heat pumps but are only available on a relatively small scale. If applied across a larger site a number of plant zones would be required for generation of heat, leading to increased plant space requirements. Typical costs for an installation this are in the region of £10,000 for a smaller commercial or domestic size installation.

Carbon dioxide emissions savings will typically be less than that of the ground source heat pump. Air source heat pumps may be more suitable as an HVAC solution.

Renewable Technology	Local, site-specific impact	Suitability and design impact	Economic viability	Operation and maintenance	CO ₂ and sustainability
ASHP	<p>✓✓✓✓</p> <p>No local air quality impacts, conservation officer may have minor concerns over visual impact, no noise issues.</p>	<p>✓✓✓✓</p> <p>Can be added to the roof, good air-flow on roof, increased buildability issues for pipework and heating emitters internally.</p>	<p>✓✓✓✓✓</p> <p>Medium- high capital costs of installation, typical payback >15 years where gas is displaced, Renewable Heat Incentive available.</p>	<p>✓✓✓</p> <p>Limited servicing and maintenance i.e. 1 visit per year, mechanical parts may require replacement over lifespan.</p>	<p>✓✓✓✓✓</p> <p>Limited carbon saving from gas displacement, less efficient in winter, consumes electricity so benefits from decarbonisation, no local air impact, high embodied energy of equipment.</p>

'Be Green': Summary of Renewable Technologies Energy Assessment

Ellerdale Road

Summary Comparison Matrix:

An assessment of the feasibility of each of the technologies is shown below.

Renewable Technology	Local, site-specific impact	Suitability and design impact	Economic viability	Operation and maintenance	CO ₂ and sustainability	Total Score
Biomass Boiler	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓	✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓	15 out of 26
Photovoltaic	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓	✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓	17 out of 26
Solar Thermal	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓	✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓	16 out of 26
Wind Energy	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓	✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓	17 out of 26
GSHP	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓	✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓	15 out of 26
ASHP	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓	✓ ✓ ✓	✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓ ✓	15 out of 26

Renewable Technology Conclusion & Specification:

Photovoltaic panels and wind energy have scored the best. It is assumed that wind energy would be considered unsuitable for the area by conservation criteria and that the local residents would raise concerns over potential noise and turbulence. Therefore, photovoltaic panels have been considered to be the optimum balance of sustainable and economic objectives.


'Be Green': Photovoltaic Energy Assessment Ellerdale Road

Summary:

A photovoltaic panel system of 3.27 kWp has been specified (approximately 10 high efficient photovoltaic panels) for the development and detailed summary of the lifecycle cost, revenue and payback for the photovoltaic panels is presented in this section.

Location:

The following drawing shows that there are 65m² of available roof that could be used to install photovoltaic modules and lack of shading. PV panels will be oriented southwest, placed horizontal, covering 16m² of the roof.



'Be Green': Photovoltaic Energy Assessment Ellerdale Road


Shading Analysis:

The shading analysis shows that there is none or very little over shading on the roof of the proposed development as the percentage of sky blocked by obstacles is 18.2%.


BRE Sunpath Indicator

Location: 51.4°, 0.0°
Obj 257 Orientation: 140.2°, 90.0°
Sun Position: -175.6°, 25.3°
HSA: 44.2°
VSA: 33.4°


Time: 12:00
Date: 29th Oct (302)
Equal-Area Sky Subdivisions: 81.6%




Overcast Sky Factor: 97.3%
Uniform Sky Factor: 95.4%



December



March



June

'Be Green': Photovoltaic Energy Assessment Ellerdale Road

Lifecycle Cost:

The lifecycle of the proposed high efficiency panels is 25 years. To calculate the lifecycle cost of the panels, the maintenance of the system and replacement cost will be included.

The total costs for the proposed system's lifetime is:

- Capital Cost = £6,540
- Maintenance Cost = £1,500
- Operation Cost = £900 (replacement inverters etc.)
- Total Costs = £7,600

Revenue and Payback Parameters:

- The cost of electricity to be displaced is 12p/kWh.
- The 3.27kWp system is estimated to generate 2,487 kWh/yr. Based on the assumption that 50% of the electricity will be used on site, an offset saving of £149/yr will be achieved.
- With the current Feed in Tariff, a tariff of 14.77p/kWh will be received for generation, and 4.77p/kWh will be received for export, which gives an additional saving of £427 per year.

Summary Performance Calculations:

The following tables summarise the reduction in carbon emissions and the life cycle cost of the photovoltaic system.

Energy and Carbon Performance Criteria		Value
Predicted Annual Energy Saved (kWh/yr)		2,487
Annual Carbon Emissions Reductions (kg CO ₂ /year)		1,291
CO ₂ Emissions Reduction (%)		39.0
Cost Performance Criteria		Value
Total Cost Over Life Cycle (£)		8,940
Predicted Annual Savings (£)		576
Payback Period (years)		15.5

Conclusion

Energy Assessment

Ellerdale Road

Summary

The baseline carbon emissions for the scheme are 3.31 Tonnes CO₂/yr.

As demonstrated, the development will reduce carbon emissions by 2.2% from the fabric energy efficiency measures described in the "Be Lean" section, and will reduce total carbon emissions by 41.2% over Building Regulations with the further inclusion of low and zero carbon technologies.

GLA's Energy Hierarchy – Regulated Carbon Emissions

	Baseline:	Be Lean:	Be Clean:	Be Green:
CO ₂ emissions (Tonnes CO ₂ /yr)	3.31	3.23	-	1.94
CO ₂ emissions saving (Tonnes CO ₂ /yr)	-	0.07	-	1.29
Saving from each stage (%)	-	2.2	-	39.0
Total CO ₂ emissions saving (Tonnes CO ₂ /yr)	1.36			

41.2% Total carbon emissions savings over Part L of the Building Regulations 2013 achieved

Appendix

Energy Assessment

Ellerdale Road

Further Information:

As required by the GLA, the emission figures and details of the calculations and methodology used to determine the figures provided within the report can be found in the following pages:

Baseline – TER from the Lean SAP TER Worksheets.
Lean – DER from the Lean SAP DER Worksheets.
Clean – There in no CHP scenario.
Green – DER from the Green SAP DER Worksheets.

Appendix

Energy Assessment

Ellerdale Road

Baseline Scenario

TER WorkSheet: New dwelling design stage

User Details:

Assessor Name:

Stroma Number:

Software Name: Stroma FSAP 2012

Software Version:

Version: 1.0.1.25

Property Address: House 1-LEAN

Address : 1 Ellerdale Road

1. Overall dwelling dimensions:

	Area(m ²)		Av. Height(m)		Volume(m ³)
Basement	67 (1a)	x	2.65 (2a)	=	177.55 (3a)
Ground floor	67 (1b)	x	3 (2b)	=	201 (3b)
First floor	87.44 (1c)	x	3 (2c)	=	262.32 (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+.....(1n)	221.44 (4)				
Dwelling volume				(3a)+(3b)+(3c)+(3d)+(3e)+.....(3n) =	640.87 (5)

2. Ventilation rate:

	main heating	secondary heating	other	total		m ³ per hour
Number of chimneys	0	+	0	+	0	x 40 = 0 (6a)
Number of open flues	0	+	0	+	0	x 20 = 0 (6b)
Number of intermittent fans				4	x 10 =	40 (7a)
Number of passive vents				0	x 10 =	0 (7b)
Number of flueless gas fires				0	x 40 =	0 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =				40	÷ (5) =	0.06 (8)
If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)						
Number of storeys in the dwelling (ns)						0 (9)
Additional infiltration					[(9)-1]x0.1 =	0 (10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction						0 (11)
if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35						
If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0						0 (12)
If no draught lobby, enter 0.05, else enter 0						0 (13)
Percentage of windows and doors draught stripped						0 (14)
Window infiltration				0.25 - [0.2 x (14) ÷ 100] =		0 (15)
Infiltration rate				(8) + (10) + (11) + (12) + (13) + (15) =		0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area						5 (17)
If based on air permeability value, then (18) = [(17) ÷ 20] + (8), otherwise (18) = (16)						0.31 (18)
Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used						
Number of sides sheltered						2 (19)
Shelter factor				(20) = 1 - [0.075 x (19)] =		0.85 (20)
Infiltration rate incorporating shelter factor				(21) = (18) x (20) =		0.27 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

TER WorkSheet: New dwelling design stage

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

	0.34	0.33	0.33	0.29	0.29	0.25	0.25	0.25	0.27	0.29	0.3	0.31
--	------	------	------	------	------	------	------	------	------	------	-----	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) × Fmv (equation (N5)) , otherwise (23b) = (23a)

0 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

0 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) × [1 – (23c) ÷ 100]

(24a)m= 0 0 0 0 0 0 0 0 0 0 0 0 0 (24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m= 0 0 0 0 0 0 0 0 0 0 0 0 0 (24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 × (23b), then (24c) = (23b); otherwise (24c) = (22b) m + 0.5 × (23b)

(24c)m= 0 0 0 0 0 0 0 0 0 0 0 0 0 (24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m= 0.56 0.56 0.55 0.54 0.54 0.53 0.53 0.53 0.54 0.54 0.54 0.55 (24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m= 0.56 0.56 0.55 0.54 0.54 0.53 0.53 0.53 0.54 0.54 0.54 0.55 (25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m²)	Openings m²	Net Area A ,m²	U-value W/m²K	A X U (W/K)	k-value kJ/m²·K	A X k kJ/K
Doors			1.76	x 1	= 1.76		(26)
Windows Type 1			0.65	x1/[1/(1.4)+0.04] =	0.86		(27)
Windows Type 2			4.82	x1/[1/(1.4)+0.04] =	6.39		(27)
Windows Type 3			7.7	x1/[1/(1.4)+0.04] =	10.21		(27)
Windows Type 4			8.78	x1/[1/(1.4)+0.04] =	11.64		(27)
Windows Type 5			4.17	x1/[1/(1.4)+0.04] =	5.53		(27)
Windows Type 6			4.5	x1/[1/(1.4)+0.04] =	5.97		(27)
Rooflights Type 1			2.275815	x1/[1/(1.7)+0.04] =	3.868886		(27b)
Rooflights Type 2			2.275815	x1/[1/(1.7)+0.04] =	3.868886		(27b)
Rooflights Type 3			3.286277	x1/[1/(1.7)+0.04] =	5.586671		(27b)
Floor			87.44	x 0.13	= 11.3672		(28)
Walls Type1	176.88	0	176.88	x 0.18	= 31.84		(29)
Walls Type2	139.89	44.25	95.64	x 0.18	= 17.22		(29)
Roof	87.44	11.12	76.32	x 0.13	= 9.92		(30)
Total area of elements, m²			491.65				(31)
Party wall			12.41	x 0	= 0		(32)

* for windows and roof windows, use effective window U-value calculated using formula 1/[(1/U-value)+0.04] as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26) (30) + (32) = 146.14 (33)

TER WorkSheet: New dwelling design stage

Heat capacity $C_m = S(A \times k)$

((28) (30) + (32) + (32a) (32e) = 64317.84 (34)

Thermal mass parameter (TMP = $C_m \div TFA$) in $\text{kJ/m}^2\text{K}$

Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : $S(L \times Y)$ calculated using Appendix K

24.58 (36)

if details of thermal bridging are not known (36) = $0.15 \times (31)$

Total fabric heat loss

(33) + (36) = 170.72 (37)

Ventilation heat loss calculated monthly

(38)m = $0.33 \times (25)\text{m} \times (5)$

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	117.87	117.39	116.93	114.77	114.36	112.47	112.47	112.12	113.2	114.36	115.18	116.04	(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

(39)m=	288.59	288.12	287.66	285.49	285.08	283.2	283.2	282.85	283.92	285.08	285.9	286.76	
Average = Sum(39) ₁₋₁₂ / 12 =												285.49	(39)

Heat loss parameter (HLP), W/m^2K

(40)m = (39)m \div (4)

(40)m=	1.3	1.3	1.3	1.29	1.29	1.28	1.28	1.28	1.28	1.29	1.29	1.29	
Average = Sum(40) ₁₋₁₂ / 12 =												1.29	(40)

Number of days in month (Table 1a)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31	(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

if $TFA > 13.9$, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (TFA - 13.9)^2)] + 0.0013 \times (TFA - 13.9)$

if $TFA \leq 13.9$, $N = 1$

3.03 (42)

Annual average hot water usage in litres per day $V_{d,average} = (25 \times N) + 36$

106.16 (43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Hot water usage in litres per day for each month $V_{d,m}$ = factor from Table 1c x (43)													
(44)m=	116.77	112.53	108.28	104.03	99.79	95.54	95.54	99.79	104.03	108.28	112.53	116.77	
Total = Sum(44) ₁₋₁₂ =												1273.89	(44)

Energy content of hot water used - calculated monthly = $4.190 \times V_{d,m} \times n_m \times DT_m / 3600$ kWh/month (see Tables 1b, 1c, 1d)

(45)m=	173.17	151.46	156.29	136.26	130.74	112.82	104.55	119.97	121.4	141.48	154.44	167.71	
Total = Sum(45) ₁₋₁₂ =												1670.28	(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

(46)m=	25.98	22.72	23.44	20.44	19.61	16.92	15.68	18	18.21	21.22	23.17	25.16	(46)
--------	-------	-------	-------	-------	-------	-------	-------	----	-------	-------	-------	-------	------

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0 (47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0 (48)

Temperature factor from Table 2b

0 (49)

Energy lost from water storage, kWh/year

(48) x (49) = 0 (50)

b) If manufacturer's declared cylinder loss factor is not known:

TER WorkSheet: New dwelling design stage

Hot water storage loss factor from Table 2 (kWh/litre/day) 0 (51)

If community heating see section 4.3

Volume factor from Table 2a 0 (52)

Temperature factor from Table 2b 0 (53)

Energy lost from water storage, kWh/year (47) × (51) × (52) × (53) = 0 (54)

Enter (50) or (54) in (55) 0 (55)

Water storage loss calculated for each month ((56)m = (55) × (41)m

(56)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (56)

If cylinder contains dedicated solar storage, (57)m = (56)m × [(50) – (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H

(57)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (57)

Primary circuit loss (annual) from Table 3 0 (58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (59)

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m

(61)m=

50.96	46.03	50.96	49.32	50.85	47.12	48.69	50.85	49.32	50.96	49.32	50.96
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (61)

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m=

224.13	197.48	207.25	185.57	181.59	159.94	153.23	170.82	170.71	192.44	203.75	218.67
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (62)

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 (63)

Output from water heater

(64)m=

224.13	197.48	207.25	185.57	181.59	159.94	153.23	170.82	170.71	192.44	203.75	218.67
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (64)

Output from water heater (annual)_{1 12} 2265.59 (64)

Heat gains from water heating, kWh/month $0.25 \times [0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=

70.32	61.87	64.71	57.63	56.18	49.29	46.93	52.6	52.69	59.78	63.68	68.5
-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

 (65)

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

(66)m=

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49

 (66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=

34.86	30.96	25.18	19.06	14.25	12.03	13	16.9	22.68	28.79	33.61	35.83
-------	-------	-------	-------	-------	-------	----	------	-------	-------	-------	-------

 (67)

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=

390.99	395.05	384.83	363.06	335.58	309.76	292.51	288.45	298.68	320.44	347.92	373.74
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 (68)

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=

38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

 (69)

Pumps and fans gains (Table 5a)

(70)m=

3	3	3	3	3	3	3	3	3	3	3	3
---	---	---	---	---	---	---	---	---	---	---	---

 (70)

Losses e.g. evaporation (negative values) (Table 5)

(71)m=

-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

 (71)

Water heating gains (Table 5)

(72)m=

94.52	92.06	86.97	80.05	75.52	68.46	63.08	70.7	73.19	80.35	88.44	92.07
-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------

 (72)

TER WorkSheet: New dwelling design stage

Total internal gains =

(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m= 591.81 589.52 568.42 533.62 496.8 461.7 440.04 447.49 465.99 501.03 541.41 573.09 (73)

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d		Area m ²		Flux Table 6a		g_ Table 6b		FF Table 6c		Gains (W)	
Southeast 0.9x	0.77	x	7.7	x	36.79	x	0.63	x	0.7	=	173.17	(77)
Southeast 0.9x	0.77	x	8.78	x	36.79	x	0.63	x	0.7	=	98.73	(77)
Southeast 0.9x	0.77	x	7.7	x	62.67	x	0.63	x	0.7	=	294.97	(77)
Southeast 0.9x	0.77	x	8.78	x	62.67	x	0.63	x	0.7	=	168.17	(77)
Southeast 0.9x	0.77	x	7.7	x	85.75	x	0.63	x	0.7	=	403.59	(77)
Southeast 0.9x	0.77	x	8.78	x	85.75	x	0.63	x	0.7	=	230.1	(77)
Southeast 0.9x	0.77	x	7.7	x	106.25	x	0.63	x	0.7	=	500.07	(77)
Southeast 0.9x	0.77	x	8.78	x	106.25	x	0.63	x	0.7	=	285.1	(77)
Southeast 0.9x	0.77	x	7.7	x	119.01	x	0.63	x	0.7	=	560.12	(77)
Southeast 0.9x	0.77	x	8.78	x	119.01	x	0.63	x	0.7	=	319.34	(77)
Southeast 0.9x	0.77	x	7.7	x	118.15	x	0.63	x	0.7	=	556.07	(77)
Southeast 0.9x	0.77	x	8.78	x	118.15	x	0.63	x	0.7	=	317.03	(77)
Southeast 0.9x	0.77	x	7.7	x	113.91	x	0.63	x	0.7	=	536.11	(77)
Southeast 0.9x	0.77	x	8.78	x	113.91	x	0.63	x	0.7	=	305.65	(77)
Southeast 0.9x	0.77	x	7.7	x	104.39	x	0.63	x	0.7	=	491.31	(77)
Southeast 0.9x	0.77	x	8.78	x	104.39	x	0.63	x	0.7	=	280.11	(77)
Southeast 0.9x	0.77	x	7.7	x	92.85	x	0.63	x	0.7	=	437	(77)
Southeast 0.9x	0.77	x	8.78	x	92.85	x	0.63	x	0.7	=	249.15	(77)
Southeast 0.9x	0.77	x	7.7	x	69.27	x	0.63	x	0.7	=	326	(77)
Southeast 0.9x	0.77	x	8.78	x	69.27	x	0.63	x	0.7	=	185.86	(77)
Southeast 0.9x	0.77	x	7.7	x	44.07	x	0.63	x	0.7	=	207.42	(77)
Southeast 0.9x	0.77	x	8.78	x	44.07	x	0.63	x	0.7	=	118.25	(77)
Southeast 0.9x	0.77	x	7.7	x	31.49	x	0.63	x	0.7	=	148.2	(77)
Southeast 0.9x	0.77	x	8.78	x	31.49	x	0.63	x	0.7	=	84.49	(77)
Southwest 0.9x	0.77	x	4.17	x	36.79		0.63	x	0.7	=	93.78	(79)
Southwest 0.9x	0.77	x	4.5	x	36.79		0.63	x	0.7	=	50.6	(79)
Southwest 0.9x	0.77	x	4.17	x	62.67		0.63	x	0.7	=	159.74	(79)
Southwest 0.9x	0.77	x	4.5	x	62.67		0.63	x	0.7	=	86.19	(79)
Southwest 0.9x	0.77	x	4.17	x	85.75		0.63	x	0.7	=	218.57	(79)
Southwest 0.9x	0.77	x	4.5	x	85.75		0.63	x	0.7	=	117.93	(79)
Southwest 0.9x	0.77	x	4.17	x	106.25		0.63	x	0.7	=	270.82	(79)
Southwest 0.9x	0.77	x	4.5	x	106.25		0.63	x	0.7	=	146.12	(79)
Southwest 0.9x	0.77	x	4.17	x	119.01		0.63	x	0.7	=	303.34	(79)
Southwest 0.9x	0.77	x	4.5	x	119.01		0.63	x	0.7	=	163.67	(79)

TER WorkSheet: New dwelling design stage

Southwest	0.9x	0.77	x	4.17	x	118.15	0.63	x	0.7	=	301.14	(79)	
Southwest	0.9x	0.77	x	4.5	x	118.15	0.63	x	0.7	=	162.49	(79)	
Southwest	0.9x	0.77	x	4.17	x	113.91	0.63	x	0.7	=	290.33	(79)	
Southwest	0.9x	0.77	x	4.5	x	113.91	0.63	x	0.7	=	156.65	(79)	
Southwest	0.9x	0.77	x	4.17	x	104.39	0.63	x	0.7	=	266.07	(79)	
Southwest	0.9x	0.77	x	4.5	x	104.39	0.63	x	0.7	=	143.56	(79)	
Southwest	0.9x	0.77	x	4.17	x	92.85	0.63	x	0.7	=	236.66	(79)	
Southwest	0.9x	0.77	x	4.5	x	92.85	0.63	x	0.7	=	127.7	(79)	
Southwest	0.9x	0.77	x	4.17	x	69.27	0.63	x	0.7	=	176.55	(79)	
Southwest	0.9x	0.77	x	4.5	x	69.27	0.63	x	0.7	=	95.26	(79)	
Southwest	0.9x	0.77	x	4.17	x	44.07	0.63	x	0.7	=	112.33	(79)	
Southwest	0.9x	0.77	x	4.5	x	44.07	0.63	x	0.7	=	60.61	(79)	
Southwest	0.9x	0.77	x	4.17	x	31.49	0.63	x	0.7	=	80.26	(79)	
Southwest	0.9x	0.77	x	4.5	x	31.49	0.63	x	0.7	=	43.3	(79)	
Northwest	0.9x	0.77	x	0.65	x	11.28	x	0.63	x	0.7	=	2.24	(81)
Northwest	0.9x	0.77	x	4.82	x	11.28	x	0.63	x	0.7	=	16.62	(81)
Northwest	0.9x	0.77	x	0.65	x	22.97	x	0.63	x	0.7	=	4.56	(81)
Northwest	0.9x	0.77	x	4.82	x	22.97	x	0.63	x	0.7	=	33.83	(81)
Northwest	0.9x	0.77	x	0.65	x	41.38	x	0.63	x	0.7	=	8.22	(81)
Northwest	0.9x	0.77	x	4.82	x	41.38	x	0.63	x	0.7	=	60.95	(81)
Northwest	0.9x	0.77	x	0.65	x	67.96	x	0.63	x	0.7	=	13.5	(81)
Northwest	0.9x	0.77	x	4.82	x	67.96	x	0.63	x	0.7	=	100.1	(81)
Northwest	0.9x	0.77	x	0.65	x	91.35	x	0.63	x	0.7	=	18.15	(81)
Northwest	0.9x	0.77	x	4.82	x	91.35	x	0.63	x	0.7	=	134.56	(81)
Northwest	0.9x	0.77	x	0.65	x	97.38	x	0.63	x	0.7	=	19.35	(81)
Northwest	0.9x	0.77	x	4.82	x	97.38	x	0.63	x	0.7	=	143.45	(81)
Northwest	0.9x	0.77	x	0.65	x	91.1	x	0.63	x	0.7	=	18.1	(81)
Northwest	0.9x	0.77	x	4.82	x	91.1	x	0.63	x	0.7	=	134.2	(81)
Northwest	0.9x	0.77	x	0.65	x	72.63	x	0.63	x	0.7	=	14.43	(81)
Northwest	0.9x	0.77	x	4.82	x	72.63	x	0.63	x	0.7	=	106.98	(81)
Northwest	0.9x	0.77	x	0.65	x	50.42	x	0.63	x	0.7	=	10.02	(81)
Northwest	0.9x	0.77	x	4.82	x	50.42	x	0.63	x	0.7	=	74.27	(81)
Northwest	0.9x	0.77	x	0.65	x	28.07	x	0.63	x	0.7	=	5.58	(81)
Northwest	0.9x	0.77	x	4.82	x	28.07	x	0.63	x	0.7	=	41.34	(81)
Northwest	0.9x	0.77	x	0.65	x	14.2	x	0.63	x	0.7	=	2.82	(81)
Northwest	0.9x	0.77	x	4.82	x	14.2	x	0.63	x	0.7	=	20.91	(81)
Northwest	0.9x	0.77	x	0.65	x	9.21	x	0.63	x	0.7	=	1.83	(81)
Northwest	0.9x	0.77	x	4.82	x	9.21	x	0.63	x	0.7	=	13.57	(81)
Rooflights	0.9x	1	x	2.28	x	26	x	0.63	x	0.7	=	23.49	(82)
Rooflights	0.9x	1	x	2.28	x	26	x	0.63	x	0.7	=	23.49	(82)
Rooflights	0.9x	1	x	3.29	x	26	x	0.63	x	0.7	=	67.82	(82)

TER WorkSheet: New dwelling design stage

Rooflights 0.9x	1	x	2.28	x	54	x	0.63	x	0.7	=	48.78	(82)
Rooflights 0.9x	1	x	2.28	x	54	x	0.63	x	0.7	=	48.78	(82)
Rooflights 0.9x	1	x	3.29	x	54	x	0.63	x	0.7	=	140.87	(82)
Rooflights 0.9x	1	x	2.28	x	96	x	0.63	x	0.7	=	86.71	(82)
Rooflights 0.9x	1	x	2.28	x	96	x	0.63	x	0.7	=	86.71	(82)
Rooflights 0.9x	1	x	3.29	x	96	x	0.63	x	0.7	=	250.43	(82)
Rooflights 0.9x	1	x	2.28	x	150	x	0.63	x	0.7	=	135.49	(82)
Rooflights 0.9x	1	x	2.28	x	150	x	0.63	x	0.7	=	135.49	(82)
Rooflights 0.9x	1	x	3.29	x	150	x	0.63	x	0.7	=	391.3	(82)
Rooflights 0.9x	1	x	2.28	x	192	x	0.63	x	0.7	=	173.43	(82)
Rooflights 0.9x	1	x	2.28	x	192	x	0.63	x	0.7	=	173.43	(82)
Rooflights 0.9x	1	x	3.29	x	192	x	0.63	x	0.7	=	500.86	(82)
Rooflights 0.9x	1	x	2.28	x	200	x	0.63	x	0.7	=	180.65	(82)
Rooflights 0.9x	1	x	2.28	x	200	x	0.63	x	0.7	=	180.65	(82)
Rooflights 0.9x	1	x	3.29	x	200	x	0.63	x	0.7	=	521.73	(82)
Rooflights 0.9x	1	x	2.28	x	189	x	0.63	x	0.7	=	170.72	(82)
Rooflights 0.9x	1	x	2.28	x	189	x	0.63	x	0.7	=	170.72	(82)
Rooflights 0.9x	1	x	3.29	x	189	x	0.63	x	0.7	=	493.03	(82)
Rooflights 0.9x	1	x	2.28	x	157	x	0.63	x	0.7	=	141.81	(82)
Rooflights 0.9x	1	x	2.28	x	157	x	0.63	x	0.7	=	141.81	(82)
Rooflights 0.9x	1	x	3.29	x	157	x	0.63	x	0.7	=	409.56	(82)
Rooflights 0.9x	1	x	2.28	x	115	x	0.63	x	0.7	=	103.88	(82)
Rooflights 0.9x	1	x	2.28	x	115	x	0.63	x	0.7	=	103.88	(82)
Rooflights 0.9x	1	x	3.29	x	115	x	0.63	x	0.7	=	299.99	(82)
Rooflights 0.9x	1	x	2.28	x	66	x	0.63	x	0.7	=	59.62	(82)
Rooflights 0.9x	1	x	2.28	x	66	x	0.63	x	0.7	=	59.62	(82)
Rooflights 0.9x	1	x	3.29	x	66	x	0.63	x	0.7	=	172.17	(82)
Rooflights 0.9x	1	x	2.28	x	33	x	0.63	x	0.7	=	29.81	(82)
Rooflights 0.9x	1	x	2.28	x	33	x	0.63	x	0.7	=	29.81	(82)
Rooflights 0.9x	1	x	3.29	x	33	x	0.63	x	0.7	=	86.09	(82)
Rooflights 0.9x	1	x	2.28	x	21	x	0.63	x	0.7	=	18.97	(82)
Rooflights 0.9x	1	x	2.28	x	21	x	0.63	x	0.7	=	18.97	(82)
Rooflights 0.9x	1	x	3.29	x	21	x	0.63	x	0.7	=	54.78	(82)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m (82)m

(83)m= 549.93 985.89 1463.22 1977.99 2346.88 2382.56 2275.51 1995.65 1642.54 1122 668.04 464.37 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m= 1141.75 1575.41 2031.64 2511.6 2843.68 2844.26 2715.55 2443.14 2108.53 1623.04 1209.45 1037.46 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21 (85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

TER WorkSheet: New dwelling design stage

(86)m=	1	1	0.98	0.92	0.79	0.61	0.45	0.52	0.79	0.97	1	1	(86)
--------	---	---	------	------	------	------	------	------	------	------	---	---	------

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	19.48	19.73	20.1	20.53	20.83	20.96	20.99	20.99	20.88	20.43	19.86	19.44	(87)
--------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.84	19.84	19.84	19.85	19.85	19.86	19.86	19.86	19.85	19.85	19.84	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	1	0.99	0.97	0.9	0.73	0.51	0.34	0.4	0.7	0.96	1	1	(89)
--------	---	------	------	-----	------	------	------	-----	-----	------	---	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	17.82	18.18	18.72	19.32	19.7	19.84	19.85	19.85	19.76	19.19	18.37	17.76	(90)
--------	-------	-------	-------	-------	------	-------	-------	-------	-------	-------	-------	-------	------

$$fLA = \text{Living area} \div (4) = 0.27 \quad (91)$$

Mean internal temperature (for the whole dwelling) = $fLA \times T1 + (1 - fLA) \times T2$

(92)m=	18.27	18.6	19.09	19.65	20.01	20.14	20.16	20.16	20.06	19.52	18.77	18.21	(92)
--------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.27	18.6	19.09	19.65	20.01	20.14	20.16	20.16	20.06	19.52	18.77	18.21	(93)
--------	-------	------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that $Ti,m=(76)m$ and re-calculate the utilisation factor for gains using Table 9a

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
Utilisation factor for gains, hm:													
(94)m=	1	0.99	0.97	0.89	0.74	0.54	0.37	0.43	0.72	0.95	0.99	1	(94)

Useful gains, hmGm, W = (94)m x (84)m

(95)m=	1139.12	1560.94	1965.19	2241.71	2101.4	1521.87	1001.86	1050.04	1521.96	1542.03	1202.08	1035.88	(95)
--------	---------	---------	---------	---------	--------	---------	---------	---------	---------	---------	---------	---------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm, W = [(39)m x [(93)m - (96)m]

(97)m=	4030.18	3947.34	3621.24	3068.2	2367.71	1568.5	1008.41	1062.95	1693.35	2544.11	3336.34	4017.25	(97)
--------	---------	---------	---------	--------	---------	--------	---------	---------	---------	---------	---------	---------	------

Space heating requirement for each month, kWh/month = $0.024 \times [(97)m - (95)m] \times (41)m$

(98)m=	2150.95	1603.66	1232.1	595.08	198.14	0	0	0	0	745.55	1536.67	2218.13	(98)
--------	---------	---------	--------	--------	--------	---	---	---	---	--------	---------	---------	------

$$\text{Total per year (kWh/year)} = \text{Sum}(98)_{1..5,9..12} = 10280.28 \quad (98)$$

Space heating requirement in kWh/m²/year

$$46.42 \quad (99)$$

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system 0 (201)

Fraction of space heat from main system(s) (202) = 1 - (201) = 1 (202)

Fraction of total heating from main system 1 (204) = (202) × [1 - (203)] = 1 (204)

Efficiency of main space heating system 1 93.4 (206)

Efficiency of secondary/supplementary heating system, % 0 (208)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
--	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

(211)m = [(98)m x (204)] x 100 ÷ (206)	2150.95	1603.66	1232.1	595.08	198.14	0	0	0	0	745.55	1536.67	2218.13	(211)
--	---------	---------	--------	--------	--------	---	---	---	---	--------	---------	---------	-------

$$\text{Total (kWh/year)} = \text{Sum}(211)_{1..5,10..12} = 11006.72 \quad (211)$$

TER WorkSheet: New dwelling design stage

Space heating fuel (secondary), kWh/month

$$= \{[(98)m \times (201)]\} \times 100 \div (208)$$

(215)m=	0	0	0	0	0	0	0	0	0	0	0	0		
Total (kWh/year) =Sum(215) _{1...5,10, 12} =													0	(215)

Water heating

Output from water heater (calculated above)

224.13	197.48	207.25	185.57	181.59	159.94	153.23	170.82	170.71	192.44	203.75	218.67
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Efficiency of water heater 80.3 (216)

(217)m=	89.34	89.17	88.79	87.78	85.27	80.3	80.3	80.3	80.3	88.13	89.09	89.39		(217)
---------	-------	-------	-------	-------	-------	------	------	------	------	-------	-------	-------	--	-------

Fuel for water heating, kWh/month

$$(219)m = (64)m \times 100 \div (217)m$$

(219)m=	250.88	221.47	233.41	211.42	212.96	199.17	190.82	212.72	212.6	218.37	228.71	244.62		
Total = Sum(219a) _{1...12} =													2637.15	(219)

Annual totals

Space heating fuel used, main system 1

kWh/year

kWh/year

11006.72

Water heating fuel used

2637.15

Electricity for pumps, fans and electric keep-hot

central heating pump:

30

(230c)

boiler with a fan-assisted flue

45

(230e)

Total electricity for the above, kWh/year

$$\text{sum of (230a) (230g) =}$$

75

(231)

Electricity for lighting

615.59

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year		Emission factor kg CO2/kWh		Emissions kg CO2/year	
Space heating (main system 1)	(211) x		0.216	=	2377.45	(261)
Space heating (secondary)	(215) x		0.519	=	0	(263)
Water heating	(219) x		0.216	=	569.62	(264)
Space and water heating	(261) + (262) + (263) + (264) =				2947.07	(265)
Electricity for pumps, fans and electric keep-hot	(231) x		0.519	=	38.93	(267)
Electricity for lighting	(232) x		0.519	=	319.49	(268)
Total CO2, kg/year		sum of (265) (271) =			3305.49	(272)

TER =

14.93

(273)

Appendix

Energy Assessment

Ellerdale Road

LEAN Scenario

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:

Software Name: Stroma FSAP 2012

Stroma Number:

Software Version:

Version: 1.0.1.25

Property Address: House 1-LEAN

Address : 1 Ellerdale Road

1. Overall dwelling dimensions:

	Area(m ²)		Av. Height(m)		Volume(m ³)
Basement	67 (1a)	x	2.65 (2a)	=	177.55 (3a)
Ground floor	67 (1b)	x	3 (2b)	=	201 (3b)
First floor	87.44 (1c)	x	3 (2c)	=	262.32 (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+.....(1n)	221.44 (4)				
Dwelling volume				(3a)+(3b)+(3c)+(3d)+(3e)+.....(3n) =	640.87 (5)

2. Ventilation rate:

	main heating		secondary heating		other		total		m ³ per hour
Number of chimneys	0	+	0	+	0	=	0	x 40 =	0 (6a)
Number of open flues	0	+	0	+	0	=	0	x 20 =	0 (6b)
Number of intermittent fans							0	x 10 =	0 (7a)
Number of passive vents							0	x 10 =	0 (7b)
Number of flueless gas fires							0	x 40 =	0 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =							0	÷ (5) =	0 (8)
If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)									
Number of storeys in the dwelling (ns)									0 (9)
Additional infiltration								[(9)-1]x0.1 =	0 (10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction									0 (11)
if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35									
If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0									0 (12)
If no draught lobby, enter 0.05, else enter 0									0 (13)
Percentage of windows and doors draught stripped									0 (14)
Window infiltration						0.25 - [0.2 x (14) ÷ 100] =			0 (15)
Infiltration rate						(8) + (10) + (11) + (12) + (13) + (15) =			0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area									3 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)									0.15 (18)
Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used									
Number of sides sheltered									2 (19)
Shelter factor						(20) = 1 - [0.075 x (19)] =			0.85 (20)
Infiltration rate incorporating shelter factor						(21) = (18) x (20) =			0.13 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

DER WorkSheet: New dwelling design stage

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

	0.16	0.16	0.16	0.14	0.14	0.12	0.12	0.12	0.13	0.14	0.14	0.15
--	------	------	------	------	------	------	------	------	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) × Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) × [1 – (23c) ÷ 100]

(24a)m=	0.28	0.28	0.27	0.26	0.25	0.24	0.24	0.24	0.24	0.25	0.26	0.27
---------	------	------	------	------	------	------	------	------	------	------	------	------

(24a)

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

(24b)

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 × (23b), then (24c) = (23b); otherwise (24c) = (22b) m + 0.5 × (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

(24c)

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0	0
---------	---	---	---	---	---	---	---	---	---	---	---	---

(24d)

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.28	0.28	0.27	0.26	0.25	0.24	0.24	0.24	0.24	0.25	0.26	0.27
--------	------	------	------	------	------	------	------	------	------	------	------	------

(25)

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m²)	Openings m²	Net Area A ,m²	U-value W/m²K	A X U (W/K)	k-value kJ/m²·K	A X k kJ/K
Doors			1.76	x 1.2	= 2.112		(26)
Windows Type 1			0.71	x 1/[1/(1.2)+ 0.04] =	0.81		(27)
Windows Type 2			5.29	x 1/[1/(1.2)+ 0.04] =	6.06		(27)
Windows Type 3			8.46	x 1/[1/(1.2)+ 0.04] =	9.69		(27)
Windows Type 4			9.64	x 1/[1/(1.2)+ 0.04] =	11.04		(27)
Windows Type 5			4.58	x 1/[1/(1.2)+ 0.04] =	5.24		(27)
Windows Type 6			4.94	x 1/[1/(1.2)+ 0.04] =	5.66		(27)
Rooflights Type 1			2.5	x 1/[1/(1.2) + 0.04] =	3		(27b)
Rooflights Type 2			2.5	x 1/[1/(1.2) + 0.04] =	3		(27b)
Rooflights Type 3			3.61	x 1/[1/(1.2) + 0.04] =	4.332		(27b)
Floor			87.44	x 0.11	= 9.618401		(28)
Walls Type1	176.88	0	176.88	x 0.18	= 31.84		(29)
Walls Type2	139.89	48.42	91.47	x 0.18	= 16.46		(29)
Roof	87.44	12.22	75.22	x 0.11	= 8.27		(30)
Total area of elements, m²			491.65				(31)
Party wall			12.41	x 0	= 0		(32)

* for windows and roof windows, use effective window U-value calculated using formula 1/[1/(U-value)+0.04] as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U)

(26) (30) + (32) =

135.73 (33)

DER WorkSheet: New dwelling design stage

Heat capacity $C_m = S(A \times k)$

((28) (30) + (32) + (32a) (32e) = 63515.68 (34)

Thermal mass parameter (TMP = $C_m \div TFA$) in $\text{kJ/m}^2\text{K}$

Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : $S(L \times Y)$ calculated using Appendix K

73.75 (36)

if details of thermal bridging are not known (36) = $0.15 \times (31)$

Total fabric heat loss

(33) + (36) = 209.47 (37)

Ventilation heat loss calculated monthly

(38)m = $0.33 \times (25)\text{m} \times (5)$

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	59.23	58.56	57.88	54.51	53.84	50.47	50.47	49.79	51.81	53.84	55.18	56.53	(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

	268.7	268.03	267.36	263.99	263.31	259.94	259.94	259.27	261.29	263.31	264.66	266.01	
(39)m=													
Average = $\text{Sum}(39)_{1-12} / 12 =$												263.82	(39)

Heat loss parameter (HLP), $\text{W/m}^2\text{K}$

(40)m = (39)m \div (4)

	1.21	1.21	1.21	1.19	1.19	1.17	1.17	1.17	1.18	1.19	1.2	1.2	
(40)m=													
Average = $\text{Sum}(40)_{1-12} / 12 =$												1.19	(40)

Number of days in month (Table 1a)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31	(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

if $TFA > 13.9$, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (TFA - 13.9)^2)] + 0.0013 \times (TFA - 13.9)$

if $TFA \leq 13.9$, $N = 1$

3.03 (42)

Annual average hot water usage in litres per day $V_{d, \text{average}} = (25 \times N) + 36$

106.16 (43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(44)m=	116.77	112.53	108.28	104.03	99.79	95.54	95.54	99.79	104.03	108.28	112.53	116.77	
Total = $\text{Sum}(44)_{1-12} =$												1273.89	(44)

Energy content of hot water used - calculated monthly = $4.190 \times V_{d, \text{m}} \times n_{\text{m}} \times DT_{\text{m}} / 3600$ kWh/month (see Tables 1b, 1c, 1d)

	173.17	151.46	156.29	136.26	130.74	112.82	104.55	119.97	121.4	141.48	154.44	167.71	
(45)m=													
Total = $\text{Sum}(45)_{1-12} =$												1670.28	(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

	25.98	22.72	23.44	20.44	19.61	16.92	15.68	18	18.21	21.22	23.17	25.16	
(46)m=													(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0 (47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0 (48)

Temperature factor from Table 2b

0 (49)

Energy lost from water storage, kWh/year

(48) \times (49) = 0 (50)

b) If manufacturer's declared cylinder loss factor is not known:

DER WorkSheet: New dwelling design stage

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

$$(47) \times (51) \times (52) \times (53) =$$

0

(54)

Enter (50) or (54) in (55)

0

(55)

Water storage loss calculated for each month

$$((56)m = (55) \times (41)m$$

(56)m=	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---

(56)

If cylinder contains dedicated solar storage, (57)m = (56)m x [(50) - (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H

(57)m=	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---

(57)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---

(59)

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m

(61)m=	50.96	46.03	50.96	49.32	50.85	47.12	48.69	50.85	49.32	50.96	49.32	50.96
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(61)

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m=	224.13	197.48	207.25	185.57	181.59	159.94	153.23	170.82	170.71	192.44	203.75	218.67
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

(62)

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=	0	0	0	0	0	0	0	0	0	0	0	0
--------	---	---	---	---	---	---	---	---	---	---	---	---

(63)

Output from water heater

(64)m=	224.13	197.48	207.25	185.57	181.59	159.94	153.23	170.82	170.71	192.44	203.75	218.67
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Output from water heater (annual)_{1 12} 2265.59 (64)

Heat gains from water heating, kWh/month $0.25 \times [0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=	70.32	61.87	64.71	57.63	56.18	49.29	46.93	52.6	52.69	59.78	63.68	68.5
--------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

(65)

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
(66)m=	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49

(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=	34.86	30.96	25.18	19.06	14.25	12.03	13	16.9	22.68	28.79	33.61	35.83
--------	-------	-------	-------	-------	-------	-------	----	------	-------	-------	-------	-------

(67)

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=	390.99	395.05	384.83	363.06	335.58	309.76	292.51	288.45	298.68	320.44	347.92	373.74
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

(68)

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(69)

Pumps and fans gains (Table 5a)

(70)m=	3	3	3	3	3	3	3	3	3	3	3	3
--------	---	---	---	---	---	---	---	---	---	---	---	---

(70)

Losses e.g. evaporation (negative values) (Table 5)

(71)m=	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19
--------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

(71)

Water heating gains (Table 5)

(72)m=	94.52	92.06	86.97	80.05	75.52	68.46	63.08	70.7	73.19	80.35	88.44	92.07
--------	-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------

(72)

DER WorkSheet: New dwelling design stage

Total internal gains =

(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m= 591.81 589.52 568.42 533.62 496.8 461.7 440.04 447.49 465.99 501.03 541.41 573.09

(73)

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d		Area m ²		Flux Table 6a		g_ Table 6b		FF Table 6c		Gains (W)	
Southeast 0.9x	0.77	x	8.46	x	36.79	x	0.55	x	0.8	=	189.83	(77)
Southeast 0.9x	0.77	x	9.64	x	36.79	x	0.55	x	0.8	=	108.15	(77)
Southeast 0.9x	0.77	x	8.46	x	62.67	x	0.55	x	0.8	=	323.35	(77)
Southeast 0.9x	0.77	x	9.64	x	62.67	x	0.55	x	0.8	=	184.22	(77)
Southeast 0.9x	0.77	x	8.46	x	85.75	x	0.55	x	0.8	=	442.42	(77)
Southeast 0.9x	0.77	x	9.64	x	85.75	x	0.55	x	0.8	=	252.06	(77)
Southeast 0.9x	0.77	x	8.46	x	106.25	x	0.55	x	0.8	=	548.18	(77)
Southeast 0.9x	0.77	x	9.64	x	106.25	x	0.55	x	0.8	=	312.32	(77)
Southeast 0.9x	0.77	x	8.46	x	119.01	x	0.55	x	0.8	=	614.01	(77)
Southeast 0.9x	0.77	x	9.64	x	119.01	x	0.55	x	0.8	=	349.82	(77)
Southeast 0.9x	0.77	x	8.46	x	118.15	x	0.55	x	0.8	=	609.57	(77)
Southeast 0.9x	0.77	x	9.64	x	118.15	x	0.55	x	0.8	=	347.29	(77)
Southeast 0.9x	0.77	x	8.46	x	113.91	x	0.55	x	0.8	=	587.69	(77)
Southeast 0.9x	0.77	x	9.64	x	113.91	x	0.55	x	0.8	=	334.83	(77)
Southeast 0.9x	0.77	x	8.46	x	104.39	x	0.55	x	0.8	=	538.58	(77)
Southeast 0.9x	0.77	x	9.64	x	104.39	x	0.55	x	0.8	=	306.85	(77)
Southeast 0.9x	0.77	x	8.46	x	92.85	x	0.55	x	0.8	=	479.05	(77)
Southeast 0.9x	0.77	x	9.64	x	92.85	x	0.55	x	0.8	=	272.93	(77)
Southeast 0.9x	0.77	x	8.46	x	69.27	x	0.55	x	0.8	=	357.37	(77)
Southeast 0.9x	0.77	x	9.64	x	69.27	x	0.55	x	0.8	=	203.61	(77)
Southeast 0.9x	0.77	x	8.46	x	44.07	x	0.55	x	0.8	=	227.37	(77)
Southeast 0.9x	0.77	x	9.64	x	44.07	x	0.55	x	0.8	=	129.54	(77)
Southeast 0.9x	0.77	x	8.46	x	31.49	x	0.55	x	0.8	=	162.45	(77)
Southeast 0.9x	0.77	x	9.64	x	31.49	x	0.55	x	0.8	=	92.56	(77)
Southwest 0.9x	0.77	x	4.58	x	36.79		0.55	x	0.8	=	102.77	(79)
Southwest 0.9x	0.77	x	4.94	x	36.79		0.55	x	0.8	=	55.42	(79)
Southwest 0.9x	0.77	x	4.58	x	62.67		0.55	x	0.8	=	175.05	(79)
Southwest 0.9x	0.77	x	4.94	x	62.67		0.55	x	0.8	=	94.41	(79)
Southwest 0.9x	0.77	x	4.58	x	85.75		0.55	x	0.8	=	239.51	(79)
Southwest 0.9x	0.77	x	4.94	x	85.75		0.55	x	0.8	=	129.17	(79)
Southwest 0.9x	0.77	x	4.58	x	106.25		0.55	x	0.8	=	296.77	(79)
Southwest 0.9x	0.77	x	4.94	x	106.25		0.55	x	0.8	=	160.05	(79)
Southwest 0.9x	0.77	x	4.58	x	119.01		0.55	x	0.8	=	332.4	(79)
Southwest 0.9x	0.77	x	4.94	x	119.01		0.55	x	0.8	=	179.27	(79)

DER WorkSheet: New dwelling design stage

Southwest	0.9x	0.77	x	4.58	x	118.15	0.55	x	0.8	=	330	(79)	
Southwest	0.9x	0.77	x	4.94	x	118.15	0.55	x	0.8	=	177.97	(79)	
Southwest	0.9x	0.77	x	4.58	x	113.91	0.55	x	0.8	=	318.16	(79)	
Southwest	0.9x	0.77	x	4.94	x	113.91	0.55	x	0.8	=	171.58	(79)	
Southwest	0.9x	0.77	x	4.58	x	104.39	0.55	x	0.8	=	291.57	(79)	
Southwest	0.9x	0.77	x	4.94	x	104.39	0.55	x	0.8	=	157.24	(79)	
Southwest	0.9x	0.77	x	4.58	x	92.85	0.55	x	0.8	=	259.34	(79)	
Southwest	0.9x	0.77	x	4.94	x	92.85	0.55	x	0.8	=	139.86	(79)	
Southwest	0.9x	0.77	x	4.58	x	69.27	0.55	x	0.8	=	193.47	(79)	
Southwest	0.9x	0.77	x	4.94	x	69.27	0.55	x	0.8	=	104.34	(79)	
Southwest	0.9x	0.77	x	4.58	x	44.07	0.55	x	0.8	=	123.09	(79)	
Southwest	0.9x	0.77	x	4.94	x	44.07	0.55	x	0.8	=	66.38	(79)	
Southwest	0.9x	0.77	x	4.58	x	31.49	0.55	x	0.8	=	87.95	(79)	
Southwest	0.9x	0.77	x	4.94	x	31.49	0.55	x	0.8	=	47.43	(79)	
Northwest	0.9x	0.77	x	0.71	x	11.28	x	0.55	x	0.8	=	2.44	(81)
Northwest	0.9x	0.77	x	5.29	x	11.28	x	0.55	x	0.8	=	18.2	(81)
Northwest	0.9x	0.77	x	0.71	x	22.97	x	0.55	x	0.8	=	4.97	(81)
Northwest	0.9x	0.77	x	5.29	x	22.97	x	0.55	x	0.8	=	37.05	(81)
Northwest	0.9x	0.77	x	0.71	x	41.38	x	0.55	x	0.8	=	8.96	(81)
Northwest	0.9x	0.77	x	5.29	x	41.38	x	0.55	x	0.8	=	66.75	(81)
Northwest	0.9x	0.77	x	0.71	x	67.96	x	0.55	x	0.8	=	14.71	(81)
Northwest	0.9x	0.77	x	5.29	x	67.96	x	0.55	x	0.8	=	109.61	(81)
Northwest	0.9x	0.77	x	0.71	x	91.35	x	0.55	x	0.8	=	19.78	(81)
Northwest	0.9x	0.77	x	5.29	x	91.35	x	0.55	x	0.8	=	147.34	(81)
Northwest	0.9x	0.77	x	0.71	x	97.38	x	0.55	x	0.8	=	21.08	(81)
Northwest	0.9x	0.77	x	5.29	x	97.38	x	0.55	x	0.8	=	157.08	(81)
Northwest	0.9x	0.77	x	0.71	x	91.1	x	0.55	x	0.8	=	19.72	(81)
Northwest	0.9x	0.77	x	5.29	x	91.1	x	0.55	x	0.8	=	146.95	(81)
Northwest	0.9x	0.77	x	0.71	x	72.63	x	0.55	x	0.8	=	15.72	(81)
Northwest	0.9x	0.77	x	5.29	x	72.63	x	0.55	x	0.8	=	117.15	(81)
Northwest	0.9x	0.77	x	0.71	x	50.42	x	0.55	x	0.8	=	10.92	(81)
Northwest	0.9x	0.77	x	5.29	x	50.42	x	0.55	x	0.8	=	81.33	(81)
Northwest	0.9x	0.77	x	0.71	x	28.07	x	0.55	x	0.8	=	6.08	(81)
Northwest	0.9x	0.77	x	5.29	x	28.07	x	0.55	x	0.8	=	45.27	(81)
Northwest	0.9x	0.77	x	0.71	x	14.2	x	0.55	x	0.8	=	3.07	(81)
Northwest	0.9x	0.77	x	5.29	x	14.2	x	0.55	x	0.8	=	22.9	(81)
Northwest	0.9x	0.77	x	0.71	x	9.21	x	0.55	x	0.8	=	1.99	(81)
Northwest	0.9x	0.77	x	5.29	x	9.21	x	0.55	x	0.8	=	14.86	(81)
Rooflights	0.9x	1	x	2.5	x	26	x	0.55	x	0.8	=	25.74	(82)
Rooflights	0.9x	1	x	2.5	x	26	x	0.55	x	0.8	=	25.74	(82)
Rooflights	0.9x	1	x	3.61	x	26	x	0.55	x	0.8	=	74.34	(82)

DER WorkSheet: New dwelling design stage

Rooflights 0.9x	1	x	2.5	x	54	x	0.55	x	0.8	=	53.46	(82)
Rooflights 0.9x	1	x	2.5	x	54	x	0.55	x	0.8	=	53.46	(82)
Rooflights 0.9x	1	x	3.61	x	54	x	0.55	x	0.8	=	154.39	(82)
Rooflights 0.9x	1	x	2.5	x	96	x	0.55	x	0.8	=	95.04	(82)
Rooflights 0.9x	1	x	2.5	x	96	x	0.55	x	0.8	=	95.04	(82)
Rooflights 0.9x	1	x	3.61	x	96	x	0.55	x	0.8	=	274.48	(82)
Rooflights 0.9x	1	x	2.5	x	150	x	0.55	x	0.8	=	148.5	(82)
Rooflights 0.9x	1	x	2.5	x	150	x	0.55	x	0.8	=	148.5	(82)
Rooflights 0.9x	1	x	3.61	x	150	x	0.55	x	0.8	=	428.87	(82)
Rooflights 0.9x	1	x	2.5	x	192	x	0.55	x	0.8	=	190.08	(82)
Rooflights 0.9x	1	x	2.5	x	192	x	0.55	x	0.8	=	190.08	(82)
Rooflights 0.9x	1	x	3.61	x	192	x	0.55	x	0.8	=	548.95	(82)
Rooflights 0.9x	1	x	2.5	x	200	x	0.55	x	0.8	=	198	(82)
Rooflights 0.9x	1	x	2.5	x	200	x	0.55	x	0.8	=	198	(82)
Rooflights 0.9x	1	x	3.61	x	200	x	0.55	x	0.8	=	571.82	(82)
Rooflights 0.9x	1	x	2.5	x	189	x	0.55	x	0.8	=	187.11	(82)
Rooflights 0.9x	1	x	2.5	x	189	x	0.55	x	0.8	=	187.11	(82)
Rooflights 0.9x	1	x	3.61	x	189	x	0.55	x	0.8	=	540.37	(82)
Rooflights 0.9x	1	x	2.5	x	157	x	0.55	x	0.8	=	155.43	(82)
Rooflights 0.9x	1	x	2.5	x	157	x	0.55	x	0.8	=	155.43	(82)
Rooflights 0.9x	1	x	3.61	x	157	x	0.55	x	0.8	=	448.88	(82)
Rooflights 0.9x	1	x	2.5	x	115	x	0.55	x	0.8	=	113.85	(82)
Rooflights 0.9x	1	x	2.5	x	115	x	0.55	x	0.8	=	113.85	(82)
Rooflights 0.9x	1	x	3.61	x	115	x	0.55	x	0.8	=	328.8	(82)
Rooflights 0.9x	1	x	2.5	x	66	x	0.55	x	0.8	=	65.34	(82)
Rooflights 0.9x	1	x	2.5	x	66	x	0.55	x	0.8	=	65.34	(82)
Rooflights 0.9x	1	x	3.61	x	66	x	0.55	x	0.8	=	188.7	(82)
Rooflights 0.9x	1	x	2.5	x	33	x	0.55	x	0.8	=	32.67	(82)
Rooflights 0.9x	1	x	2.5	x	33	x	0.55	x	0.8	=	32.67	(82)
Rooflights 0.9x	1	x	3.61	x	33	x	0.55	x	0.8	=	94.35	(82)
Rooflights 0.9x	1	x	2.5	x	21	x	0.55	x	0.8	=	20.79	(82)
Rooflights 0.9x	1	x	2.5	x	21	x	0.55	x	0.8	=	20.79	(82)
Rooflights 0.9x	1	x	3.61	x	21	x	0.55	x	0.8	=	60.04	(82)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m (82)m

(83)m= 602.63 1080.36 1603.42 2167.51 2571.73 2610.82 2493.52 2186.85 1799.93 1229.51 732.05 508.87 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m= 1194.44 1669.88 2171.84 2701.12 3068.53 3072.52 2933.55 2634.35 2265.91 1730.55 1273.47 1081.95 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21 (85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

DER WorkSheet: New dwelling design stage

(86)m=	1	0.99	0.97	0.89	0.73	0.53	0.39	0.45	0.72	0.96	1	1	(86)
--------	---	------	------	------	------	------	------	------	------	------	---	---	------

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	19.62	19.89	20.26	20.67	20.91	20.98	21	20.99	20.93	20.55	19.99	19.58	(87)
--------	-------	-------	-------	-------	-------	-------	----	-------	-------	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.91	19.91	19.91	19.93	19.93	19.94	19.94	19.94	19.93	19.92	19.92	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	1	0.99	0.96	0.86	0.66	0.45	0.3	0.35	0.64	0.94	0.99	1	(89)
--------	---	------	------	------	------	------	-----	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.07	18.46	19	19.56	19.85	19.93	19.94	19.94	19.89	19.42	18.61	18.01	(90)
--------	-------	-------	----	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

fLA = Living area ÷ (4) =	0.27	(91)
---------------------------	------	------

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	18.48	18.84	19.34	19.86	20.13	20.21	20.22	20.22	20.17	19.72	18.98	18.43	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.33	18.69	19.19	19.71	19.98	20.06	20.07	20.07	20.02	19.57	18.83	18.28	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that Ti,m=(76)m and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	1	0.99	0.95	0.85	0.67	0.46	0.31	0.36	0.65	0.93	0.99	1	(94)
--------	---	------	------	------	------	------	------	------	------	------	------	---	------

Useful gains, hmGm, W = (94)m x (84)m

(95)m=	1191.22	1649.89	2074.03	2301.41	2043.75	1403.48	901.29	948.77	1462.89	1610.34	1263.66	1080.1	(95)
--------	---------	---------	---------	---------	---------	---------	--------	--------	---------	---------	---------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm, W = [(39)m x [(93)m – (96)m]

(97)m=	3770.88	3696.46	3391.48	2853.83	2180.64	1420.5	903.13	952.72	1546.44	2361.82	3105.13	3745.9	(97)
--------	---------	---------	---------	---------	---------	--------	--------	--------	---------	---------	---------	--------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	1919.26	1375.3	980.18	397.75	101.84	0	0	0	0	559.1	1325.86	1983.36	(98)
--------	---------	--------	--------	--------	--------	---	---	---	---	-------	---------	---------	------

Total per year (kWh/year) = Sum(98) _{1...5,9...12} =	8642.66	(98)
---	---------	------

Space heating requirement in kWh/m²/year

39.03	(99)
-------	------

8c. Space cooling requirement

Calculated for June, July and August. See Table 10b

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Heat loss rate Lm (calculated using 25°C internal temperature and external temperature from Table 10)

(100)m=	0	0	0	0	0	2443.45	1923.56	1970.43	0	0	0	0	(100)
---------	---	---	---	---	---	---------	---------	---------	---	---	---	---	-------

Utilisation factor for loss hm

(101)m=	0	0	0	0	0	0.95	0.97	0.96	0	0	0	0	(101)
---------	---	---	---	---	---	------	------	------	---	---	---	---	-------

Useful loss, hmLm (Watts) = (100)m x (101)m

(102)m=	0	0	0	0	0	2310.73	1872.35	1887.73	0	0	0	0	(102)
---------	---	---	---	---	---	---------	---------	---------	---	---	---	---	-------

Gains (solar gains calculated for applicable weather region, see Table 10)

(103)m=	0	0	0	0	0	3565.88	3409.05	3088.06	0	0	0	0	(103)
---------	---	---	---	---	---	---------	---------	---------	---	---	---	---	-------

Space cooling requirement for month, whole dwelling, continuous (kWh) = 0.024 x [(103)m – (102)m] x (41)m

set (104)m to zero if (104)m < 3 × (98)m

(104)m=	0	0	0	0	0	903.7	1143.3	893.05	0	0	0	0	(104)
---------	---	---	---	---	---	-------	--------	--------	---	---	---	---	-------

Total = Sum(104) =	2940.05	(104)
--------------------	---------	-------

DER WorkSheet: New dwelling design stage

Cooled fraction $f_C = \text{cooled area} \div (4) =$ 0.72 (105)

Intermittency factor (Table 10b)

(106)m=	0	0	0	0	0	0.25	0.25	0.25	0	0	0	0	
$Total = \text{Sum}(104) =$													0 (106)

Space cooling requirement for month = (104)m × (105) × (106)m

(107)m=	0	0	0	0	0	162.89	206.08	160.97	0	0	0	0	
$Total = \text{Sum}(107) =$													529.95 (107)

Space cooling requirement in kWh/m²/year $(107) \div (4) =$ 2.39 (108)

9a. Energy requirements – Individual heating systems including micro-CHP)

Space heating:

Fraction of space heat from secondary/supplementary system 0 (201)

Fraction of space heat from main system(s) $(202) = 1 - (201) =$ 1 (202)

Fraction of total heating from main system 1 $(204) = (202) \times [1 - (203)] =$ 1 (204)

Efficiency of main space heating system 1 93.3 (206)

Efficiency of secondary/supplementary heating system, % 0 (208)

Cooling System Energy Efficiency Ratio 4.32 (209)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

(211)m =	1919.26	1375.3	980.18	397.75	101.84	0	0	0	0	559.1	1325.86	1983.36	
$Total (kWh/year) = \text{Sum}(211)_{1..5,10..12} =$													9263.3 (211)

Space heating fuel (secondary), kWh/month
= $\{[(98)m \times (201)]\} \times 100 \div (208)$

(215)m=	0	0	0	0	0	0	0	0	0	0	0	0	
$Total (kWh/year) = \text{Sum}(215)_{1..5,10..12} =$													0 (215)

Water heating

Output from water heater (calculated above)

224.13	197.48	207.25	185.57	181.59	159.94	153.23	170.82	170.71	192.44	203.75	218.67
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Efficiency of water heater 81 (216)

(217)m= 89.23 (217)

Fuel for water heating, kWh/month

(219)m = (64)m × 100 ÷ (217)m

(219)m=	251.19	221.85	234.11	213.01	215.89	197.45	189.18	210.89	210.76	219.38	229.09	244.92	
$Total = \text{Sum}(219a)_{1..12} =$													2637.71 (219)

Space cooling fuel, kWh/month.

(221)m = (107)m ÷ (209)

(221)m=	0	0	0	0	0	37.71	47.7	37.26	0	0	0	0	
$Total = \text{Sum}(221)_{6..8} =$													122.67 (221)

Annual totals

Space heating fuel used, main system 1

kWh/year

kWh/year

Water heating fuel used

Space cooling fuel used

9263.3

2637.71

122.67

DER WorkSheet: New dwelling design stage

Electricity for pumps, fans and electric keep-hot

mechanical ventilation - balanced, extract or positive input from outside

508.21

(230a)

central heating pump:

30

(230c)

Total electricity for the above, kWh/year

sum of (230a) (230g) =

538.21

(231)

Electricity for lighting

615.59

(232)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh		Emissions kg CO2/year	
Space heating (main system 1)	(211) x	0.216	=	2000.87	(261)
Space heating (secondary)	(215) x	0.519	=	0	(263)
Water heating	(219) x	0.216	=	569.75	(264)
Space and water heating	(261) + (262) + (263) + (264) =			2570.62	(265)
Space cooling	(221) x	0.519	=	63.67	(266)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519	=	279.33	(267)
Electricity for lighting	(232) x	0.519	=	319.49	(268)
Total CO2, kg/year			sum of (265) (271) =	3233.11	(272)
Dwelling CO2 Emission Rate			(272) ÷ (4) =	14.6	(273)
El rating (section 14)				84	(274)

Appendix

Energy Assessment

Ellerdale Road

GREEN Scenario

DER WorkSheet: New dwelling design stage

User Details:

Assessor Name:

Stroma Number:

Software Name: Stroma FSAP 2012

Software Version:

Version: 1.0.1.25

Property Address: House 1-GREEN

Address : 1 Ellerdale Road

1. Overall dwelling dimensions:

	Area(m ²)		Av. Height(m)		Volume(m ³)
Basement	67 (1a)	x	2.65 (2a)	=	177.55 (3a)
Ground floor	67 (1b)	x	3 (2b)	=	201 (3b)
First floor	87.44 (1c)	x	3 (2c)	=	262.32 (3c)
Total floor area TFA = (1a)+(1b)+(1c)+(1d)+(1e)+.....(1n)	221.44 (4)				
Dwelling volume				(3a)+(3b)+(3c)+(3d)+(3e)+.....(3n) =	640.87 (5)

2. Ventilation rate:

	main heating		secondary heating		other		total		m ³ per hour
Number of chimneys	0	+	0	+	0	=	0	x 40 =	0 (6a)
Number of open flues	0	+	0	+	0	=	0	x 20 =	0 (6b)
Number of intermittent fans							0	x 10 =	0 (7a)
Number of passive vents							0	x 10 =	0 (7b)
Number of flueless gas fires							0	x 40 =	0 (7c)
Infiltration due to chimneys, flues and fans = (6a)+(6b)+(7a)+(7b)+(7c) =									
							0	÷ (5) =	0 (8)
If a pressurisation test has been carried out or is intended, proceed to (17), otherwise continue from (9) to (16)									
Number of storeys in the dwelling (ns)									0 (9)
Additional infiltration								[(9)-1]x0.1 =	0 (10)
Structural infiltration: 0.25 for steel or timber frame or 0.35 for masonry construction									0 (11)
if both types of wall are present, use the value corresponding to the greater wall area (after deducting areas of openings); if equal user 0.35									
If suspended wooden floor, enter 0.2 (unsealed) or 0.1 (sealed), else enter 0									0 (12)
If no draught lobby, enter 0.05, else enter 0									0 (13)
Percentage of windows and doors draught stripped									0 (14)
Window infiltration							0.25 - [0.2 x (14) ÷ 100] =		0 (15)
Infiltration rate							(8) + (10) + (11) + (12) + (13) + (15) =		0 (16)
Air permeability value, q50, expressed in cubic metres per hour per square metre of envelope area									3 (17)
If based on air permeability value, then (18) = [(17) ÷ 20]+(8), otherwise (18) = (16)									0.15 (18)
Air permeability value applies if a pressurisation test has been done or a degree air permeability is being used									
Number of sides sheltered									2 (19)
Shelter factor							(20) = 1 - [0.075 x (19)] =		0.85 (20)
Infiltration rate incorporating shelter factor							(21) = (18) x (20) =		0.13 (21)

Infiltration rate modified for monthly wind speed

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Monthly average wind speed from Table 7

(22)m=	5.1	5	4.9	4.4	4.3	3.8	3.8	3.7	4	4.3	4.5	4.7
--------	-----	---	-----	-----	-----	-----	-----	-----	---	-----	-----	-----

DER WorkSheet: New dwelling design stage

Wind Factor (22a)m = (22)m ÷ 4

(22a)m=	1.27	1.25	1.23	1.1	1.08	0.95	0.95	0.92	1	1.08	1.12	1.18
---------	------	------	------	-----	------	------	------	------	---	------	------	------

Adjusted infiltration rate (allowing for shelter and wind speed) = (21a) x (22a)m

	0.16	0.16	0.16	0.14	0.14	0.12	0.12	0.12	0.13	0.14	0.14	0.15
--	------	------	------	------	------	------	------	------	------	------	------	------

Calculate effective air change rate for the applicable case

If mechanical ventilation:

0.5 (23a)

If exhaust air heat pump using Appendix N, (23b) = (23a) × Fmv (equation (N5)) , otherwise (23b) = (23a)

0.5 (23b)

If balanced with heat recovery: efficiency in % allowing for in-use factor (from Table 4h) =

76.5 (23c)

a) If balanced mechanical ventilation with heat recovery (MVHR) (24a)m = (22b)m + (23b) × [1 – (23c) ÷ 100]

(24a)m=	0.28	0.28	0.27	0.26	0.25	0.24	0.24	0.24	0.24	0.25	0.26	0.27	(24a)
---------	------	------	------	------	------	------	------	------	------	------	------	------	-------

b) If balanced mechanical ventilation without heat recovery (MV) (24b)m = (22b)m + (23b)

(24b)m=	0	0	0	0	0	0	0	0	0	0	0	0	(24b)
---------	---	---	---	---	---	---	---	---	---	---	---	---	-------

c) If whole house extract ventilation or positive input ventilation from outside

if (22b)m < 0.5 × (23b), then (24c) = (23b); otherwise (24c) = (22b) m + 0.5 × (23b)

(24c)m=	0	0	0	0	0	0	0	0	0	0	0	0	(24c)
---------	---	---	---	---	---	---	---	---	---	---	---	---	-------

d) If natural ventilation or whole house positive input ventilation from loft

if (22b)m = 1, then (24d)m = (22b)m otherwise (24d)m = 0.5 + [(22b)m² x 0.5]

(24d)m=	0	0	0	0	0	0	0	0	0	0	0	0	(24d)
---------	---	---	---	---	---	---	---	---	---	---	---	---	-------

Effective air change rate - enter (24a) or (24b) or (24c) or (24d) in box (25)

(25)m=	0.28	0.28	0.27	0.26	0.25	0.24	0.24	0.24	0.24	0.25	0.26	0.27	(25)
--------	------	------	------	------	------	------	------	------	------	------	------	------	------

3. Heat losses and heat loss parameter:

ELEMENT	Gross area (m²)	Openings m²	Net Area A ,m²	U-value W/m²K	A X U (W/K)	k-value kJ/m²·K	A X k kJ/K
Doors			1.76	x 1.2	= 2.112		(26)
Windows Type 1			0.71	x 1/[1/(1.2)+ 0.04] =	0.81		(27)
Windows Type 2			5.29	x 1/[1/(1.2)+ 0.04] =	6.06		(27)
Windows Type 3			8.46	x 1/[1/(1.2)+ 0.04] =	9.69		(27)
Windows Type 4			9.64	x 1/[1/(1.2)+ 0.04] =	11.04		(27)
Windows Type 5			4.58	x 1/[1/(1.2)+ 0.04] =	5.24		(27)
Windows Type 6			4.94	x 1/[1/(1.2)+ 0.04] =	5.66		(27)
Rooflights Type 1			2.5	x 1/[1/(1.2) + 0.04] =	3		(27b)
Rooflights Type 2			2.5	x 1/[1/(1.2) + 0.04] =	3		(27b)
Rooflights Type 3			3.61	x 1/[1/(1.2) + 0.04] =	4.332		(27b)
Floor			87.44	x 0.11	= 9.618401		(28)
Walls Type1	176.88	0	176.88	x 0.18	= 31.84		(29)
Walls Type2	139.89	48.42	91.47	x 0.18	= 16.46		(29)
Roof	87.44	12.22	75.22	x 0.11	= 8.27		(30)
Total area of elements, m²			491.65				(31)
Party wall			12.41	x 0	= 0		(32)

* for windows and roof windows, use effective window U-value calculated using formula 1/[1/(U-value)+0.04] as given in paragraph 3.2

** include the areas on both sides of internal walls and partitions

Fabric heat loss, W/K = S (A x U) (26) (30) + (32) = 135.73 (33)

DER WorkSheet: New dwelling design stage

Heat capacity $C_m = S(A \times k)$

((28) (30) + (32) + (32a) (32e) = 63515.68 (34)

Thermal mass parameter (TMP = $C_m \div TFA$) in $\text{kJ/m}^2\text{K}$

Indicative Value: Medium 250 (35)

For design assessments where the details of the construction are not known precisely the indicative values of TMP in Table 1f can be used instead of a detailed calculation.

Thermal bridges : $S(L \times Y)$ calculated using Appendix K

73.75 (36)

if details of thermal bridging are not known (36) = $0.15 \times (31)$

Total fabric heat loss

(33) + (36) = 209.47 (37)

Ventilation heat loss calculated monthly

(38)m = $0.33 \times (25)\text{m} \times (5)$

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(38)m=	59.23	58.56	57.88	54.51	53.84	50.47	50.47	49.79	51.81	53.84	55.18	56.53	(38)

Heat transfer coefficient, W/K

(39)m = (37) + (38)m

	268.7	268.03	267.36	263.99	263.31	259.94	259.94	259.27	261.29	263.31	264.66	266.01	
(39)m=													
Average = $\text{Sum}(39)_{1-12} / 12 =$												263.82	(39)

Heat loss parameter (HLP), $\text{W/m}^2\text{K}$

(40)m = (39)m \div (4)

	1.21	1.21	1.21	1.19	1.19	1.17	1.17	1.17	1.18	1.19	1.2	1.2	
(40)m=													
Average = $\text{Sum}(40)_{1-12} / 12 =$												1.19	(40)

Number of days in month (Table 1a)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(41)m=	31	28	31	30	31	30	31	31	30	31	30	31	(41)

4. Water heating energy requirement:

kWh/year:

Assumed occupancy, N

if $TFA > 13.9$, $N = 1 + 1.76 \times [1 - \exp(-0.000349 \times (TFA - 13.9)^2)] + 0.0013 \times (TFA - 13.9)$

if $TFA \leq 13.9$, $N = 1$

3.03 (42)

Annual average hot water usage in litres per day $V_{d, \text{average}} = (25 \times N) + 36$

106.16 (43)

Reduce the annual average hot water usage by 5% if the dwelling is designed to achieve a water use target of not more than 125 litres per person per day (all water use, hot and cold)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
(44)m=	116.77	112.53	108.28	104.03	99.79	95.54	95.54	99.79	104.03	108.28	112.53	116.77	
Total = $\text{Sum}(44)_{1-12} =$												1273.89	(44)

Energy content of hot water used - calculated monthly = $4.190 \times V_{d,m} \times n_m \times DT_m / 3600$ kWh/month (see Tables 1b, 1c, 1d)

	173.17	151.46	156.29	136.26	130.74	112.82	104.55	119.97	121.4	141.48	154.44	167.71	
(45)m=													
Total = $\text{Sum}(45)_{1-12} =$												1670.28	(45)

If instantaneous water heating at point of use (no hot water storage), enter 0 in boxes (46) to (61)

	25.98	22.72	23.44	20.44	19.61	16.92	15.68	18	18.21	21.22	23.17	25.16	
(46)m=													(46)

Water storage loss:

Storage volume (litres) including any solar or WWHRS storage within same vessel

0 (47)

If community heating and no tank in dwelling, enter 110 litres in (47)

Otherwise if no stored hot water (this includes instantaneous combi boilers) enter '0' in (47)

Water storage loss:

a) If manufacturer's declared loss factor is known (kWh/day):

0 (48)

Temperature factor from Table 2b

0 (49)

Energy lost from water storage, kWh/year

(48) \times (49) = 0 (50)

b) If manufacturer's declared cylinder loss factor is not known:

DER WorkSheet: New dwelling design stage

Hot water storage loss factor from Table 2 (kWh/litre/day)

0

(51)

If community heating see section 4.3

Volume factor from Table 2a

0

(52)

Temperature factor from Table 2b

0

(53)

Energy lost from water storage, kWh/year

$$(47) \times (51) \times (52) \times (53) =$$

0

(54)

Enter (50) or (54) in (55)

0

(55)

Water storage loss calculated for each month

$$((56)m = (55) \times (41)m$$

(56)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

(56)

If cylinder contains dedicated solar storage, (57)m = (56)m x [(50) - (H11)] ÷ (50), else (57)m = (56)m where (H11) is from Appendix H

(57)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

(57)

Primary circuit loss (annual) from Table 3

0

(58)

Primary circuit loss calculated for each month (59)m = (58) ÷ 365 × (41)m

(modified by factor from Table H5 if there is solar water heating and a cylinder thermostat)

(59)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

(59)

Combi loss calculated for each month (61)m = (60) ÷ 365 × (41)m

(61)m=

50.96	46.03	50.96	49.32	50.85	47.12	48.69	50.85	49.32	50.96	49.32	50.96
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(61)

Total heat required for water heating calculated for each month (62)m = 0.85 × (45)m + (46)m + (57)m + (59)m + (61)m

(62)m=

224.13	197.48	207.25	185.57	181.59	159.94	153.23	170.82	170.71	192.44	203.75	218.67
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

(62)

Solar DHW input calculated using Appendix G or Appendix H (negative quantity) (enter '0' if no solar contribution to water heating)

(add additional lines if FGHRs and/or WWHRs applies, see Appendix G)

(63)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

(63)

Output from water heater

(64)m=

224.13	197.48	207.25	185.57	181.59	159.94	153.23	170.82	170.71	192.44	203.75	218.67
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Output from water heater (annual)_{1 12}

2265.59

(64)

Heat gains from water heating, kWh/month $0.25 \times [0.85 \times (45)m + (61)m] + 0.8 \times [(46)m + (57)m + (59)m]$

(65)m=

70.32	61.87	64.71	57.63	56.18	49.29	46.93	52.6	52.69	59.78	63.68	68.5
-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	------

(65)

include (57)m in calculation of (65)m only if cylinder is in the dwelling or hot water is from community heating

5. Internal gains (see Table 5 and 5a):

Metabolic gains (Table 5), Watts

(66)m=

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49	151.49

(66)

Lighting gains (calculated in Appendix L, equation L9 or L9a), also see Table 5

(67)m=

34.86	30.96	25.18	19.06	14.25	12.03	13	16.9	22.68	28.79	33.61	35.83
-------	-------	-------	-------	-------	-------	----	------	-------	-------	-------	-------

(67)

Appliances gains (calculated in Appendix L, equation L13 or L13a), also see Table 5

(68)m=

390.99	395.05	384.83	363.06	335.58	309.76	292.51	288.45	298.68	320.44	347.92	373.74
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

(68)

Cooking gains (calculated in Appendix L, equation L15 or L15a), also see Table 5

(69)m=

38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15	38.15
-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------

(69)

Pumps and fans gains (Table 5a)

(70)m=

3	3	3	3	3	3	3	3	3	3	3	3
---	---	---	---	---	---	---	---	---	---	---	---

(70)

Losses e.g. evaporation (negative values) (Table 5)

(71)m=

-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19	-121.19
---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------	---------

(71)

Water heating gains (Table 5)

(72)m=

94.52	92.06	86.97	80.05	75.52	68.46	63.08	70.7	73.19	80.35	88.44	92.07
-------	-------	-------	-------	-------	-------	-------	------	-------	-------	-------	-------

(72)

DER WorkSheet: New dwelling design stage

Total internal gains =

(66)m + (67)m + (68)m + (69)m + (70)m + (71)m + (72)m

(73)m=	591.81	589.52	568.42	533.62	496.8	461.7	440.04	447.49	465.99	501.03	541.41	573.09
--------	--------	--------	--------	--------	-------	-------	--------	--------	--------	--------	--------	--------

(73)

6. Solar gains:

Solar gains are calculated using solar flux from Table 6a and associated equations to convert to the applicable orientation.

Orientation:	Access Factor Table 6d		Area m ²		Flux Table 6a		g_ Table 6b		FF Table 6c		Gains (W)	
Southeast 0.9x	0.77	x	8.46	x	36.79	x	0.55	x	0.8	=	189.83	(77)
Southeast 0.9x	0.77	x	9.64	x	36.79	x	0.55	x	0.8	=	108.15	(77)
Southeast 0.9x	0.77	x	8.46	x	62.67	x	0.55	x	0.8	=	323.35	(77)
Southeast 0.9x	0.77	x	9.64	x	62.67	x	0.55	x	0.8	=	184.22	(77)
Southeast 0.9x	0.77	x	8.46	x	85.75	x	0.55	x	0.8	=	442.42	(77)
Southeast 0.9x	0.77	x	9.64	x	85.75	x	0.55	x	0.8	=	252.06	(77)
Southeast 0.9x	0.77	x	8.46	x	106.25	x	0.55	x	0.8	=	548.18	(77)
Southeast 0.9x	0.77	x	9.64	x	106.25	x	0.55	x	0.8	=	312.32	(77)
Southeast 0.9x	0.77	x	8.46	x	119.01	x	0.55	x	0.8	=	614.01	(77)
Southeast 0.9x	0.77	x	9.64	x	119.01	x	0.55	x	0.8	=	349.82	(77)
Southeast 0.9x	0.77	x	8.46	x	118.15	x	0.55	x	0.8	=	609.57	(77)
Southeast 0.9x	0.77	x	9.64	x	118.15	x	0.55	x	0.8	=	347.29	(77)
Southeast 0.9x	0.77	x	8.46	x	113.91	x	0.55	x	0.8	=	587.69	(77)
Southeast 0.9x	0.77	x	9.64	x	113.91	x	0.55	x	0.8	=	334.83	(77)
Southeast 0.9x	0.77	x	8.46	x	104.39	x	0.55	x	0.8	=	538.58	(77)
Southeast 0.9x	0.77	x	9.64	x	104.39	x	0.55	x	0.8	=	306.85	(77)
Southeast 0.9x	0.77	x	8.46	x	92.85	x	0.55	x	0.8	=	479.05	(77)
Southeast 0.9x	0.77	x	9.64	x	92.85	x	0.55	x	0.8	=	272.93	(77)
Southeast 0.9x	0.77	x	8.46	x	69.27	x	0.55	x	0.8	=	357.37	(77)
Southeast 0.9x	0.77	x	9.64	x	69.27	x	0.55	x	0.8	=	203.61	(77)
Southeast 0.9x	0.77	x	8.46	x	44.07	x	0.55	x	0.8	=	227.37	(77)
Southeast 0.9x	0.77	x	9.64	x	44.07	x	0.55	x	0.8	=	129.54	(77)
Southeast 0.9x	0.77	x	8.46	x	31.49	x	0.55	x	0.8	=	162.45	(77)
Southeast 0.9x	0.77	x	9.64	x	31.49	x	0.55	x	0.8	=	92.56	(77)
Southwest 0.9x	0.77	x	4.58	x	36.79		0.55	x	0.8	=	102.77	(79)
Southwest 0.9x	0.77	x	4.94	x	36.79		0.55	x	0.8	=	55.42	(79)
Southwest 0.9x	0.77	x	4.58	x	62.67		0.55	x	0.8	=	175.05	(79)
Southwest 0.9x	0.77	x	4.94	x	62.67		0.55	x	0.8	=	94.41	(79)
Southwest 0.9x	0.77	x	4.58	x	85.75		0.55	x	0.8	=	239.51	(79)
Southwest 0.9x	0.77	x	4.94	x	85.75		0.55	x	0.8	=	129.17	(79)
Southwest 0.9x	0.77	x	4.58	x	106.25		0.55	x	0.8	=	296.77	(79)
Southwest 0.9x	0.77	x	4.94	x	106.25		0.55	x	0.8	=	160.05	(79)
Southwest 0.9x	0.77	x	4.58	x	119.01		0.55	x	0.8	=	332.4	(79)
Southwest 0.9x	0.77	x	4.94	x	119.01		0.55	x	0.8	=	179.27	(79)

DER WorkSheet: New dwelling design stage

Southwest	0.9x	0.77	x	4.58	x	118.15	0.55	x	0.8	=	330	(79)	
Southwest	0.9x	0.77	x	4.94	x	118.15	0.55	x	0.8	=	177.97	(79)	
Southwest	0.9x	0.77	x	4.58	x	113.91	0.55	x	0.8	=	318.16	(79)	
Southwest	0.9x	0.77	x	4.94	x	113.91	0.55	x	0.8	=	171.58	(79)	
Southwest	0.9x	0.77	x	4.58	x	104.39	0.55	x	0.8	=	291.57	(79)	
Southwest	0.9x	0.77	x	4.94	x	104.39	0.55	x	0.8	=	157.24	(79)	
Southwest	0.9x	0.77	x	4.58	x	92.85	0.55	x	0.8	=	259.34	(79)	
Southwest	0.9x	0.77	x	4.94	x	92.85	0.55	x	0.8	=	139.86	(79)	
Southwest	0.9x	0.77	x	4.58	x	69.27	0.55	x	0.8	=	193.47	(79)	
Southwest	0.9x	0.77	x	4.94	x	69.27	0.55	x	0.8	=	104.34	(79)	
Southwest	0.9x	0.77	x	4.58	x	44.07	0.55	x	0.8	=	123.09	(79)	
Southwest	0.9x	0.77	x	4.94	x	44.07	0.55	x	0.8	=	66.38	(79)	
Southwest	0.9x	0.77	x	4.58	x	31.49	0.55	x	0.8	=	87.95	(79)	
Southwest	0.9x	0.77	x	4.94	x	31.49	0.55	x	0.8	=	47.43	(79)	
Northwest	0.9x	0.77	x	0.71	x	11.28	x	0.55	x	0.8	=	2.44	(81)
Northwest	0.9x	0.77	x	5.29	x	11.28	x	0.55	x	0.8	=	18.2	(81)
Northwest	0.9x	0.77	x	0.71	x	22.97	x	0.55	x	0.8	=	4.97	(81)
Northwest	0.9x	0.77	x	5.29	x	22.97	x	0.55	x	0.8	=	37.05	(81)
Northwest	0.9x	0.77	x	0.71	x	41.38	x	0.55	x	0.8	=	8.96	(81)
Northwest	0.9x	0.77	x	5.29	x	41.38	x	0.55	x	0.8	=	66.75	(81)
Northwest	0.9x	0.77	x	0.71	x	67.96	x	0.55	x	0.8	=	14.71	(81)
Northwest	0.9x	0.77	x	5.29	x	67.96	x	0.55	x	0.8	=	109.61	(81)
Northwest	0.9x	0.77	x	0.71	x	91.35	x	0.55	x	0.8	=	19.78	(81)
Northwest	0.9x	0.77	x	5.29	x	91.35	x	0.55	x	0.8	=	147.34	(81)
Northwest	0.9x	0.77	x	0.71	x	97.38	x	0.55	x	0.8	=	21.08	(81)
Northwest	0.9x	0.77	x	5.29	x	97.38	x	0.55	x	0.8	=	157.08	(81)
Northwest	0.9x	0.77	x	0.71	x	91.1	x	0.55	x	0.8	=	19.72	(81)
Northwest	0.9x	0.77	x	5.29	x	91.1	x	0.55	x	0.8	=	146.95	(81)
Northwest	0.9x	0.77	x	0.71	x	72.63	x	0.55	x	0.8	=	15.72	(81)
Northwest	0.9x	0.77	x	5.29	x	72.63	x	0.55	x	0.8	=	117.15	(81)
Northwest	0.9x	0.77	x	0.71	x	50.42	x	0.55	x	0.8	=	10.92	(81)
Northwest	0.9x	0.77	x	5.29	x	50.42	x	0.55	x	0.8	=	81.33	(81)
Northwest	0.9x	0.77	x	0.71	x	28.07	x	0.55	x	0.8	=	6.08	(81)
Northwest	0.9x	0.77	x	5.29	x	28.07	x	0.55	x	0.8	=	45.27	(81)
Northwest	0.9x	0.77	x	0.71	x	14.2	x	0.55	x	0.8	=	3.07	(81)
Northwest	0.9x	0.77	x	5.29	x	14.2	x	0.55	x	0.8	=	22.9	(81)
Northwest	0.9x	0.77	x	0.71	x	9.21	x	0.55	x	0.8	=	1.99	(81)
Northwest	0.9x	0.77	x	5.29	x	9.21	x	0.55	x	0.8	=	14.86	(81)
Rooflights	0.9x	1	x	2.5	x	26	x	0.55	x	0.8	=	25.74	(82)
Rooflights	0.9x	1	x	2.5	x	26	x	0.55	x	0.8	=	25.74	(82)
Rooflights	0.9x	1	x	3.61	x	26	x	0.55	x	0.8	=	74.34	(82)

DER WorkSheet: New dwelling design stage

Rooflights 0.9x	1	x	2.5	x	54	x	0.55	x	0.8	=	53.46	(82)
Rooflights 0.9x	1	x	2.5	x	54	x	0.55	x	0.8	=	53.46	(82)
Rooflights 0.9x	1	x	3.61	x	54	x	0.55	x	0.8	=	154.39	(82)
Rooflights 0.9x	1	x	2.5	x	96	x	0.55	x	0.8	=	95.04	(82)
Rooflights 0.9x	1	x	2.5	x	96	x	0.55	x	0.8	=	95.04	(82)
Rooflights 0.9x	1	x	3.61	x	96	x	0.55	x	0.8	=	274.48	(82)
Rooflights 0.9x	1	x	2.5	x	150	x	0.55	x	0.8	=	148.5	(82)
Rooflights 0.9x	1	x	2.5	x	150	x	0.55	x	0.8	=	148.5	(82)
Rooflights 0.9x	1	x	3.61	x	150	x	0.55	x	0.8	=	428.87	(82)
Rooflights 0.9x	1	x	2.5	x	192	x	0.55	x	0.8	=	190.08	(82)
Rooflights 0.9x	1	x	2.5	x	192	x	0.55	x	0.8	=	190.08	(82)
Rooflights 0.9x	1	x	3.61	x	192	x	0.55	x	0.8	=	548.95	(82)
Rooflights 0.9x	1	x	2.5	x	200	x	0.55	x	0.8	=	198	(82)
Rooflights 0.9x	1	x	2.5	x	200	x	0.55	x	0.8	=	198	(82)
Rooflights 0.9x	1	x	3.61	x	200	x	0.55	x	0.8	=	571.82	(82)
Rooflights 0.9x	1	x	2.5	x	189	x	0.55	x	0.8	=	187.11	(82)
Rooflights 0.9x	1	x	2.5	x	189	x	0.55	x	0.8	=	187.11	(82)
Rooflights 0.9x	1	x	3.61	x	189	x	0.55	x	0.8	=	540.37	(82)
Rooflights 0.9x	1	x	2.5	x	157	x	0.55	x	0.8	=	155.43	(82)
Rooflights 0.9x	1	x	2.5	x	157	x	0.55	x	0.8	=	155.43	(82)
Rooflights 0.9x	1	x	3.61	x	157	x	0.55	x	0.8	=	448.88	(82)
Rooflights 0.9x	1	x	2.5	x	115	x	0.55	x	0.8	=	113.85	(82)
Rooflights 0.9x	1	x	2.5	x	115	x	0.55	x	0.8	=	113.85	(82)
Rooflights 0.9x	1	x	3.61	x	115	x	0.55	x	0.8	=	328.8	(82)
Rooflights 0.9x	1	x	2.5	x	66	x	0.55	x	0.8	=	65.34	(82)
Rooflights 0.9x	1	x	2.5	x	66	x	0.55	x	0.8	=	65.34	(82)
Rooflights 0.9x	1	x	3.61	x	66	x	0.55	x	0.8	=	188.7	(82)
Rooflights 0.9x	1	x	2.5	x	33	x	0.55	x	0.8	=	32.67	(82)
Rooflights 0.9x	1	x	2.5	x	33	x	0.55	x	0.8	=	32.67	(82)
Rooflights 0.9x	1	x	3.61	x	33	x	0.55	x	0.8	=	94.35	(82)
Rooflights 0.9x	1	x	2.5	x	21	x	0.55	x	0.8	=	20.79	(82)
Rooflights 0.9x	1	x	2.5	x	21	x	0.55	x	0.8	=	20.79	(82)
Rooflights 0.9x	1	x	3.61	x	21	x	0.55	x	0.8	=	60.04	(82)

Solar gains in watts, calculated for each month

(83)m = Sum(74)m (82)m

(83)m= 602.63 1080.36 1603.42 2167.51 2571.73 2610.82 2493.52 2186.85 1799.93 1229.51 732.05 508.87 (83)

Total gains – internal and solar (84)m = (73)m + (83)m , watts

(84)m= 1194.44 1669.88 2171.84 2701.12 3068.53 3072.52 2933.55 2634.35 2265.91 1730.55 1273.47 1081.95 (84)

7. Mean internal temperature (heating season)

Temperature during heating periods in the living area from Table 9, Th1 (°C)

21 (85)

Utilisation factor for gains for living area, h1,m (see Table 9a)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

DER WorkSheet: New dwelling design stage

(86)m=	1	0.99	0.97	0.89	0.73	0.53	0.39	0.45	0.72	0.96	1	1	(86)
--------	---	------	------	------	------	------	------	------	------	------	---	---	------

Mean internal temperature in living area T1 (follow steps 3 to 7 in Table 9c)

(87)m=	19.62	19.89	20.26	20.67	20.91	20.98	21	20.99	20.93	20.55	19.99	19.58	(87)
--------	-------	-------	-------	-------	-------	-------	----	-------	-------	-------	-------	-------	------

Temperature during heating periods in rest of dwelling from Table 9, Th2 (°C)

(88)m=	19.91	19.91	19.91	19.93	19.93	19.94	19.94	19.94	19.93	19.92	19.92	(88)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Utilisation factor for gains for rest of dwelling, h2,m (see Table 9a)

(89)m=	1	0.99	0.96	0.86	0.66	0.45	0.3	0.35	0.64	0.94	0.99	1	(89)
--------	---	------	------	------	------	------	-----	------	------	------	------	---	------

Mean internal temperature in the rest of dwelling T2 (follow steps 3 to 7 in Table 9c)

(90)m=	18.07	18.46	19	19.56	19.85	19.93	19.94	19.94	19.89	19.42	18.61	18.01	(90)
--------	-------	-------	----	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

fLA = Living area ÷ (4) =	0.27	(91)
---------------------------	------	------

Mean internal temperature (for the whole dwelling) = fLA × T1 + (1 – fLA) × T2

(92)m=	18.48	18.84	19.34	19.86	20.13	20.21	20.22	20.22	20.17	19.72	18.98	18.43	(92)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

Apply adjustment to the mean internal temperature from Table 4e, where appropriate

(93)m=	18.33	18.69	19.19	19.71	19.98	20.06	20.07	20.07	20.02	19.57	18.83	18.28	(93)
--------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	-------	------

8. Space heating requirement

Set Ti to the mean internal temperature obtained at step 11 of Table 9b, so that Ti,m=(76)m and re-calculate the utilisation factor for gains using Table 9a

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Utilisation factor for gains, hm:

(94)m=	1	0.99	0.95	0.85	0.67	0.46	0.31	0.36	0.65	0.93	0.99	1	(94)
--------	---	------	------	------	------	------	------	------	------	------	------	---	------

Useful gains, hmGm, W = (94)m x (84)m

(95)m=	1191.22	1649.89	2074.03	2301.41	2043.75	1403.48	901.29	948.77	1462.89	1610.34	1263.66	1080.1	(95)
--------	---------	---------	---------	---------	---------	---------	--------	--------	---------	---------	---------	--------	------

Monthly average external temperature from Table 8

(96)m=	4.3	4.9	6.5	8.9	11.7	14.6	16.6	16.4	14.1	10.6	7.1	4.2	(96)
--------	-----	-----	-----	-----	------	------	------	------	------	------	-----	-----	------

Heat loss rate for mean internal temperature, Lm, W = [(39)m x [(93)m – (96)m]

(97)m=	3770.88	3696.46	3391.48	2853.83	2180.64	1420.5	903.13	952.72	1546.44	2361.82	3105.13	3745.9	(97)
--------	---------	---------	---------	---------	---------	--------	--------	--------	---------	---------	---------	--------	------

Space heating requirement for each month, kWh/month = 0.024 x [(97)m – (95)m] x (41)m

(98)m=	1919.26	1375.3	980.18	397.75	101.84	0	0	0	0	559.1	1325.86	1983.36	(98)
--------	---------	--------	--------	--------	--------	---	---	---	---	-------	---------	---------	------

Total per year (kWh/year) = Sum(98) _{1...5,9...12} =	8642.66	(98)
---	---------	------

Space heating requirement in kWh/m²/year

39.03	(99)
-------	------

8c. Space cooling requirement

Calculated for June, July and August. See Table 10b

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

Heat loss rate Lm (calculated using 25°C internal temperature and external temperature from Table 10)

(100)m=	0	0	0	0	0	2443.45	1923.56	1970.43	0	0	0	0	(100)
---------	---	---	---	---	---	---------	---------	---------	---	---	---	---	-------

Utilisation factor for loss hm

(101)m=	0	0	0	0	0	0.95	0.97	0.96	0	0	0	0	(101)
---------	---	---	---	---	---	------	------	------	---	---	---	---	-------

Useful loss, hmLm (Watts) = (100)m x (101)m

(102)m=	0	0	0	0	0	2310.73	1872.35	1887.73	0	0	0	0	(102)
---------	---	---	---	---	---	---------	---------	---------	---	---	---	---	-------

Gains (solar gains calculated for applicable weather region, see Table 10)

(103)m=	0	0	0	0	0	3565.88	3409.05	3088.06	0	0	0	0	(103)
---------	---	---	---	---	---	---------	---------	---------	---	---	---	---	-------

Space cooling requirement for month, whole dwelling, continuous (kWh) = 0.024 x [(103)m – (102)m] x (41)m

set (104)m to zero if (104)m < 3 × (98)m

(104)m=	0	0	0	0	0	903.7	1143.3	893.05	0	0	0	0	(104)
---------	---	---	---	---	---	-------	--------	--------	---	---	---	---	-------

Total = Sum(104) =	2940.05	(104)
--------------------	---------	-------

DER WorkSheet: New dwelling design stage

Cooled fraction $f_C = \text{cooled area} \div (4) =$ 0.72 (105)

Intermittency factor (Table 10b)

(106)m=

0	0	0	0	0	0.25	0.25	0.25	0	0	0	0
---	---	---	---	---	------	------	------	---	---	---	---

 $Total = \text{Sum}(104) =$ 0 (106)

Space cooling requirement for month = (104)m × (105) × (106)m

(107)m=

0	0	0	0	0	162.89	206.08	160.97	0	0	0	0
---	---	---	---	---	--------	--------	--------	---	---	---	---

 $Total = \text{Sum}(107) =$ 529.95 (107)

Space cooling requirement in kWh/m²/year $(107) \div (4) =$ 2.39 (108)

9a. Energy requirements – Individual heating systems including micro-CHP

Space heating:

Fraction of space heat from secondary/supplementary system 0 (201)

Fraction of space heat from main system(s) $(202) = 1 - (201) =$ 1 (202)

Fraction of total heating from main system 1 $(204) = (202) \times [1 - (203)] =$ 1 (204)

Efficiency of main space heating system 1 93.3 (206)

Efficiency of secondary/supplementary heating system, % 0 (208)

Cooling System Energy Efficiency Ratio 4.32 (209)

Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	kWh/year
-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	----------

Space heating requirement (calculated above)

(211)m = $\{[(98)m \times (204)]\} \times 100 \div (206)$ (211)

1919.26	1375.3	980.18	397.75	101.84	0	0	0	0	559.1	1325.86	1983.36
---------	--------	--------	--------	--------	---	---	---	---	-------	---------	---------

$Total \text{ (kWh/year)} = \text{Sum}(211)_{1..5,10..12} =$ 9263.3 (211)

Space heating fuel (secondary), kWh/month
 = $\{[(98)m \times (201)]\} \times 100 \div (208)$

(215)m=

0	0	0	0	0	0	0	0	0	0	0	0
---	---	---	---	---	---	---	---	---	---	---	---

 $Total \text{ (kWh/year)} = \text{Sum}(215)_{1..5,10..12} =$ 0 (215)

Water heating

Output from water heater (calculated above)

224.13	197.48	207.25	185.57	181.59	159.94	153.23	170.82	170.71	192.44	203.75	218.67
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

Efficiency of water heater 81 (216)

(217)m=

89.23	89.02	88.53	87.12	84.11	81	81	81	81	87.72	88.94	89.28
-------	-------	-------	-------	-------	----	----	----	----	-------	-------	-------

(217)

Fuel for water heating, kWh/month

(219)m = (64)m × 100 ÷ (217)m

(219)m=

251.19	221.85	234.11	213.01	215.89	197.45	189.18	210.89	210.76	219.38	229.09	244.92
--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------	--------

 $Total = \text{Sum}(219a)_{1..12} =$ 2637.71 (219)

Space cooling fuel, kWh/month.

(221)m = (107)m ÷ (209)

(221)m=

0	0	0	0	0	37.71	47.7	37.26	0	0	0	0
---	---	---	---	---	-------	------	-------	---	---	---	---

 $Total = \text{Sum}(221)_{6..8} =$ 122.67 (221)

Annual totals

Space heating fuel used, main system 1

kWh/year

kWh/year

9263.3

Water heating fuel used

2637.71

Space cooling fuel used

122.67

DER WorkSheet: New dwelling design stage

Electricity for pumps, fans and electric keep-hot

mechanical ventilation - balanced, extract or positive input from outside

508.21 (230a)

central heating pump:

30 (230c)

Total electricity for the above, kWh/year

sum of (230a) (230g) = 538.21 (231)

Electricity for lighting

615.59 (232)

Electricity generated by PVs

-2486.81 (233)

12a. CO2 emissions – Individual heating systems including micro-CHP

	Energy kWh/year	Emission factor kg CO2/kWh	Emissions kg CO2/year
Space heating (main system 1)	(211) x	0.216 =	2000.87 (261)
Space heating (secondary)	(215) x	0.519 =	0 (263)
Water heating	(219) x	0.216 =	569.75 (264)
Space and water heating	(261) + (262) + (263) + (264) =		2570.62 (265)
Space cooling	(221) x	0.519 =	63.67 (266)
Electricity for pumps, fans and electric keep-hot	(231) x	0.519 =	279.33 (267)
Electricity for lighting	(232) x	0.519 =	319.49 (268)
Energy saving/generation technologies Item 1		0.519 =	-1290.66 (269)
Total CO2, kg/year		sum of (265) (271) =	1942.45 (272)
Dwelling CO2 Emission Rate		(272) ÷ (4) =	8.77 (273)
EI rating (section 14)			90 (274)