

## Project name

**CST\_06**

After Energy Demand Reduction

As designed

Date: Sun Oct 18 22:13:06 2015

## Administrative information

## Building Details

Address: Address 1, City, Postcode

## Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.4

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.4

BRUKL compliance check version: v5.2.d.2

## Owner Details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

## Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Criterion 1: The calculated CO<sub>2</sub> emission rate for the building should not exceed the target

CO <sub>2</sub> emission rate from the notional building, kgCO <sub>2</sub> /m <sup>2</sup> .annum	21.6
Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	21.6
Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	19.3
Are emissions from the building less than or equal to the target?	BER =< TER
Are as built details the same as used in the BER calculations?	Separate submission

## Criterion 2: The performance of the building fabric and the building services should achieve reasonable overall standards of energy efficiency

Values not achieving standards in the Non-Domestic Building Services Compliance Guide and Part L are displayed in red.

## Building fabric

Element	U <sub>a</sub> -Limit	U <sub>a</sub> -Calc	U <sub>i</sub> -Calc	Surface where the maximum value occurs*
Wall**	0.35	0.1	0.1	PL000003:Surf[0]
Floor	0.25	0.09	0.1	PL000003:Surf[4]
Roof	0.25	0.12	0.12	CR000000:Surf[1]
Windows***, roof windows, and rooflights	2.2	1.31	1.64	NR000005:Surf[1]
Personnel doors	2.2	1.72	1.72	PL000003:Surf[2]
Vehicle access & similar large doors	1.5	-	-	No Vehicle access doors in building
High usage entrance doors	3.5	-	-	No High usage entrance doors in building
U <sub>a</sub> -Limit = Limiting area-weighted average U-values [W/(m <sup>2</sup> K)] U <sub>a</sub> -Calc = Calculated area-weighted average U-values [W/(m <sup>2</sup> K)] U <sub>i</sub> -Calc = Calculated maximum individual element U-values [W/(m <sup>2</sup> K)]				
* There might be more than one surface where the maximum U-value occurs.				
** Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.				
*** Display windows and similar glazing are excluded from the U-value check.				
N.B.: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.				

Air Permeability	Worst acceptable standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	10	3

## Building services

The standard values listed below are minimum values for efficiencies and maximum values for SFPs. Refer to the Non-Domestic Building Services Compliance Guide for details.

<b>Whole building lighting automatic monitoring &amp; targeting with alarms for out-of-range values</b>	YES
<b>Whole building electric power factor achieved by power factor correction</b>	>0.95

### 1- Gas Boilers : Nat Vent

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.91	-	0.2	0	-
<b>Standard value</b>	0.91*	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					NO
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

### 2- Gas Boilers : MVHR

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	0.91	-	0.2	0	0.8
<b>Standard value</b>	0.91*	N/A	N/A	N/A	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					NO
* Standard shown is for gas single boiler systems <=2 MW output. For single boiler systems >2 MW or multi-boiler systems, (overall) limiting efficiency is 0.86. For any individual boiler in a multi-boiler system, limiting efficiency is 0.82.					

"No HWS in project, or hot water is provided by HVAC system"

"No zones in project where local mechanical ventilation, exhaust, or terminal unit is applicable"

General lighting and display lighting	Luminous efficacy [lm/W]			General lighting [W]
	Luminaire	Lamp	Display lamp	
<b>Zone name</b>				
<b>Standard value</b>	60	60	22	
Common Plant	58	-	-	109
Common Plant	55	-	-	60
CPF Entrance	-	74	-	37
CPF Hall	-	80	-	1179
CPF Office	55	-	-	76
CPF Reading	50	-	-	110
CPF Reception	88	-	-	39
CPF Snug	-	80	-	313
CPF Staff	43	-	-	90
CPF Staff Corridor	-	68	-	27
CPF Stair	-	120	-	8
CPF Stair	-	122	-	14
CPF WC	-	82	-	25
CPF WC	-	86	-	21
CPF WC	-	84	-	24
CPF WC	-	83	-	23
CPF WC	-	95	-	16
Housing Entrance	-	81	-	106
Housing Lift	-	154	-	21
MUGA Change	-	96	-	66

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name	Standard value	Luminaire	Lamp	Display lamp	
	60	60	60	22	
MUGA Change	-	-	97	-	67
MUGA Lift	-	-	164	-	22
MUGA Lift	-	-	84	-	22
MUGA Lobby	-	-	69	-	53
MUGA Stair	-	-	97	-	60
MUGA Stair	-	-	67	-	60
MUGA WC	-	-	95	-	16
Nursery Kitchen Corridor	-	-	66	-	125
Nursery Kitchenette	-	-	69	-	67
Nursery Office	-	44	-	-	79
Nursery Parents	-	43	-	-	70
Nursery WC	-	-	134	-	27
Nursery WC	-	-	106	-	42
CPF Plant	-	61	-	-	27
Nursery	-	-	85	-	432
Nursery Lobby	-	-	86	-	55
Nursery Group	-	52	-	-	107
Nursery Staff	-	48	-	-	96

**Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains**

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
CPF Hall	NO (-29.9%)	YES
CPF Office	NO (-10.3%)	YES
CPF Reading	NO (-38.9%)	YES
CPF Reception	NO (-78.9%)	NO
CPF Snug	NO (-71.7%)	NO
CPF Staff	NO (-72.6%)	NO
MUGA Change	N/A	N/A
MUGA Change	N/A	N/A
Nursery Office	NO (-77.7%)	NO
Nursery Parents	NO (-50.7%)	NO
Nursery	NO (-58.2%)	YES
Nursery Group	NO (-46.6%)	YES
Nursery Staff	NO (-71.5%)	YES

**Criterion 4: The performance of the building, as built, should be consistent with the calculated BER**

Separate submission

**Criterion 5: The necessary provisions for enabling energy-efficient operation of the building should be in place**

Separate submission

## EPBD (Recast): Consideration of alternative energy systems

<b>Were alternative energy systems considered and analysed as part of the design process?</b>	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES



# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

	Actual	Notional
Area [m <sup>2</sup> ]	702	702
External area [m <sup>2</sup> ]	2076.5	2076.5
Weather	LON	LON
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	3	3
Average conductance [W/K]	458.79	817.06
Average U-value [W/m <sup>2</sup> K]	0.22	0.39
Alpha value* [%]	9.48	10

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

### % Area Building Type

A1/A2 Retail/Financial and Professional services  
 A3/A4/A5 Restaurants and Cafes/Drinking Est./Takeaways  
 B1 Offices and Workshop businesses  
 B2 to B7 General Industrial and Special Industrial Groups  
 B8 Storage or Distribution  
 C1 Hotels  
 C2 Residential Inst.: Hospitals and Care Homes  
 C2 Residential Inst.: Residential schools  
 C2 Residential Inst.: Universities and colleges  
 C2A Secure Residential Inst.  
 Residential spaces

### 100 D1 Non-residential Inst.: Community/Day Centre

D1 Non-residential Inst.: Libraries, Museums, and Galleries  
 D1 Non-residential Inst.: Education  
 D1 Non-residential Inst.: Primary Health Care Building  
 D1 Non-residential Inst.: Crown and County Courts  
 D2 General Assembly and Leisure, Night Clubs and Theatres  
 Others: Passenger terminals  
 Others: Emergency services  
 Others: Miscellaneous 24hr activities  
 Others: Car Parks 24 hrs  
 Others - Stand alone utility block

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	56.37	65.84
Cooling	0	0
Auxiliary	3	1.12
Lighting	8.31	11.92
Hot water	6.44	3.77
Equipment*	23.14	23.14
<b>TOTAL**</b>	<b>74.12</b>	<b>82.66</b>

\* Energy used by equipment does not count towards the total for calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	0	0
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	140.01	204.34
Primary energy* [kWh/m <sup>2</sup> ]	110.49	123.98
Total emissions [kg/m <sup>2</sup> ]	19.3	21.6

\* Primary energy is net of any electrical energy displaced by CHP generators, if applicable.

## HVAC Systems Performance

System Type	Heat dem MJ/m <sup>2</sup>	Cool dem MJ/m <sup>2</sup>	Heat con kWh/m <sup>2</sup>	Cool con kWh/m <sup>2</sup>	Aux con kWh/m <sup>2</sup>	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER
<b>[ST] Central heating using water: floor heating, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
<b>Actual</b>	19.3	0	7.8	0	7.9	0.69	0	0.91	0
<b>Notional</b>	53.4	0	17.2	0	3.7	0.86	0	----	----
<b>[ST] Central heating using water: floor heating, [HS] LTHW boiler, [HFT] Natural Gas, [CFT] Electricity</b>									
<b>Actual</b>	148.9	0	60	0	1.6	0.69	0	0.91	0
<b>Notional</b>	215.5	0	69.4	0	0.9	0.86	0	----	----

### Key to terms

Heat dem [MJ/m <sup>2</sup> ]	= Heating energy demand
Cool dem [MJ/m <sup>2</sup> ]	= Cooling energy demand
Heat con [kWh/m <sup>2</sup> ]	= Heating energy consumption
Cool con [kWh/m <sup>2</sup> ]	= Cooling energy consumption
Aux con [kWh/m <sup>2</sup> ]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type

# Key Features

The BCO can give particular attention to items with specifications that are better than typically expected.

## Building fabric

Element	U <sub>i-Typ</sub>	U <sub>i-Min</sub>	Surface where the minimum value occurs*
Wall	0.23	0.1	PL000003:Surf[0]
Floor	0.2	0.08	NR000000E:Surf[0]
Roof	0.15	0.12	PL000003:Surf[1]
Windows, roof windows, and rooflights	1.5	1.31	CP000000:Surf[2]
Personnel doors	1.5	1.72	PL000003:Surf[2]
Vehicle access & similar large doors	1.5	-	No Vehicle access doors in building
High usage entrance doors	1.5	-	No High usage entrance doors in building
U <sub>i-Typ</sub> = Typical individual element U-values [W/(m <sup>2</sup> K)]		U <sub>i-Min</sub> = Minimum individual element U-values [W/(m <sup>2</sup> K)]	
* There might be more than one surface where the minimum U-value occurs.			

Air Permeability	Typical value	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	5	3