

Mrs Leonie Oliva  
Deloitte LLP  
Athene Place  
66 Shoe Lane  
London  
EC4A 3BQ

Application Ref: **2015/4180/P**  
Please ask for: **Jennifer Chivers**  
Telephone: 020 7974 **3303**

18 November 2015

Dear Sir/Madam

## **DECISION**

Town and Country Planning Act 1990 (as amended)

### **Full Planning Permission Granted**

Address:  
**21 Bedford Square**  
**London**  
**WC1B 3HH**

Proposal:

Restoration of two chimneys and repairs to roof. Installation of new external plant including 6 x roof mounted condenser units and 1 x AC Unit in central lightwell.

Drawing Nos: 21-LP1; 21-D05; 21-D06; 21-D07; 21-D08; 21-D09; 21-E05; 21-E06; 21-E07; 21-E08; 21-E09; 21-P05; 21-P06A; 21-P07A; 21-P08A; 21-P09B; 21-DT00A; 21-D00; 21-D01; 21-D02; 21-D03; 21-D04; 21-E000; 21-E00; 21-E01; 21-E02; 21-E03; 21-E04; 21-P000A; 21-P00; 21-P01; 21-P02; 21-P03; 21-P04A.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).



- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Core Strategy and policies DP24 and DP25 of the London Borough of Camden Local Development Framework Development Policies.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans

21-LP1; 21-D06; 21-D07; 21-D08; 21-D09; 21-E05; 21-E06; 21-E07; 21-E08; 21-E09; 21-P05; 21-P06A; 21-P07A; 21-P08A; 21-P09B; 21-DT00A; 21-D00; 21-D01; 21-D02; 21-D03; 21-D04; 21-E000; 21-E00; 21-E01; 21-E02; 21-E03; 21-E04; 21-P000A; 21-P00; 21-P01; 21-P02; 21-P03; 21-P04A.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 4 Before the use commences, details shall be submitted to and approved in writing by the Council, of the external noise levels emitted from the plant equipment and noise reduction mitigation measures as stated in report ref: AS8239.150429.NIA1.1, dated 17th July 2015. The measures shall ensure that the external noise levels emitted from plant equipment will be lower than the lowest existing background noise level by at least 10dBA as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity. Approved details shall be implemented prior to use of the plant/equipment and thereafter be permanently retained.

Reason: To ensure that the amenity of occupiers of the development site/ surrounding premises is not adversely affected by noise from plant/mechanical installations/ equipment.

#### Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public

Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

You can find advice about your rights of appeal at:

<http://www.planningportal.gov.uk/planning/appeals/guidance/guidancecontent>

Yours faithfully

A handwritten signature in black ink, appearing to read 'Ed Watson', written in a cursive style.

Ed Watson  
Director of Culture & Environment