


Reproduced from the Ordnance Survey Map with permission of the controller of Her Majesty's Stationery Office. Crown Copyright. Licence No: 0100040692



Centre of Map Window (E.N): 525594, 184826

WEST END LANE	
Plot Scale	1:1156
Plot Date	13/1/2016
	

Output Created from the GI Portal - A4 Landscape

From: Chug, Josleen
Sent: 18 January 2016 13:45
To: Planning
Subject: FW: Ref 2015/6455/P - redevelopment of 156 West End Lane, London
Attachments: West End Lane GI Portal plan.pdf; ATT00001.txt

Could you log this consultation response for 2015/6455/P please?

Thanks

Josleen Chug
Principal Planning Officer
[REDACTED]
Telephone: 02079744672

We want to hear your views on the changes we are proposing to how we consult on planning applications. To find out more and have your say visit www.camden.gov.uk/sci. Consultation closes on the 20 January 2016.

From: Leighton Matthew [mailto:[REDACTED]]
Sent: 14 January 2016 13:35
To: Chug, Josleen
Subject: Ref 2015/6455/P - redevelopment of 156 West End Lane, London

FAO – Josleen Chug
Ref – 2015/6455/P

Proposal – Comprehensive redevelopment following demolition of all existing buildings to provide 164 self-contained residential dwelling (Class C3), 891sqm of flexible non-residential use (Class A-A3, D1, D2), 889sqm of employment floorspace (Class B1) and 63sqm of community space (Class D1)
Location – 156 West End Lane, London, NW6 1SD

Thank you for your letter of 27 November 2015 providing Network Rail with an opportunity to comment on the abovementioned application.

With reference to the protection of the railway, Network Rail has no objection in principle to the development, but below are some requirements which must be met, especially with the close proximity to the development of an electrified railway.

Land in Network Rail Ownership

With reference to the protection of the railway, Network Rail has no objection in principle to a development of this type at this location but cannot support the proposals in the current format. This is because the development as proposed appears to be partly located on an area of land still in the ownership of Network Rail. The attached plan shows the land in Network Rails ownership (shaded green).

It is therefore appropriate that the applicant re-submit the redline plan showing the correct boundary or contact Network Rail at landinformation@networkrail.co.uk to discuss the boundary issue and reach agreement if they have not already done so.

The following are requirements which must be met when considering this type of development at this location.

Drainage

All surface and foul water arising from the proposed works must be collected and diverted away from Network Rail property. In the absence of detailed plans all soakaways must be located so as to discharge away from the railway infrastructure. The following points need to be addressed:

1. There should be no increase to average or peak flows of surface water run off leading towards Network Rail assets, including earthworks, bridges and culverts.
2. All surface water run off and sewage effluent should be handled in accordance with Local Council and Water Company regulations.
3. Attenuation should be included as necessary to protect the existing surface water drainage systems from any increase in average or peak loadings due to normal and extreme rainfall events.

It is expected that the preparation and implementation of a surface water drainage strategy addressing the above points will be conditioned as part of any approval.

Fail Safe Use of Crane and Plant

All operations, including the use of cranes or other mechanical plant working adjacent to Network Rail's property, must at all times be carried out in a "fail safe" manner such that in the event of mishandling, collapse or failure, no materials or plant are capable of falling within 3.0m of the nearest rail of the adjacent railway line, or where the railway is electrified, within 3.0m of overhead electrical equipment or supports.

Excavations/Earthworks

All excavations/ earthworks carried out in the vicinity of Network Rail property/ structures must be designed and executed such that no interference with the integrity of that property/ structure can occur. If temporary works compounds are to be located adjacent to the operational railway, these should be included in a method statement for approval by Network Rail. Prior to commencement of works, full details of excavations and earthworks to be carried out near the railway undertaker's boundary fence should be submitted for the approval of the Local Planning Authority acting in consultation with the railway undertaker and the works shall only be carried out in accordance with the approved details. Where development may affect the railway, consultation with the Asset Protection Project Manager should be undertaken. Network Rail will not accept any liability for any settlement, disturbance or damage caused to any development by failure of the railway infrastructure nor for any noise or vibration arising from the normal use and/or maintenance of the operational railway. No right of support is given or can be claimed from Network Rail's infrastructure or railway land.

Security of Mutual Boundary

Security of the railway boundary will need to be maintained at all times. If the works require temporary or permanent alterations to the mutual boundary the applicant must contact Network Rail's Asset Protection Project Manager.

Fencing

Although the existing NR fence is adequate in preventing trespass there will inevitably be pressure from the new residents to soften or even attempt to alter its appearance. It should be noted that our fence should not be altered or moved in any way and nothing should be put in place to prevent us from maintaining our boundary fence as we are obliged to do so in law. It is our experience that most developments seek to provide their own boundary enclosure so as to avoid such future problems. It would also help to reduce the impact of railway noise. We would advise that the developer should provide a trespass proof fence adjacent to Network Rail's boundary (minimum 1.8m high) and make provision for its future maintenance and renewal. Network Rail's existing fencing / wall must not be removed or damaged.

Method Statements/Fail Safe/Possessions

Method statements may require to be submitted to Network Rail's Asset Protection Project Manager at the below address for approval prior to works commencing on site. This should include an outline of the proposed method of construction, risk assessment in relation to the railway and construction traffic management plan. Where appropriate an asset protection agreement will have to be entered into. Where any works cannot be carried out in a "fail-safe" manner, it will be necessary to restrict those works to periods when the railway is closed to rail traffic i.e. "possession" which must be booked via Network Rail's Asset Protection Project Manager and are subject to a minimum prior notice period for booking of 20 weeks. **Generally if excavations/piling/buildings are to be located within 10m of the railway boundary a method statement should be submitted for NR approval.**

OPE

Once planning permission has been granted and at least six weeks prior to works commencing on site the Asset Protection Project Manager (OPE) MUST be contacted, contact details as below. The OPE will require to see any method statements/drawings relating to any excavation, drainage, demolition, lighting and building work or any works to be carried out on site that may affect the safety, operation, integrity and access to the railway.

Demolition

Any demolition or refurbishment works must not be carried out on the development site that may endanger the safe operation of the railway, or the stability of the adjoining Network Rail structures. The demolition of buildings or other structures near to the operational railway infrastructure must be carried out in accordance with an agreed method statement. Approval of the method statement must be obtained from Network Rail's Asset Protection Project Manager before the development can commence.

Vibro-impact Machinery

Where vibro-compaction machinery is to be used in development, details of the use of such machinery and a method statement should be submitted for the approval of the Local Planning Authority acting in consultation with the railway undertaker prior to the commencement of works and the works shall only be carried out in accordance with the approved method statement

Scaffolding

Any scaffold which is to be constructed within 10 metres of the railway boundary fence must be erected in such a manner that at no time will any poles over-sail the railway and protective netting around such scaffold must be installed.

Abnormal Loads

From the information supplied, it is not clear if any abnormal loads will be using routes that include any Network Rail assets (e.g. bridges). We would have serious reservations if during the construction or operation of the site, abnormal loads will use routes that include Network Rail assets. Network Rail would request that the applicant contact our Asset Protection Project Manager to confirm that any proposed route is viable and to agree a strategy to protect our asset(s) from any potential damage caused by abnormal loads. I would also like to advise that where any damage, injury or delay to the rail network is caused by an abnormal load (related to the application site), the applicant or developer will incur full liability.

Cranes

With a development of a certain height that may/will require use of a crane, the developer must bear in mind the following. Crane usage adjacent to railway infrastructure is subject to stipulations on size, capacity etc. which needs to be agreed by the Asset Protection Project Manager prior to implementation.

Two Metre Boundary

Consideration should be given to ensure that the construction and subsequent maintenance can be carried out to any proposed buildings or structures without adversely affecting the safety of, or encroaching upon Network Rail's adjacent land, and therefore all/any building should be situated at least 2 metres from Network Rail's boundary. This will allow construction and future maintenance to be carried out from the applicant's land, thus reducing the probability of provision and costs of railway look-out protection, supervision and other facilities necessary when working from or on railway land.

ENCROACHMENT

The developer/applicant must ensure that their proposal, both during construction, and after completion of works on site, does not affect the safety, operation or integrity of the operational railway, Network Rail and its infrastructure or undermine or damage or adversely affect any railway land and structures. There must be no physical encroachment of the proposal onto Network Rail land, no over-sailing into Network Rail air-space and no encroachment of foundations onto Network Rail land and soil. There must be no physical encroachment of any foundations onto Network Rail land. Any future maintenance must be conducted solely within the applicant's land ownership. Should the applicant require access to Network Rail land then must seek approval from the Network Rail Asset Protection Team. Any unauthorised access to Network Rail land or air-space is an act of trespass and we would remind the council that this is a criminal offence (**s55 British Transport Commission Act 1949**). Should the applicant be granted access to Network Rail land then they will be liable for all costs incurred in facilitating the proposal.

Noise/Soundproofing

The Developer should be aware that any development for residential use adjacent to an operational railway may result in neighbour issues arising. Consequently every endeavour should be made by the developer to provide adequate soundproofing for each dwelling. Please note that in a worst case scenario there could be trains running 24 hours a day and the soundproofing should take this into account.

Trees/Shrubs/Landscaping

Having reviewed the landscaping proposals, there do not appear to be any areas of concern for Network Rail. However, if the plans were to be altered we would advise the developer of the following requirement: Where trees/shrubs are to be planted adjacent to the railway boundary these shrubs should be positioned at a minimum distance greater than their predicted mature height from the boundary. Certain broad leaf deciduous species should not be planted adjacent to the railway boundary. We would wish to be involved in the approval of any landscaping

scheme adjacent to the railway. Where landscaping is proposed as part of an application adjacent to the railway it will be necessary for details of the landscaping to be known and approved to ensure it does not impact upon the railway infrastructure. Any hedge planted adjacent to Network Rail's boundary fencing for screening purposes should be so placed that when fully grown it does not damage the fencing or provide a means of scaling it. No hedge should prevent Network Rail from maintaining its boundary fencing. Lists of trees that are permitted and those that are not permitted are provided below and these should be added to any tree planting conditions:

Acceptable:

Birch (Betula), Crab Apple (Malus Sylvestris), Field Maple (Acer Campestre), Bird Cherry (Prunus Padus), Wild Pear (Pyrs Communis), Fir Trees – Pines (Pinus), Hawthorne (Cretaegus), Mountain Ash – Whitebeams (Sorbus), False Acacia (Robinia), Willow Shrubs (Shrubby Salix), Thuja Plicatata "Zebrina"

Not Acceptable:

Acer (Acer pseudoplatanus), Aspen – Poplar (Populus), Small-leaved Lime (Tilia Cordata), Sycamore – Norway Maple (Acer), Horse Chestnut (Aesculus Hippocastanum), Sweet Chestnut (Castanea Sativa), Ash (Fraxinus excelsior), Black poplar (Populus nigra var, betulifolia), Lombardy Poplar (Populus nigra var, italica), Large-leaved lime (Tilia platyphyllos), Common lime (Tilia x europea)

A comprehensive list of permitted tree species is available upon request.

Lighting

Where new lighting is to be erected adjacent to the operational railway the potential for train drivers to be dazzled must be eliminated. In addition the location and colour of lights must not give rise to the potential for confusion with the signalling arrangements on the railway. Detail of any external lighting should be provided as a condition if not already indicated on the application.

Network Rail is required to recover all reasonable costs associated with facilitating these works.

I would advise that in particular the **drainage, boundary fencing, method statements, soundproofing, lighting and landscaping** should be the subject of conditions, the reasons for which can include the safety, operational needs and integrity of the railway. For the other matters we would be pleased if an informative could be attached to the decision notice.

I trust full cognisance will be taken in respect of these comments. If you have any further queries or require clarification of any aspects, please do not hesitate to contact myself I would also be grateful if you could inform me of the outcome of this application, forwarding a copy of the Decision Notice to me in due course.

The method statement will need to be agreed with:

**Asset Protection Project Manager
Network Rail (London North Eastern)
Floor 2A
George Stephenson House
Toft Green
York
Y01 6JT**

Email: assetprotectionlneem@networkrail.co.uk

Kind regards,

Matt Leighton

Town Planning Technician | Property
Network Rail
George Stephenson House | Toft Green | York | YO1 6JT

www.networkrail.co.uk/property

