

L30 Ballustrade

Refer to: 1221\_Z3-711

F30 Pre-cast brick coping. By Manchester Pre-cast or similar. Angled to falls w/drip detail

J41 - Bauder Capping sheet

F10 Floren Pallas facing brickwork

F30 50mm min. cavity

F30 60mm Kooltherm K12 Rigid Insulation

150mm RC Concrete Upstand

F30 Brick ties to SE spec.

J41 30mm Bauder PIR Insulation

Timber Cladding

Timber Cladding

J41 Bauder VB4 Expal

F30 Proprietary BBA approved Cavity tray with stop ends over air vent dressed into internal leaf and discharging through open perp end in external leaf

Q55 Optima Decking

Q55 Support battens

J41 Bauder pedestal supports

F30 Brick Shelf support to SE spec.

Outlet to RWP

J41 Bauder zero falls gutter

J41 160mm Bauder PIR Insulation

J41 Bauder VB4 Expal

Slab laid to 1in60 falls

R10 Alumasc non standard hopper head

R10 downpipe

150mm

945mm

250mm

100mm

150mm

01 Devonshire Upper Deck Details  
621 xxx



0m 50mm 250mm

Notes:

To be read in conjunction with:  
1211\_Z3-271  
Structural Engineers drawings

REVISION	DATE	AMENDMENT
D	18.12.15	ISSUED FOR PLANNING
C	XX.12.15	CONDITION DISCHARGE STRUCTURE UPDATED TO INCLUDE UPSTAND
B	03.12.15	PACKAGE ISSUED FOLLOWING CLIENT COMMENTS AND DEVELOPMENT
A	27.11.12	PACKAGE 4 TENDER ISSUE
/	15.11.12	ISSUED FOR TENDER

DO NOT SCALE FROM THIS DRAWING  
ALL DIMENSIONS TO BE CHECKED ON SITE BY THE CONTRACTOR  
AND SUCH DIMENSIONS TO BE HIS RESPONSIBILITY  
REPORT ALL DRAWING ERRORS AND OMISSIONS TO THE ARCHITECT  
IF IN DOUBT ASK CONTRACT ADMINISTRATOR

**m&c**  
mae LLP  
1 Naorog Street, London, WC1X 0GB  
Telephone 020 7704 6060  
www.mae-lp.co.uk.com

job title  
TYBALDS CLOSE ESTATE

drawing title  
DEVONSHIRE TYPICAL UPPER DECK DETAILS

status	TENDER	drawing no	revision
scale	1:5 @ A1	23 623	D
job no	1211		