

18.12.2015

PAGE ①

309

WEST END LAKE - LOWER NW6 1RD

Lifetime Homes - Features

LIFETIME HOMES CRITERIA	KEY OBJECTIVES	DETAILED CRITERIA
1. Parking (width or widening capability) N/A	Provide, or enable by cost effective adaptation, parking that makes getting into and out of the vehicle as convenient as possible for the widest range of people (including those with reduced mobility and/or those with children). General Note: Criterion 1 is not relevant to developments that do not contain any parking provision (for specific requirements refer to Camden Development Policy - DP18 Parking standards and limiting the availability of car parking which specifically discourages on-site parking)	a) 'On plot' (non-communal) parking: Where a dwelling has car parking within its individual plot (or title) boundary, at least one parking space length should be capable of enlargement to achieve a minimum width of 3300mm. b) Communal or shared parking: Where parking is provided by communal or shared bays, spaces should be provided with a width of 3300mm and in accordance with the specification given in Appendix 2 on page 65 or www.lifetimehomes.org.uk .
2. Approach to dwelling from parking (distance, gradients and widths) N/A	Enable convenient movement between the vehicle and dwelling for the widest range of people, including those with reduced mobility and/or those carrying children or shopping.	The distance from the car parking space of Criterion 1 to the dwelling entrance (or relevant block entrance or lift core), should be kept to a minimum and be level or gently sloping. The distance from visitors parking to relevant entrances should be as short as practicable and be level or gently sloping.
3. Approach to all entrances EXISTING ACCESS	Enable, as far as practicable, convenient movement along other approach routes to dwellings (in addition to the principal approach from a vehicle required by Criterion 2) for the widest range of people.	The approach to all entrances should preferably be level or gently sloping, and in accordance with the specification given at www.lifetimehomes.org.uk
4. Entrances EXISTING ACCESS	Enable ease of use of all entrances for the widest range of people. Note: For the purpose of requirements d) and e) of this Criterion, main entrances are deemed to be: the front door to an individual dwelling, the main communal entrance door to a block of dwellings, plus any other entrance door associated with the approach route from parking required by Criterion 2.	All entrances should a) Be illuminated b) Have level access over the threshold, and c) Have effective clear opening widths and nibs as specified given at www.lifetimehomes.org.uk d) In addition, main entrances should also e) Have adequate weather protection* f) Have a level external landing *
5. Communal stairs and lifts EXISTING	Enable access to dwellings above the entrance level to as many people as possible.	a) Communal Stairs Principal access stairs should provide easy access in accordance with the specification given at www.lifetimehomes.org.uk , regardless of whether or not a lift is provided. b) Communal Lifts Where a dwelling is reached by a lift, it should be fully accessible in accordance with the specification given at www.lifetimehomes.org.uk Note: provision of a lift is not a Lifetime Homes requirement, but is recommended where dwellings are not entered at the same level as the main block entrance.
6. Internal doorways and hallways EXISTING	Enable convenient movement in hallways and through doorways.	Movement in hallways and through doorways should be as convenient to the widest range of people, including those using mobility aids or wheelchairs, and those moving furniture or other objects. As a general principle, narrower hallways and landings will need wider doorways in their side walls. The width of doorways and hallways should conform to the specification given at www.lifetimehomes.org.uk .
7. Circulation Space N/A	Enable convenient movement in rooms for as many people as possible.	There should be space for turning a wheelchair in dining areas and living rooms and basic circulation space for wheelchair users elsewhere.

18.12.2015

309

WESTEND LAKE - LONDON NW16 1RD

PAGE 2

Lifetime homes - Features (continued)

LIFETIME HOMES CRITERIA	KEY OBJECTIVES	DETAILED CRITERIA
8. Entrance level living space	Provide accessible socialising space for visitors less able to use stairs.	A living room / living space should be provided on the entrance level of every dwelling (see Appendix 1 on page 65 or www.lifetimehomes.org.uk for definition of 'entrance level'). Note: Entrance level generally means the storey containing the entrance door to the individual dwelling. It may refer to the first storey that contains a room (habitable or non-habitable) if the entrance door leads directly to an 'easy-going' stair.
9. Potential for entrance level bed-space	Provide space for a member of the household to sleep on the entrance level if they are temporarily unable to use stairs	In dwellings with two or more storeys, with no permanent bedroom on the entrance level, there should be space on the entrance level that could be used as a convenient temporary bed-space (see Appendix 1 on page 65 or www.lifetimehomes.org.uk for definition of 'entrance level').
10. Entrance level toilet and shower drainage	Provide an accessible toilet and potential showering facilities for: a) any member of the household using the temporary entrance level bed space of Criterion 9, and b) visitors unable to use stairs.	Where an accessible bathroom, in accordance with Criterion 14, is not provided on the entrance level of a dwelling, the entrance level should have an accessible toilet compartment, with potential for a shower to be installed - as detailed in the specification given at (see Appendix 1 on page 65 or www.lifetimehomes.org.uk for definition of 'entrance level')
11. Toilet and bathroom walls	Ensure future provision of grab rails is possible, to assist with independent use of toilet and bathroom facilities	Walls in all bathrooms and toilet compartments should be capable of firm fixing and support for adaptations such as grab rails.
12. Stairs and potential through-floor lift in dwelling	Enable access to storeys above the entrance level for the widest range of households.	The design within a dwelling of two or more storeys should incorporate both: a) Potential for stair lift installation; and b) A suitable identified space for a through-the-floor lift from the entrance level to a storey containing a main bedroom and a bathroom satisfying Criterion 14.
13. Potential for fitting of hoists and bedroom / bathroom relationship	Assist with independent living by enabling convenient movement between bedroom and bathroom facilities for a wide range of people.	Structure above a main bedroom and bathroom ceilings should be capable of supporting ceiling hoists and the design should provide a reasonable route between this bedroom and the bathroom.
14. Bathrooms	Provide an accessible bathroom that has ease of access to its facilities from the outset and potential for simple adaptation to provide for different needs in the future.	An accessible bathroom, providing ease of access in accordance with the specification given at www.lifetimehomes.org.uk should be provided in every dwelling on the same storey as a main bedroom.
15. Glazing and window handle heights	Enable people to have a reasonable line of sight from a seated position in the living room and to use at least one window for ventilation in each room.	Windows in the principal living space (typically the living room), should allow people to see out when seated. In addition, at least one opening light in each habitable room should be approachable and usable by a wide range of people - including those with restricted movement and reach. Note: In kitchens areas or bathrooms with only one window situated behind kitchen units or bathroom fittings, the requirement for a potential clear approach space to that window need not apply. However, the window handle height/control requirement remains applicable. Any other window within the kitchen area or bathroom, not behind fittings is required to satisfy both the approach and window handle/control height requirements.
16. Location of service controls	Locate regularly used service controls, or those needed in an emergency, so that they are usable by a wide range of household members - including those with restricted movement and limited reach.	Service controls should be within a height band of 450mm to 1200mm from the floor and at least 300mm away from any internal room corner.

N/A

N/A

USE OF SHOWER WC

TO BE PROVIDED - SEE FLOOR PLAN

SEE FLOOR PLANS

SEE FLOOR PLANS

TO BE PROVIDED