


NEW 40MM GAS PIPE TO CONNECT INTO METER AND RUN AT HIGH LEVEL WITHIN BASEMENT. BEFORE PENETRATING FLOOR UP TO GROUND FLOOR LEVEL IN LOCATION AS SHOWN ON M208.



AREA OF CARPET TO BE REPLACED

REFERRED TO AS FIRST FLOOR LOBBY

NOT TO SCALE

INDICATIVE PLANS. ONLY. DUE TO ASBESTOS DEBRIS IN BASEMENT WE ARE UNABLE TO UNDERTAKE A MEASURED SURVEY

M210