

From: Vicki Fox [REDACTED]
Sent: 15 February 2016 12:28
To: Planning
Cc: Jon Finney; [REDACTED]
Subject: Ref: 2015/6812/P - 35 Great James Street, London WC1N 3HB



**Historic
Buildings**

London and Middlesex Archaeological Society - for and behalf of the
Council for British Archaeology

For the attention of James Clarke

This Committee acts on behalf of the Council for British Archaeology in respect of Listed buildings and Applications within the Greater London area. The Committee discussed the above case at its meeting on Tuesday, 26 January 2016 and made the following observations:

The Committee had no objections in principle but maintained that Conditions would be needed to ensure protection of retained internal panelling and archaeology for lowering of the vault floors. Although the Committee were uncertain about the lift opening onto a half-landing, it was estimated that little damage would be caused and was therefore unobjectionable. Materials (bricks/bond/joints) should be Conditioned for the closet wing extension (an exact match would be needed). The roof-lights should be of the heritage type.

Vicki Fox (Hon. Secretary)
LAMAS - Historic Buildings & Conservation Committee