

Audit Query Tracker

Query No	Subject	Query	Status	Date closed out
1	Stability	Trial pits are required to confirm the depth of the foundations and their relationship with the adjoining properties foundation.	Open	
2	Stability	Dependent on the findings of the foundation inspection pits, a ground movement/building damage assessment may be required with proposals for monitoring.	Open	
3	Stability	A geotechnical interpretation is required to justify the design of the underpins and basement slab.	Open	
4	Trees	Due to the proximity of a number of mature trees to the property, evidence is required that the root protection areas will not be disturbed.	Open	