

LDC (Proposed) Report		Application number	2016/0315/P
Officer		Expiry date	
John Diver		10/03/2016	
Application Address		Authorised Officer Signature	
30 Woodyard Close London NW5 4BX			
Conservation Area		Article 4	
N/A		N/A	
Proposal			
The erection of a single storey rear extension.			
Recommendation:		Grant	

Site Description:

The application site contains a two storey, terraced single family dwellinghouse. The application site is not within a Conservation Area and the property is not statutorily or locally listed. There are no Article 4 Directives which might limit Permitted Development rights for the property. There are no trees protected by Tree Preservation Orders on or adjacent to the application site. There is no planning history regarding the application dwelling.

Planning Appraisal:

It is considered that the proposed development would be lawful under Class A, Part 1 of Schedule 2 of the General Permitted Development Order 2015. The reasoning for this consideration may be seen below:

Class A The enlargement, improvement or other alteration of a dwellinghouse		
If yes to any of the questions below the proposal is not permitted development		Yes/no
A.1 (a)	As a result of the works, will the total area of ground covered by buildings within the curtilage of the dwellinghouse (other than the original dwellinghouse) exceed 50% of the total area of the curtilage (excluding the ground area of the original dwellinghouse)?	NO
A.1 (b)	Will the height of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the highest part of the roof of the existing dwellinghouse?	NO
A.1 (c)	Will the height of the eaves of the part of the dwellinghouse enlarged, improved or altered would exceed the height of the eaves of the existing dwellinghouse?	NO
A.1 (d)	Will the enlarged part of the dwellinghouse extend beyond a wall	NO

	which (i) fronts a highway, and (ii) forms either the principal elevation or a side elevation of the original dwellinghouse?	
A.1 (e)	Will the enlarged part of the dwellinghouse have a single storey and (i) extend beyond the rear wall of the original dwellinghouse by more than 4 metres in the case of a detached dwellinghouse, or 3 metres in the case of any other dwellinghouse, or (ii) exceed 4 metres in height?	NO
A.1 (f)	Will the enlarged part of the dwellinghouse have more than one storey and— (i) extend beyond the rear wall of the original dwellinghouse by more than 3 metres, or (ii) be within 7 metres of any boundary of the curtilage of the dwellinghouse opposite the rear wall of the dwellinghouse?	NO
A.1 (g)	Will the enlarged part of the dwellinghouse be within 2 metres of the boundary of the curtilage of the dwellinghouse, and the height of the eaves of the enlarged part exceed 3 metres?	NO
A.1 (h)	Will the enlarged part of the dwellinghouse extend beyond a wall forming a side elevation of the original dwellinghouse, and either (i) exceed 4 metres in height, (ii) have more than one storey, or (ii) have a width greater than half the width of the original dwellinghouse?	NO
A.1(i)	Would it would consist of or include either (i) the construction or provision of a veranda, balcony or raised platform, (ii) the installation, alteration or replacement of a microwave antenna, (iii) the installation, alteration or replacement of a chimney, flue or soil and vent pipe, or (iv) an alteration to any part of the roof of the dwellinghouse?	NO
Is the property in a conservation area? If yes to any of the questions below then the proposal is not permitted development		
A.2(a)	Would it consist of or include the cladding of any part of the exterior of the dwellinghouse with stone, artificial stone, pebble dash, render, timber, plastic or tiles?	N/A
A.2(b)	Would the enlarged part of the dwellinghouse extend beyond a wall forming a side elevation of the original dwellinghouse?	N/A
A.2(c)	Would the enlarged part of the dwellinghouse have more than one storey and extend beyond the rear wall of the original dwellinghouse?	N/A
Conditions. If no to any of the below then the proposal is not permitted development		
A.3(a)	Would the materials used in any exterior work (other than materials used in the construction of a conservatory) be of a similar appearance to those used in the construction of the exterior of the existing dwellinghouse?	YES
A.3(b)	Would any upper-floor window located in a wall or roof slope forming a side elevation of the dwellinghouse be— (i) obscure-glazed, and (ii) non-opening unless the parts of the window which can be opened are more than 1.7 metres above the floor of the room in which the window is installed?	N/A

A.3(c)	Where the enlarged part of the dwellinghouse has more than one storey, would the roof pitch of the enlarged part, so far as practicable, be the same as the roof pitch of the original dwellinghouse?	N/A
--------	---	-----

Recommendation:

As such it is recommended that the Proposed Lawful Development Certificate be granted.