



LAB UK Limited

34 Britannia Court Burnt Mills Industrial Estate Basildon Essex SS13 1EU
Tel 08447 703 349 – Fax 01268 726 143
Email technical@labukltd.co.uk



CLIENT DETAILS

FAO: Jim
Higgins Construction PLC
1 Langston Road

Loughton
Essex
IG10 3SD

BULK ANALYSIS REPORT

Report No: BK 50272
Job No: 115427
Date Sample Booked in: 16-Nov-15
Report Confirmation Date: 16-Nov-15
Order No:
Client Reference:
Sample Source: Brought in by Client

Sample(s) of material were examined with a stereo microscope, polarised light and dispersion staining technique as described in the Company's MAAM 04 Document that incorporates methods set out in the HSG 248. Opinions are not covered by UKAS accreditation. We are not accredited for 'Soil' analysis, we are accredited to analyse elements within soil.

Report For : - Plender Street Camden London NW1 OLG

Samples analysed on 16 November 2015

Sample No	Sample Location/Description	Material Type (See # Note)	Asbestos Fibre Type
50272-1	01 - Stockpile Samples	Cement Based	Chrysotile
50272-2	02 - Stockpile Samples	Cement Based	Chrysotile
50272-3	03 - Stockpile Samples	Cement Based	Chrysotile
50272-4	04 - Stockpile Samples	Cement Based	Chrysotile
50272-5	TP01 - Pit Samples	Cement Based	Chrysotile
50272-6	TP02 - Pit Samples	Cement Based	Chrysotile
50272-7	TP03 - Pit Samples	Cement Based	Chrysotile
50272-8	TP04 - Pit Samples	Cement Based	Chrysotile
50272-9	TP05 - Pit Samples	Cement Based	Chrysotile
50272-10	TP06 - Pit Samples	Cement Based	Chrysotile
50272-11	TP07 - Pit Samples	Cement Based	Chrysotile
50272-12	TP08 - Pit Samples	Cement Based	No Asbestos Detected
50272-13	TP09 - Pit Samples	Cement Based	Chrysotile
50272-14	TP10 - Pit Samples	Cement Based	Chrysotile
50272-15	TP11 - Pit Samples	Cement Based	No Asbestos Detected
50272-16	TP12 - Pit Samples	Cement Based	Chrysotile

Site Comments:

Analysts Signature and Reported by: Kevin Sparrow (Senior Analyst/Surveyor)