



NOTES:

1. Pin bases under rear wall #44 minimum 1100mm below rear ground level.
2. Clay in test pit at pin 1A found to be stiff plastic clay with safe bearing capacity 25000kg/m² from site test.

3m/10ft

PROPOSED REAR WALL LINE - SECTION F-F

44 Downshire Hill, London NW3 1NU

1:20 28Mar16 53035-11

Claymore Design & Build

copyright 2016